

OPTIMIZATION OF ENERGY AND WATER QUALITY COSTS FOR DRINKING WATER UTILITIES



Tara Hawes and Greg Harrington
University of Wisconsin-Madison
Civil and Environmental Engineering





Madison Water Utility



Objectives

- Develop procedure that optimizes pump schedule to minimize energy and energy related costs
- Develop procedure that accounts for water quality costs as part of the optimization
- Develop computer application that utility staff can use to evaluate minimum cost for different operating scenarios

MWU Historical Patterns



MWU Historical Patterns




MWU Energy and Energy Cost Saving Strategies

Reduced Energy


- Lowest Energy Well
- Optimal Flow Rate

Reduced Energy Costs

- Complete Off-Peak
- Partial Off-Peak



Drinking Water Utilities Objectives



Optimization Options

Zone Zone 3 ▼

Zone

Online

Offline

Demand (MGD) 1.15

UW 25 ▼

Require Volume from other Zone

Yes

No

Transfer Method

Booster Station

Pressure Reducing Valve

Percent (%) 20 to 35

From Zone Zone 6e ▼

From BS 115hi ▼

BS 115hi ▼

UW Time-of-Day

Online

Offline

BS Time-of-Day

Online

On-Peak Only

Off-Peak Only

Offline

Zone Fill Zone 6e ▼

Zone Empty Zone 3 ▼

Optimization Option

Energy Costs Only

Operational Costs (Energy and Flushing)

Total Costs (Energy, Flushing, and Health)

Energy Consumption

Month May ▼

Run

Save Setup

Edit Zone Information

Refresh

Status ●

Results

Daily Schedule

Estimations

Zone Zone 6e ▼

Off-Peak Hours

Parameter	7	8	11	13	29	109	115lo
DW Volume (MGD)	1.2800	0.7600	1.4800	1.1700	0.4100	0	0
DW Flow Rate (gpm)	1640	1900	2140	1500	800	0	0
DW Run Time (hr)	13	6.6300	11.5400	13	8.4800	0	0
BP Volume (MGD)	1.2800	0.7600	1.4800	1.1700	0.4100	0	0
BP Flow Rate (gpm)	1750	1040	1900	1500	1100	0	0
BP Run Time (hr)	12.1500	12.1600	13	13	6.1600	0	0

On-Peak Hours

Parameter	7	8	11	13	29	109	115lo
DW Volume (MGD)	0	0	0	0	0	0	0
DW Flow Rate (gpm)	0	0	0	0	0	0	0
DW Run Time (hr)	0	0	0	0	0	0	0
BP Volume (MGD)	0	0	0	0	0	0.5400	0.9600
BP Flow Rate (gpm)	0	0	0	0	0	1070	2400
BP Run Time (hr)	0	0	0	0	0	8.4600	6.6300

Daily

Parameter	7	8	11	13	29	109	115lo
Volume Pumped (MG...)	1.2800	0.7600	1.4800	1.1700	0.4100	0.5400	0.9600
Energy Intensity (kW...)	2010	1820	1860	1510	1970	220	260
Cost Intensity (\$/MG)	139	110	128	103	130	26	34

Zone

- Zone 3
- Zone 4
- Zone 6e**

Unit Well

- 7
- 8
- 11**
- 13

Add UW Delete UW

Test UW Save UW

Billing Rate Structure

- MGE CG-2**
- MGE CG-4

Additional energy intensity (Fixed + Treatment) required to meet billing energy intensity

Additional Energy Intensity (kW/MG)

DW SHC	DW PC	BP SHC	BP PC
Flow Rate (gpm)		Head (ft)	
	0		48.6800
	250		63.0190
	500		77.3580
	750		91.6970
	1000		106.0360
	1250		120.3750
	1500		134.7140

Edit DW SHC


Water Quality Information

Utility **Non-Utility**

Contaminant

Cost per Unidirectional Flush (\$)

95th percentile allowable volume (MG)



DW Flow Rate (gpm)

Operating
 Constrained

Max
Min

BP Flow Rate (gpm)

Operating
 Constrained

Max
Min

Graph DW Graph BP

Ground Reservoir

Storage Capacity

Max Level (ft)

Min Level (ft)

Available Max (ft)

DW/BP Configuration


Normal (BP into Dist)
 DW into Dist

Close


Status

Reset to Original

Energy Optimization



Cost Optimization



Summary

- Off-peak pumping strategies can be used to save MWU's east side:
 - Approximately 30-35% energy related costs
 - Approximately 3-4% energy consumption
- Computer program is usable by staff and allows for flexible input parameters to optimize pumping schedule



Thank You!



Madison Water Utility