

BPW Meeting February 22, 2012:

Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

**4. Beld Street Assessment District**

This project will disturb over an acre, and so will require a City Engineering Erosion Control/Stormwater Management Permit and a Notice of Intent permit from the Wisconsin Department of Natural Resources. **(Lisa Coleman, City Engineering)**

Prepared By: Cheryl Steinfeld

Date: 2-22-12