

BPW Meeting March 26, 2007:

Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

7. Rugby Row, Vista Road, Eton Ridge Assessment District

This project will disturb more than one acre of land, and so will require a Notice of Intent permit from the Department of Natural Resources.

(Chris Petykowski, City Engineering)

25. Sayle Street Warehouse Building

This project will disturb more than 10,000 square feet on the bank of a navigable waterway (Wingra Creek) and includes stream bank restoration and so requires a Chapter 30 permit from the Department of Natural Resources. The permit application has been submitted.

(Genesis Bichanich, City Engineering)

33. Portage/Hanson Road Resurfacing

This project will disturb more than one acre of land, and so will require a Notice of Intent permit from the Department of Natural Resources. There also may be wetland impact associated with this project, which would require a DNR NR103 (Water Quality Certification) permit.

(Mike Cechvala, City Engineering)

Prepared By: *Mike Bichanich*

Date: *3/25/08*