

**PLANNING UNIT REPORT
DEPARTMENT OF PLANNING AND DEVELOPMENT
of May 30, 2006**

RE: I.D. #03756, Demolition Permit – 2553 Upham Street

1. Requested Action: Approval of a demolition permit for a single-family residence at 2553 Upham Street.
2. Applicable Regulations: Section 28.04 (22) provides the guidelines and regulations for the approval of demolition permits.
3. Report Prepared By: Timothy M. Parks, Planner

GENERAL INFORMATION:

1. Applicant & Property Owner: Tim Perry, Operation Fresh Start; 1925 Winnebago Street; Madison.
2. Development Schedule: The applicant wishes to begin demolition as soon as all necessary approvals have been obtained.
3. Parcel Location: An approximately 4,835 square-foot parcel located approximately 250 feet west of North Street on the south side of Upham Street; Aldermanic District 12; Madison Metropolitan School District.
4. Existing Conditions: The site is developed with a fire-damaged single-family residence, zoned R4 (General Residence District).
5. Proposed Use: A new single-family residence.
6. Surrounding Land Use and Zoning: The subject site is generally surrounded by other one and two-family residences in R4 (General Residence District) zoning.
7. Adopted Land Use Plan: The Comprehensive Plan identifies this area for low-density residential uses.
8. Environmental Corridor Status: This property is not located within a mapped environmental corridor.
9. Public Utilities & Services: This property is served by a full range of urban services

STANDARDS FOR REVIEW:

This application is subject to the demolition standards of Section 28.04 (22).

ANALYSIS, EVALUATION AND CONCLUSION:

The applicant is requesting approval of a demolition permit to demolish an existing one-story, 920 square-foot single-family bungalow located at 2553 Upham Street, approximately 250 feet west of North Street. The residence, which City records indicate was built in 1921, contains two bedrooms and one bath and sustained significant damage in a fire in December 2005. The subject site is an approximately 37-foot wide and 130-foot deep lot and is located in an area developed primarily with one and two-family residences in R4 (General Residence District) zoning.

Following demolition, the applicant proposes to construct an approximate architectural replica of the existing bungalow using the existing foundation, which is set back six feet from the Upham Street property line and three feet from the western property line. The only significant change between the existing floorplan and the proposed residence will be the replacement of an exterior basement entrance with an interior basement entrance in the new building off the kitchen. An existing 448 square-foot, detached one-car garage located in the rear yard will remain and will continue to be served by an existing ten-foot wide driveway extending along the eastern property line.

The applicant proposes to replace the fire-damaged structure with a new, more modern structure very similar in appearance and character to the existing residence. According to City records, damage to the existing structure from the December fire was estimated by the Fire Department to be \$100,000, including structural damage to the bedrooms, ceilings and attic. The Planning Unit has no reason to believe that the existing residence should not be demolished and believes that the demolition standards are substantially met with this request.

A reuse and recycling plan approved by the Recycling Coordinator is required by ordinance prior to the issuance of wrecking permit.

RECOMMENDATION

The Planning Unit recommends that the Plan Commission find that the demolition standards are met and **approve** demolition of single-family residence at 2553 Upham Street subject to input at the public hearing and comments from reviewing agencies.



Department of Public Works
City Engineering Division

608 266 4751

Larry D. Nelson, P.E.
City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
608 264 9275 FAX
608 267 8677 TDD

Deputy City Engineer
Robert F. Phillips, P.E.

Principal Engineers
Michael R. Dalley, P.E.
Christina M. Bachmann, P.E.
John S. Fahrney, P.E.
David L. Benzschawel, P.E.
Gregory T. Fries, P.E.

Operations Supervisor
Kathleen M. Cryan

Hydrogeologist
Joseph L. DeMorett, P.G.

GIS Manager
David A. Davis, R.L.S.

DATE: May 15, 2006
TO: Plan Commission
FROM: Larry D. Nelson, P.E., City Engineer
SUBJECT: 2553 Upham Street Demolition

The City Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

- 1. N/A

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

Engineering Division Review of Planned Community Developments, Planned Unit Developments and Conditional Use Applications.

Name: 2553 Upham Street Demolition

General

- 1.1 The construction of this building will require removal and replacement of sidewalk, curb and gutter and possibly other parts of the City's infrastructure. The applicant shall enter into a City / Developer agreement for the improvements required for this development. The applicant shall be required to provide deposits to cover City labor and materials and surety to cover the cost of construction. The applicant shall meet with the City Engineer to schedule the development of the plans and the agreement. The City Engineer will not sign off on this project without the agreement executed by the developer. The developer shall sign the Developer's Acknowledgement prior to the City Engineer signing off on this project.
- 1.2 The site plan shall identify lot and block numbers of recorded Certified Survey Map or Plat.
- 1.3 The site plan shall include all lot/ownership lines, existing building locations, proposed building additions, demolitions, parking stalls, driveways, sidewalks (public and/or private), existing and proposed signage, existing and proposed utility locations and landscaping.
- 1.4 The site plan shall identify the difference between existing and proposed impervious areas. (3)
- 1.5 The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
- 1.6 The site plan shall include a full and complete legal description of the site or property being subjected to this application.

Right of Way / Easements



- 2.1 The Applicant shall Dedicate a _____ foot wide strip of Right of Way along _____.
- 2.2 The Applicant shall Dedicate a _____ foot wide strip of Right of Way along _____.
- 2.3 The Applicant shall Dedicate a Permanent Limited Easement for grading and sloping _____ feet wide along _____.
- 2.4 The City Engineer has reviewed the need for pedestrian and bicycle connections through the development and finds that no connections are required.
- 2.5 The Applicant shall Dedicate a Permanent Limited Easement for a pedestrian / bicycle easement _____ feet wide from _____ to _____.
- 2.6 The Developer shall provide a private easement for public pedestrian and bicycle use through the property running from _____ to _____.
- 2.7 The developer shall be responsible for the ongoing construction and maintenance of a path within the easement. The maintenance responsibilities shall include, but not be limited to, paving, repaving, repairing, marking and plowing. The developer shall work with the City of Madison Real Estate Staff to administer this easement. Applicable fees shall apply.

Streets and Sidewalks

- 3.1 The Applicant shall execute a waiver of notice and hearing on the assessments for the improvement of [roadway] _____ in accordance with Section 66.0703(7)(b) Wisconsin Statutes and Section 4.09 of the MGO.
- 3.2 **Value of sidewalk installation over \$5000.** The Applicant shall Construct Sidewalk to a plan approved by the City Engineer along _____.
- 3.3 **Value of sidewalk installation under \$5000.** The Applicant shall install public sidewalk along _____. The Applicant shall obtain a Street Excavation Permit for the sidewalk work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. All work must be completed within six months or the succeeding June 1, whichever is later.
- 3.4 The Applicant shall execute a waiver of their right to notice and hearings on the assessments for the installation of sidewalk along [roadway] _____ in accordance with Section 66.0703(7)(b) Wisconsin Statutes and Section 4.09 of the MGO.
- 3.5 The Applicant shall grade the property line along _____ to a grade established by the City Engineer. The grading shall be suitable to allow the installation of sidewalk in the future without the need to grade beyond the property line. The Applicant shall obtain a Street Excavation permit prior to the City Engineer signing off on this development.
- 3.6 The Applicant shall close all abandoned driveways by replacing the curb in front of the driveways and restoring the terrace with grass.
- 3.7 **Value of the restoration work less than \$5,000. When computing the value, do not include a cost for driveways. Do not include the restoration required to facilitate a utility lateral installation.** The Applicant's project requires the minor restoration of the street and sidewalk. The Applicant shall obtain a Street Excavation Permit for the street restoration work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees.
- 3.8 The Applicant shall make improvements to _____ in order to facilitate ingress and egress to the development. The improvement shall include a (Describe what the work involves or strike this part of the comment.) _____.
- 3.9 The Applicant shall make improvements to _____. The improvements shall consist of _____.
- 3.10 The approval of this Conditional Use does not include the approval of the changes to roadways, sidewalks or utilities. The applicant shall obtain separate approval by the Board of Public Works and the Common Council for the restoration of the public right of way including any changes requested by developer. The City Engineer shall complete the final plans for the restoration with input from the developer. The curb location, grades, tree locations, tree species, lighting modifications and other items required to facilitate the development or restore the right of way shall be reviewed by the City Engineer, City Traffic Engineer, and City Forester.
- 3.11 The Applicant shall provide the City Engineer with a survey indicating the grade of the existing sidewalk and street. The Applicant shall hire a Professional Engineer to set the grade of the building entrances adjacent to the public right of way. The Applicant shall provide the City Engineer the proposed grade of the building entrances. The City Engineer shall approve the grade of the entrances prior to signing off on this development.
- 3.12 The Applicant shall replace all sidewalk and curb and gutter which abuts the property which is damaged by the construction or any sidewalk and curb and gutter which the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction.
- 3.13 The Applicant shall obtain a privilege in streets agreement for any encroachments inside the public right of way.

The approval of this development does not constitute or guarantee approval of the encroachments.

- 3.14 The Applicant shall provide the City Engineer with the proposed soil retention system to accommodate the restoration. The soil retention system must be stamped by a Professional Engineer. The City Engineer may reject or require modifications to the retention system.
- 3.15 The Applicant shall complete work on exposed aggregate sidewalk in accordance with specifications provided by the city. The stone used for the exposed aggregate shall be approved by the City. The Construction Engineer shall be notified prior to beginning construction. Any work that does not match the adjacent work or which the City Construction Engineer finds is unacceptable shall be removed and replaced.
- 3.16 All work in the public right-of-way shall be performed by a City licensed contractor.

Storm Water Management

- 4.1 The site plans shall be revised to show the location of all rain gutter down spout discharges.
- 4.2 Storm sewer to serve this development has been designed and constructed. The site plans shall be revised to identify the location of this storm sewer and to show connection of an internal drainage system to the existing public storm sewer.
- 4.3 The plan set shall be revised to show a proposed private internal drainage system on the site. This information shall include the depths and locations of structures and the type of pipe to be used.
- 4.5 The applicant shall show storm water "overflow" paths that will safely route runoff when the storm sewer is at capacity.
- 4.6 The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
- 4.7 The City of Madison is an approved agent of the Department of Commerce. This proposal contains a commercial building and as such, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required.
- 4.8 This development includes multiple building permits within a single lot. The City Engineer and/or the Director of the Inspection Unit may require individual control plans and measures for each building.
- 4.9 If the lots within this site plan are inter-dependent upon one another for stormwater runoff conveyance, and/or a private drainage system exists for the entire site an agreement shall be provided for the rights and responsibilities of all lot owners. Said agreement shall be reviewed and placed on file by the City Engineer, referenced on the site plan and recorded at the Dane Co Register of Deeds.
- 4.10 Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to:
 - Detain the 2 & 10-year storm events.
 - Detain the 2, 10, & 100-year storm events.
 - Control 40% TSS (20 micron particle).
 - Control 80% TSS (5 micron particle).
 - Provide infiltration in accordance with NR-151.
 - Provide substantial thermal control.
 - Provide oil & grease control from the first 1/2" of runoff from parking areas.

Stormwater management plans shall be submitted and approved by City Engineering prior to signoff.

- 4.11 The plan set shall be revised to show more information on proposed drainage for the site. This shall be accomplished by using spot elevations and drainage arrows or through the use of proposed contours. It is necessary to show the location of drainage leaving the site to the public right-of-way. It may be necessary to provide information off the site to fully meet this requirement.
- 4.12 A portion of this project comes under the jurisdiction of the US Army Corp of Engineers and WDNR for wetland or flood plain issues. A permit for those matters shall be required prior to construction on any of the lots currently within the jurisdictional flood plain.
- 4.13 The Applicant shall submit, prior to plan sign-off, digital CAD files to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital copies shall be to scale and represent final construction.

CAD submittals can be either AutoCAD (dwg) Version 2001 or older, MicroStation (dgn) Version J or older, or Universal (dxf) formats and contain the following data, each on a separate layer name/level number:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)

- f) Lot lines
- g) Lot numbers
- h) Lot/Plat dimensions
- i) Street names

NOTE: Email file transmissions preferred izenchenko@cityofmadison.com . Include the site address in this transmittal.

- 4.14 NR-151 of the Wisconsin Administrative Code will be effective on October 1, 2004. Future phases of this project shall comply with NR 151 in effect when work commences. Specifically, any phases not covered by a Notice of Intent (NOI) received from the WDNR under NR-216 prior to October 1, 2004 shall be responsible for compliance with all requirements of NR-151 Subchapter III. As most of the requirements of NR-151 are currently implemented in Chapter 37 of the Madison General Ordinances, the most significant additional requirement shall be that of infiltration.

NR-151 requires infiltration in accord with the following criteria. For the type of development, the site shall comply with one of the three (3) options provided below:

Residential developments shall infiltrate 90% of the predevelopment infiltration amount, 25% of the runoff from the 2-year post development storm or dedicated a maximum of 1% of the site area to active infiltration practices.

Commercial development shall infiltrate 60% of the predevelopment infiltration amount, 10% of the runoff from the 2-year post development storm or dedicate a maximum of 2% of the site area to active infiltration practices.

- 4.15 The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or Tim Troester). The digital copies shall be to scale, and shall have a scale bar on the plan set.

PDF submittals shall contain the following information:

- a) Building footprints.
- b) Internal walkway areas.
- c) Internal site parking areas.
- d) Lot lines and right-of-way lines.
- e) Street names.
- f) Stormwater Management Facilities.
- g) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).

- 4.16 The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including:

- a) SLAMM DAT files.
- b) RECARGA files.
- c) TR-55/HYDROCAD/Etc...
- d) Sediment loading calculations

If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided.

Utilities General

- 5.1 The Applicant shall obtain a Street Excavation permit for the installation of utilities required to serve this project. The Applicant shall pay the permit fee, inspection fee and street degradation fee as applicable and shall comply with all the conditions of the permit.
- 5.2 The applicant shall obtain all necessary sewer connection permits and sewer plugging permits prior to any utility work.
- 5.3 All proposed and existing utilities including gas, electric, phone, steam, chilled water, etc shall be shown on the plan.
- 5.4 The applicant's utility contractor shall obtain a connection permit and excavation permit prior to commencing the storm sewer construction.
- 5.5 The site plans shall be revised to show the location of existing utilities, including depth, type, and size in the adjacent right-of-way.
- 5.6 The developer shall provide information on how the Department of Commerce's requirements regarding treatment of storm water runoff, from parking structures, shall satisfied prior to discharge to the public sewer system. Additionally, information shall be provided on which system (storm or sanitary) the pipe shall be connected to.

Sanitary Sewer

- 6.1 Prior to approval of the conditional use application, the owner shall obtain a permit to plug each existing sanitary sewer lateral that serves a building that is proposed for demolition. For each lateral to be plugged the owner shall deposit \$1,000 with the City Engineer in two separate checks in the following amounts: (1). \$100 non-refundable deposit for the cost of inspection of the plugging by City staff; and (2). \$900 for the cost of City crews to perform the plugging. If the owner elects to complete the plugging of a lateral by private contractor and the plugging is inspected and approved by the City Engineer, the \$900 fee shall be refunded to the owner.

- 6.2 All outstanding Madison Metropolitan Sewerage District (MMSD) and City of Madison sanitary sewer connection charges are due and payable prior to connection to the public sewerage system.
- 6.3 Each unit of a duplex building shall be served by a separate and independent sanitary sewer lateral.
- 6.4 The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size and alignment of the proposed service.

()

**CITY OF MADISON
INTERDEPARTMENTAL
CORRESPONDENCE**

Date: May 18, 2006

To: Plan Commission

From: Kathy Voeck, Assistant Zoning Administrator

Subject: 2553 Upham St, Demolition (Operation Fresh Start)

Present Zoning District: R-4

Proposed Use: Demolish a fire damaged house & construct a new single family home on existing foundation.

Conditional Use: 2804(22) Demolition of a principal building requires Plan Com. approval

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project). **NONE.**

GENERAL OR STANDARD REVIEW COMMENTS

1. Note: A fire damaged building can be replaced to its' current bulk.

ZONING CRITERIA

| Bulk Requirements | Required | Proposed |
|--------------------------|-----------------|--------------------------|
| Lot Area | 6,000 sq. ft. | 4,835 sq. ft. (existing) |
| Lot width | 50' | 37' (existing) |
| Usable open space | 500 sq. ft. | adequate |
| Front yard | 25' | 6' (grandfathered) |
| Side yards | 5' 3" | 3' (grandfathered) |
| Rear yard | 35' | provided |
| Building height | 2 stories/35' | 1 story |

| Site Design | Required | Proposed |
|-----------------------|-----------------|-----------------|
| Number parking stalls | 1 | 1 |

| Other Critical Zoning Items | |
|------------------------------------|----|
| Flood plain | No |

With the above conditions, the proposed project **does** comply with all of the above requirements.



CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295

Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: 5/18/06
TO: Plan Commission
FROM: Edwin J. Ruckriegel, Fire Marshal
SUBJECT: **2553 Upham St.**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

2. All portions of the exterior walls of newly constructed one- and two-family dwellings shall be within 500-feet of at least one fire hydrant. Distances are measured along the path **traveled by the fire truck as the hose lays off the truck.** See MGO 34.20 for additional information.

Please contact John Lippitt, MFD Fire Protection Engineer, at 608-261-9658 if you have questions regarding the above items.

cc: John Lippitt

(3)



Department of Planning & Development
 Planning/Inspection/Real Estate/Community & Economic Development
 Mark A. Olinger, Director

Bradley J. Murphy
 Planning Unit
 215 Martin Luther King, Jr. Boulevard
 P.O. Box 2985
 Madison, WI 53701-2985
 (608) 266-4635

REVIEW REQUEST FOR:

- PRELIMINARY PLAT
- FINAL PLAT
- LOT DIVISION/CSM
- CONDITIONAL USE
- DEMOLITION
- REZONING
- INCLUSIONARY ZONING
- OTHER _____

2553 UPHAM STREET
 DEMOLISH FIRE-DAMAGED HOUSE FOR FUTURE SINGLE FAMILY HOME
 TIM PERRY - OPERATION FRESH START

(10)

PLANNING UNIT CONTACT: TIM PAXKS
 RETURN COMMENTS BY: 25 MAY 2006

PLEASE ALSO EMAIL OR FAX ANY COMMENTS TO THE APPLICANT:
 Applicant E-mail: timof3@hotmail.com Fax: 244-8162

Date Submitted: 26 APRIL 2006 Plan Commission: 05 JUNE 2006
 Date Circulated: 02 MAY 2006 Common Council: _____

CIRCULATED TO:

- | | | |
|--|---|---|
| <input type="checkbox"/> ZONING | <input type="checkbox"/> DISABILITY RIGHTS | <input checked="" type="checkbox"/> ALD. <u>Benford</u> DIST. <u>12</u> |
| <input type="checkbox"/> FIRE DEPARTMENT | <input type="checkbox"/> POLICE DEPT. - THURBER | <input type="checkbox"/> MADISON GAS & ELECTRIC |
| <input type="checkbox"/> PARKS DIVISION | <input type="checkbox"/> CITY ASSESSOR - SEIFERT | <input type="checkbox"/> ALLIANT ENERGY |
| <input type="checkbox"/> TRAFFIC ENGINEERING | <input type="checkbox"/> MADISON METRO - SOBOTA | <input type="checkbox"/> SBC |
| <input type="checkbox"/> CITY ENGINEERING | <input type="checkbox"/> BOARD OF EDUCATION C/O SUPT. | <input type="checkbox"/> MID PLAINS TELE |
| <input type="checkbox"/> WATER UTILITY | <input type="checkbox"/> PUBLIC HEALTH - K. VEDDER | <input type="checkbox"/> MT. VERNON TELE |
| <input type="checkbox"/> CDBG - CONSTANS | <input type="checkbox"/> NEIGHBORHOOD ORGANIZATION | _____ |
| <input type="checkbox"/> REAL ESTATE - EKOLA | | _____ |

- Review the above as per time schedule set in Chapter 16.23(5)(b)2; 16.23(5)(3)3; or Chapter 28, City of Madison Ordinance; OR your agency's comments cannot be considered prior to action.
- One copy for your files; one copy for file of appropriate telephone company; PLEASE RETURN one copy with joint comments.
- The above is located in your district. A copy is on file in the Planning & Development Office for review. If you have any questions or comments, contact our office at 266-4635.
- The above is located within or near the limits of your neighborhood organization. A copy is on file in the Planning & Development Office for review. If you have any questions or comments, contact our office at 266-4635.
- A resolution will be before the Common Council within a few weeks regarding this matter.

RETURN COMMENTS TO: PLANNING UNIT, DEPARTMENT OF PLANNING & DEVELOPMENT

NO COMMENTS / YOUR COMMENTS:
Please allow.
Ben Benford.