



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King, Jr. Blvd
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
www.cityofmadison.com

September 19, 2023

Ryan Wilgreen, PLS
Excel Engineering, Inc.
100 Camelot Drive

RE: LNDSCM-2023-00022; Legistar ID 79335 – Certified Survey Map – 1412 Pflaum Road

Dear Ryan Wilgreen:

Your one-lot certified survey of property located at 1412 Pflaum Road, Section 16, Township 07N, Range 10E, City of Madison, Dane County, Wisconsin, is hereby **conditionally approved**. The property is zoned CC-T (Commercial Corridor - Transitional district). The conditions of approval from the reviewing agencies to be satisfied prior to final approval and recording of the CSM are:

Please contact Brenda Stanley of the City Engineering Division at 261-9127 if you have questions regarding the following five (5) items:

1. Per the WDNR closure letter, this property was closed with residual soil and/or groundwater contamination (BRRTS 03-13-543834, CITGO GAS STATION). Written approval from the WDNR is required prior to disturbing the existing barrier cap. Submit copy of WDNR approval letter to Brynn Bemis (608.267.1986, bbemis@cityofmadison.com).
2. Enter into a City / Developer agreement for the required infrastructure improvements. Agreement to be executed prior to sign off. Allow 4-6 weeks to obtain agreement. Contact City Engineering to schedule the development and approval of the plans and the agreement. (MGO 16.23(9)c)
3. Construct sidewalk to a plan as approved by City Engineer
4. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
5. A minimum of two (2) working days prior to requesting City Engineering signoff on the plat/csm contact either Tim Troester (West) at 261-1995 (ttroester@cityofmadison.com) or Brenda Stanley (East) at 608-261-9127 (bstanley@cityofmadison.com) to obtain the final stormwater utility charges that are due and payable prior to sub-division of the properties. The stormwater utility charges (as all utility charges) are due for the previous months of service and must be cleared prior to the land division (and subsequent obsolesces of the existing parcel). (POLICY)

Please contact Jeff Quamme of the City Engineering Division–Mapping Section at 266-4097 if you have questions regarding the following fifteen (15) items:

6. The Utility Easements per the plat of Charles Spaanem Addn through the site shall be released by the Utilities serving the area and the City of Madison. Provide to Jeff Quamme a map exhibit, legal description and \$500 check made out to City of Madison Treasurer to set up the Real Estate project for the City's release. The applicant shall coordinate and provide the recorded releases from the other utilities before the City will release its rights. If the easement is not released prior to the recording of this CSM, it shall be release prior to final sign off for any new construction on the site.
7. This Certified Survey Map application for this property shall be completed and recorded with the Dane County Register of Deeds (ROD), the new parcel data created by the Assessor's Office and the parcel data available to zoning and building inspection staff prior to issuance of building permits for new construction or early start permit.
8. Grant a Public Sidewalk Easement to the City on the face of this Certified Survey Map as required along the south side of this CSM as required for the new public sidewalk with a wider terrace to be constructed along Pflaum Road. Contact Jeff Quamme (jrquamme@cityofmadison.com for the easement text to be placed on the CSM. The easement area shall extend to 1' behind the proposed public sidewalk.
9. Remove the Encroachment Agreement per Document No. 4272925 from the title report as it has been terminated by Document No. 5902916.
10. Place the direct access to USH 51 restriction per the plat of Charles Spaanem Addition on the face of the Certified Survey Map.
11. Provide the recorded document releasing the Agreement per Document No. 5471533
12. Wisconsin Administrative Code A-E 7.08 identifies when Public Land System (PLS) tie sheets must be filed with the Dane County Surveyor's office. The Developer's Surveyor and/or Applicant must submit copies of required tie sheets or monument condition reports (with current tie sheet attached) for all monuments, including center of sections of record, used in this survey, to Jeff Quamme, City Engineering (jrquamme@cityofmadison.com)
13. Prior to Engineering final sign-off by main office for Plats or Certified Survey Maps (CSM), the final Plat or CSM in pdf format must be submitted by email transmittal to Engineering Land Records Coordinator Jeff Quamme (jrquamme@cityofmadison.com) for final technical review and approval. This submittal must occur a minimum of two working days prior to final Engineering Division sign-off.
14. Show and label the 50' wide strip of land dedicated by Document No 0970838 and the area dedicated by the Charles Spaanem Addn along the easterly side of this CSM. The area should also be labeled S Stoughton Rd Service Rd. Correct the width of USH 51 to 230 feet at the northerly end of the CSM and width varies to the south.
15. Add Document No 1097568 to the 20' Setback line text.
16. Remove "FOR CARLYSLE PARTNERS, LLC" from the header on sheet 1.

17. Provide updated title supporting the new owner in the Owner's Certificate and that there is not a mortgage on the lands included in this CSM prior to final CSM sign off.
18. Provide recorded as data from Document No 1564934 on the west and north line of this CSM.
19. The west line of this CSM is substantially shorter than prior surveys and record information. Also the centerline of Pflaum Rd is north of the Section line on this CSM. The plat has the centerline south of the section line. Surveyor shall provide supporting information confirming the location of the right of way.
20. Submit to Jeff Quamme, prior to Engineering sign-off of the subject plat, one (1) digital CADD drawing in a format compatible with AutoCAD. The digital CADD file(s) shall be referenced to the Dane County Coordinate System and shall contain, at minimum, the list of items stated below, each on a separate layer/level name. The line work, closed polylines for all parcels, shall be void of gaps and overlaps and match the final recorded plat:
 - a) Right-of-Way lines (public and private)
 - b) Lot lines
 - c) Lot numbers
 - d) Lot/Plat dimensions
 - e) Street names
 - f) Easement lines (i.e. all shown on the plat including wetland & floodplain boundaries.)

NOTE: This Transmittal is a separate requirement from the required Engineering Streets Section for design purposes. The Developer/Surveyor shall submit new updated final plat, electronic data for any changes subsequent to any submittal.

Please contact Sean Malloy of the Traffic Engineering Division at 266-5987 if you have any questions regarding the following two (2) items:

21. The applicant shall dedicate Right of Way or grant a Public Sidewalk Easement for and be responsible for the construction of a five (5)-foot wide sidewalk, eight (8)-foot terrace, and additional one (1) foot for maintenance along Pflaum Road.
22. The applicant shall dedicate Right of Way or grant a Public Sidewalk Easement for and be responsible for the construction of a five (5)-foot wide sidewalk, eight (8)-foot terrace, and additional one (1) foot for maintenance along S. Stoughton Road Service Road.

Please contact Bill Sullivan of the Fire Department at 886-4691 if you have any questions regarding the following one (1) item:

23. Before the parking easement can be released, the existing building at 2418 S Stoughton Road will need to have the openings along the south wall be updated to comply with the current building code.

Please contact Melissa Hermann of the Office of Real Estate Services at 264-9297 if you have any questions regarding the following sixteen (16) items:

24. Prior to approval sign-off by the Office of Real Estate Services ("ORES"), the Owner's Certificate(s) on the CSM shall be executed by all parties of interest having the legal authority to do so, pursuant to

Wis. Stats. 236.21(2)(a). Said parties shall provide documentation of legal signing authority to the notary or authentication attorney at the time of execution. The title of each certificate shall be consistent with the ownership interest(s) reported in the most recent title report.

25. Prior to CSM approval sign-off, an executed and notarized or authenticated certificate of consent for all mortgagees/vendors shall be included following the Owner's Certificate(s).
26. If a mortgage or other financial instrument is reported in record title, but has been satisfied or no longer encumbers the lands or ownership within the CSM boundary, a copy of a recorded satisfaction or release document for said instrument shall be provided prior to CSM approval sign-off.
27. All ownership consents and certifications for the subject lands shall conform to Wis. Stats. 236.21(2) and 236.29 by including the language ...surveyed, divided, mapped and dedicated....
28. If any portion of the lands within the CSM boundary are subject to an Option to Purchase or other Option interest please include a Certificate of Consent for the option holder and have it executed prior to CSM sign-off, if said ownership interest meets the criteria set forth by Wis. Stat. Sec. 236.34 and Sec. 236.21(2)(a).
29. A Consent of Lessee certificate shall be included on the CSM for all tenant interests in excess of one year, recorded or unrecorded, and executed prior to CSM sign-off.
30. Madison Common Council Certificate: This certificate is required when dedication of land and the conveyance of rights in land are required. For parcels located within the City of Madison, a Madison Common Council Certificate shall appear as follows:

Resolved that this certified survey map located in the City of Madison was hereby approved by Enactment Number _____, File ID Number _____, adopted on the ____ day of _____, 20__, and that said enactment further provided for the acceptance of those lands dedicated and rights conveyed by said Certified Survey Map to the City of Madison for public use.

Dated this ____ day of _____, 2023

Maribeth L. Witzel-Behl, City Clerk
City of Madison, Dane County Wisconsin

31. City of Madison Plan Commission Certificate: Pursuant to Madison City Ordinance Section 16.23(7)(d)3 and Wis. Stats. 236.21(2)(a), all CSM's that are subject to the review and approval of the City of Madison shall contain the following certificate of approval:

Approved for recording per the Secretary of the City of Madison Plan Commission.

By: _____ Date: _____
Matthew Wachter, Secretary of the Plan Commission

32. Register of Deeds Certificate: Please include a space for the Register to hand write the recording info on the date of recording, to appear similar to the following:

Office of the Register of Deeds

Dane County, Wisconsin

Received for recording on _____, 20__ at ____ o'clock__ M, and
recorded in Volume ____ of CSMs on page(s)_____, Document No. _____.

Kristi Chlebowski, Register of Deeds

33. Pursuant to Madison City Ordinance Section 16.23(5)(g)(4), the owner shall furnish an updated title report to ORES via email to Melissa Hermann (mhermann@cityofmadison.com), as well as the survey firm preparing the proposed CSM. The report shall search the period subsequent to the date of the initial title report (xx-xx-xx) submitted with the CSM application and include all associated documents that have been recorded since the initial title report. A title commitment may be provided, but will be considered only as supplementary information to the title report update. Surveyor shall update the CSM with the most recent information reported in the title update. ORES reserves the right to impose additional conditions of approval in the event the title update contains changes that warrant revisions to the CSM.
34. Depict, name, and identify by document number all existing easements cited in record title and the updated title report.
35. Depict and dimension all existing improvements including, but not limited to: buildings, drives, parking lots, encroachments, wells, septic systems, etc. located within the CSM boundary.
36. Depict and dimension public easements for utilities and storm water drainage rights-of-way to be dedicated on the proposed CSM where necessary.
37. If all parties of interest agree that certain easements from prior plats or CSM's of record are no longer necessary, the release documents for said easements shall be recorded prior to CSM approval sign-off, with the recording information for the release included as a Note on the proposed CSM.
38. Liens or judgments levied against the lands within the CSM boundary shall be satisfied, with proof of satisfaction provided prior to CSM approval sign-off.
39. Create notes that define the purpose of and the ownership of (whether public or private) all outlots. The note for an outlot dedicated to the public shall say: "Dedicated to the public for _____ purposes."

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

A resolution approving the CSM and authorizing the City to sign it and any other documents related to the proposed land division will be reviewed by the Common Council at its October 3, 2023 meeting.

Prior to City Engineering final sign-off by the main office of the CSM, the final CSM shall be submitted to the Engineering Division Surveyor/ Land Records Coordinator for final technical review and approval. This


submittal must occur a minimum of two working days prior to final Engineering Division signoff. E-mail submittal of the final CSM in PDF form is preferred. Transmit to jrquamme@cityofmadison.com.

As soon as the comments and conditions have been satisfied, the original along with the revised Certified Survey Map, with all signatures and approvals from the reviewing agencies, shall be brought to this office for final signoff. You or your client may then record the certified survey at the Dane County Register of Deeds. For information on recording procedures and fees, contact the Register of Deeds at 266-4141.

Any appeal from this action, including the conditions of approval, must be filed with the Circuit Court within 30 days from the date of this letter. **The approval of this CSM shall be null and void if not recorded in twelve (12) months from the date of the approving resolution or this letter, whichever is later.**

If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at 243-0455.

Sincerely,

A handwritten signature in black ink, appearing to read 'Colin Punt', with a stylized, flowing script.

Colin Punt
Planner

cc: Brenda Stanley, City Engineering Division
Jeff Quamme, City Engineering Division—Mapping Section
Sean Malloy, Traffic Engineering Division
Bill Sullivan, Fire Department
Melissa Hermann, Office of Real Estate Services