

BPW Meeting June 22, 2011:

Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

**27. Mid Town Road Assessment District**

Project will require a permit from DNR for land disturbance over an acre as well as a City Engineering Erosion Control and Stormwater Permit. (Elia Acosta, City Engineering)

**29. Forsythia Cunette Rehab**

This project may require a DNR Chapter 30 permit for work in a “navigable waterway.” DNR staff is currently reviewing this project. (Lisa Coleman, City Parks)

**30. Kennedy School Storm Bypass & Merryturn Greenway**

This project will likely disturb over an acre, which will require a DNR permit (WRAPP) as well as a City Engineering Erosion Control and Stormwater Permit. (Max Conway, City Engineering)

Prepared By: Genesis Steinert

Date: 6/21/11