



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King, Jr. Blvd
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
www.cityofmadison.com

January 24, 2023

Steve Doran
Galway Companies
800 W Broadway, Ste 400
Monona, WI 53718

RE: Legistar ID 74907 & 74908; Accela 'LNDUSE-2022-00116' -- Approval demolition permit and conditional use at 4522 E Washington Ave

Dear Steve Doran:

At its January 23 meeting, the Plan Commission, meeting in regular session, found the standards met and approved your to demolition permit to raze a multi-tenant commercial building and conditional use to construct a two single story commercial buildings, one of which includes a drive-through, at 4522 East Washington Avenue. In order to receive final approval of your requests, and for any other permits that may need to be issued for your project, the following conditions shall be met:

Please contact Jenny Kirchgatter, Assistant Zoning Administrator at (608) 266-4429 if you have any questions regarding the following twelve (12) items:

1. Reduce the amount of stucco or EIFS used on 4510 E Washington Ave. Per Sec. 28.060(2)(g), Table 28D-1, the use of stucco or EIFS is limited to use at the top of the building and as a trim or accent material. It shall not be used within three feet of the ground or used in heavily trafficked pedestrian areas or where high pedestrian traffic is anticipated.
2. Improve the entrance orientation and entrance visibility of 4510 E Washington Ave. All new buildings shall have a functional entrance oriented to an abutting public street. Additional entrances may be oriented to a private street or parking area. Entries shall be clearly visible and identifiable from the street and delineated with elements such as roof overhangs, recessed entries, landscaping, or similar design features.
3. Section 28.185(9) requires that every applicant for a demolition or removal approval that requires approval by the Plan Commission is required to get a Reuse and Recycling Plan approved by the City Recycling Coordinator, Bryan Johnson at streets@cityofmadison.com prior to receiving a raze permit. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(9) shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.
4. Submit an overall site plan for the planned multi-use site including 2225 Independence Ln.

5. Bicycle parking for the project shall comply with the requirements of Sections 28.141(4)(g) and 28.141(11). Distribute bicycle parking at each building. For a multi-building development, bicycle parking shall be provided for each building. Provide a minimum of two (2) short-term bicycle parking stalls at 4522 E Washington Ave located in a convenient and visible area on a paved or pervious surface. A minimum amount of bicycle parking equal to 5% of capacity of persons is required for the restaurant at 4510 E Washington Ave. Bicycle parking shall be located at least as close as the closest non-accessible automobile parking and within one hundred (100) feet of a principal entrance. Note: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area. Provide a detail of the proposed bike rack.
6. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.
7. Per Sections 28.142(3)(c) and 28.142(4)(e), planting beds or planted areas must contain at least 75% vegetative cover mulched. Mulch shall consist of shredded bark, chipped wood or stone installed at a minimum depth of two (2) inches. If stone is used, it shall be spread over weed barrier fabric.
8. Submit a detail of the trash enclosure. The trash enclosure shall be screened on four (4) sides (including a gate for access) by a solid, commercial-grade wood fence, wall, or equivalent material with a minimum height of six (6) feet and not greater than eight (8) feet.
9. Submit the building floor plans and roof plans for both buildings. The rooftop plans shall show the locations of any proposed rooftop mechanical equipment and screening. All rooftop and ground level mechanical equipment and utilities shall be fully screened from view from any street or residential district per Sections 28.060(2)(f) and 28.142(9)(d). Screens shall be of durable, permanent materials that are compatible with the primary building materials.
10. Identify the spandrel glazed areas on both buildings. Glass on windows and doors shall be clear or slightly tinted, allowing views into and out of the interior. Spandrel glass that mimics the appearance of windows may be used for up to twenty percent (20%) of the required area of the openings. For nonresidential uses at ground floor level, windows and doors or other openings shall comprise at least sixty percent (60%) of the length and at least forty percent (40%) of the area of the ground floor of the primary street facade. At least fifty percent (50%) of windows on the primary street facade shall have the lower sill within three (3) feet of grade.
11. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.
12. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances and Chapter 33 Urban Design District ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

Please contact Brenda Stanley of the City Engineering Division at (608) 261-912 if you have any questions regarding the following fifteen (15) items:

13. Based on Yellow Pages records for 4512 E. Washington Ave., this property operated as a dry cleaner from at least 1987 to 2010 and may contain residual contamination. If contamination is encountered during construction, follow all WDNR and DSPS regulations for proper handling and disposal.
14. The applicant shall connect to or extend public storm sewer connecting directly to a public storm structure that is either in the public sidewalk or terrace area, or inlet at the curb on the side of the street, adjacent to the development. Any storm lateral extension crossing any lanes of traffic or running longitudinally within a public street right of way for over 20ft, in order to connect to the public system, shall be considered a private storm sewer lateral and will require an approved and recorded privilege in streets agreement. (POLICY)
15. Obtain a permit to Excavate in the Right-of-Way for completing the improvements in the public Right-of-Way. The permit application is available on the City Engineering Division website at <http://www.cityofmadison.com/engineering/Permits.cfm>. As a condition of the permit a deposit to cover estimated City expenses will be required.
16. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
17. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
18. Obtain a permit to plug each existing storm sewer. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 37.05(7))
19. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.
20. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.
21. A Storm Water Maintenance Agreement (SWMA) is required for this project. See Storm comments for agreement specific details and requirements.
22. This site appears to disturb over one (1) acre of land and requires a permit from the WDNR for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR216 and NR-151 however a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process. Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line: <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm>.The

applicant is notified that the City of Madison is an approved agent of the Department of Safety and Professional Services (DSPS) and no separate submittal to this agency or CARPC is required for this project to proceed.

23. Revise the site plan to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
24. This site appears to have a land use that will result in their inclusion as a restaurant class sanitary sewer customer. This will charge commercial kitchen facilities a higher sanitary sewer fee per gallon than domestic users and is based on strengths of waste measured at representative similar customers throughout the City. If the applicant desires, a sampling structure may be installed, as part of the initial construction at their cost, to allow site-specific sampling of their waste to determine sanitary sewer charges specifically for this site. If no sampling structure is installed, this site will default to the restaurant class code in MGO Chapter 35. If you have questions on the restaurant class sewer charges please contact Megan Eberhardt at Meberhardt@cityofmadison.com or 608-266-6432.
25. This project will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval. Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html> Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.
26. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.
The Storm Water Management Plan & Report shall include compliance with the following:
Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.
Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))
Rate Control Redevelopment: By design detain the 10-year post construction design storm such that the peak discharge during this event is reduced 15% compared to the peak discharge from the 10-year design storm in the existing condition of the site. Further, the volumetric discharge leaving the post development site in the 10year storm event shall be reduced by 5% compared to the volumetric discharge from the site in an existing condition during the 10-year storm event. These required rate

and volume reductions shall be completed, using green infrastructure that captures at least the first 1/2 inch of rainfall over the total site impervious area. If additional stormwater controls are necessary beyond the first 1/2 inch of rainfall, either green or non-green infrastructure may be used.

TSS Redevelopment with TMDL: Reduce TSS by 80% off of the proposed development when compared with the existing site.

Oil/Grease Control: Treat the first 1/2 inch of runoff over the proposed parking facility and/or drive up window.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

27. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West).

Please contact Julius Smith of the City Engineering Division – Mapping Section at (608) 264-9276 if you have any questions regarding the following five (5) items:

28. Provide for review, comprehensive reciprocal easements and agreements including, but not limited to, access, parking, common areas, that are necessary to accomplish the site development as proposed prior to final sign off. The document(s) shall be executed and recorded prior to building permit issuance. The site as currently designed seems to intend to retain an access drive that was expressly recently released in recent CSM to allow more developable area. if the intent of this design is to continue to allow this cross access on to East Washington Ave Service Road, An agreement will need to be recorded.
29. On Sheets C100 and C101, correctly note that the easement running from East Washington Ave Service Road across the parcel to the adjacent Lot 2 of CSM 15382 is not a Private Access/Emergency Access Easement but rather a Non-Exclusive Private Stormwater Drainage Easement per Document 5577142
30. Remove the second call out for No. 17 (Existing Driveway Easement) shown pointing to the southwesterly easement on sheet C200. This is incorrect. This is a Non-Exclusive Private Stormwater Drainage Easement per Document No. 5577142
31. The address of 4522 E Washington Ave will be retired and archived with the demolition of the current building. The addresses of the 2 new proposed buildings are 4510 E Washington Ave and 4518 E Washington Ave. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
32. The pending Certified Survey Map application for this property shall be completed and recorded with the Dane County Register of Deeds (ROD), the new parcel data created by the Assessor's Office and the parcel data available to zoning and building inspection staff prior to issuance of building permits for new construction.

Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following thirteen (13) items:

33. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be to engineering scale and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
34. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
35. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
36. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
37. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
38. All pedestrian walkways adjacent parking stalls shall be 7 feet wide to accommodate vehicle overhang, signage and impediments to walkway movements. Any request for variance shall be submitted to and reviewed by City Traffic Engineering.
39. The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). Alteration necessary to achieve compliance may include but are not limited to; substitution to transparent materials, removing sections of the structure and modifying or removing landscaping elements. If applicant believes public safety can be maintained they shall apply for a reduction of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the reduction shall be the determination of the City Traffic Engineer.
40. The applicant shall provide a clearly defined 5' walkway from the front door to the public Right of Way clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
41. "Stop" signs shall be installed at a height of seven (7) feet from the bottom of the sign at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.

42. One way operation of the site shall be secured by placing a "One Way" sign at the entrance and a "Do Not Enter" sign at the Exit.
43. Applicant shall submit for review a Commercial Delivery Plan. This plan will include times, vehicle size, use of loading zones and all related turning movements.
44. Developer shall provide a recorded copy of any joint driveway ingress/egress and crossing easements and shall be noted on face of plan.
45. All existing driveway approaches on which are to be abandoned shall be removed and replaced with curb and gutter and noted on the plan.

Please contact Bill Sullivan of the Fire Department at (608) 866-4691 if you have any questions regarding the following two (2) item:

46. Provide documentation on fire access requirements.
47. Establish addresses through City Engineering in accordance with Madison General Ordinances.

Please contact Jeff Heinecke of the Forestry Section at (608) 266-4890 if you have any questions regarding the following eight (8) items:

48. An existing inventory of street trees located within the right of way shall be included on the site, demo, utility, landscape, grading, fire aerial apparatus and street tree plan sets. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.
49. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the street tree plan set.
50. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at (608) 266-4816. Penalties and remediation shall be required. Add as a note on the site, grading, utility, demolition, and street tree plan set.
51. As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry at (608) 266-4816 prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications

can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the site, grading, utility, demolition and street tree plan sets.

52. Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction (website: <https://www.cityofmadison.com/business/pw/specs.cfm>) addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on both the site and street tree plan sets.
53. On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on both the site and street tree plan sets.
54. Street tree pruning shall be coordinated with City Forestry at a minimum of two weeks prior to the start of construction for this project. Contact City Forestry at (608)266-4816. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on both the site and street plan sets.
55. Applicant shall work with City Forestry and Engineering during the right of way design process to address street tree and utility conflicts. Any street tree removals due to utility improvements within the right of way shall be reviewed and approved by the Board of Public Works. Any approval of Privilege in Streets Agreements shall be reviewed by City Forestry for street tree impacts.

Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following three (3) items:

56. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.
57. A Water Meter Application Form and fees must be submitted before connecting to the existing water lateral. Provide at least two working days notice between the application submittal and the scheduled lateral connection/extension. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or

authorized agent is also required to sign the application. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

58. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.

Please contact Jessica Vaughn, Urban Design Commission Secretary, at (608) 267-8740 if you have any questions regarding the following one (1) item:

59. Prior to final sign-off and the issuance of building permits, a complete plan set with the following modifications shall be presented to the Urban Design Commission Secretary for review and approval.
- Add plantings in the parking lot islands.
 - Replace stone mulch with bark mulch with the exception of the island strip adjacent to the angled parking.
 - The applicant shall provide retaining wall details and materials which shall match the adjacent wall details (Aspen Dental).
 - Update the plant list to:
 - Replace four Callery pears on the east side of the Chapter Building with some other small tree such as Astria, Carpinus, small Crabapple, Redbuds, etc.
 - Replace the Black Eyed Susans species with a true perennial version.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your demolition permit and conditional use:


1. After the plans have been revised per the above conditions, please **one (1) complete digital plan set in PDF format** of complete, fully dimensioned, and to-scale plans; the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code; and any other documentation requested herein to the Zoning Administrator at SPRapplications@cityofmadison.com. (Note that that an individual email cannot exceed 20MB and it is the responsibility of the applicant to present files in a manner that can be accepted. Please email zoning@cityofmadison.com regarding questions or if you need alternative filing options) The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
3. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.
4. The conditional use approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a

building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.

5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
6. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0455.

Sincerely,



Colin Punt
 Planner

- cc: Jenny Kirchgatter, Asst. Zoning Administrator
 Brenda Stanley, City Engineering Division
 Julius Smith, City Engineering Division – Mapping
 Sean Malloy, Traffic Engineering Division
 Bill Sullivan, Fire Department
 Jeff Heinecke, Forestry Section
 Jeff Belshaw, Water Utility
 Bryan Johnson, Recycling Coordinator
 Jessica Vaughn, Urban Design Commission Secretary

<p>I hereby acknowledge that I understand and will comply with the above conditions of approvals.</p> <hr style="border: 0; border-top: 1px solid black; margin-bottom: 5px;"/> <p style="text-align: center;"><i>Signature of Applicant</i></p> <hr style="border: 0; border-top: 1px solid black; margin-bottom: 5px;"/> <p style="text-align: center;"><i>Signature of Property Owner (if not the applicant)</i></p>

LNDUSE-2022-00116			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Punt)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Other: Forestry