

BPW Meeting December 1, 2010:

Review of Projects by Engineering Environmental Staff for Impacts to Water Resources

**5. Williamson & Ingersoll Street Reconstruction**

This project will disturb over one acre of land, which will require a WRAPP from the Department of Natural Resources and an Erosion Control/Stormwater Management Permit from City Engineering. **(Jim Wolfe, City Engineering)**

**6. University/Paunack/Forest Resurfacing**

This project will disturb over one acre of land, which will require a WRAPP from the Department of Natural Resources and an Erosion Control/Stormwater Management Permit from City Engineering. **(Glen Yoerger, City Engineering)**

**6. University/Highland/Van Hise/Walnut Reconstruction**

This project will disturb over one acre of land, which will require a WRAPP from the Department of Natural Resources and an Erosion Control/Stormwater Management Permit from City Engineering. **(Glen Yoerger, City Engineering)**

**18. Junction Rd Relief Storm Sewer**

This project will disturb over 4,000 square feet, but less than one acre, which will require an Erosion Control/Stormwater Management Permit from City Engineering only. **(Max Conway, City Engineering)**

**19. Tenney Park Pavillion**

This project will disturb over 10,000 square feet (but less than one acre) on the bank of a navigable waterway, which will require an Individual Chapter 30 permit for grading by the Wisconsin Department of Natural Resources and an Erosion Control/Stormwater Management Permit from City Engineering. **(Tom Maglio, City Parks)**

Prepared By: James Alcindor

Date: 12/30/10