

Madison Water Utility
Status of Unit Wells Offline for Repairs or Upgrades
2/15/2026

Region	Unit Well	Lost Supply (GPM)	Date Offline	Expected Online	Status of Repair/Replacement
C	19	2,300	10/2024	3/2026	Final equipment testing & adjustment
D	28	2,250	12/2025	4/2026	10-Year Inspection & Maintenance

GPM = gallons per minute; 1,000 gpm = 1.44 MGD (million gallons per day)