



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite LL-100
215 Martin Luther King, Jr. Boulevard
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
Fax (608) 267-8739
www.cityofmadison.com

September 30, 2016

Christopher Langkamp
Sooper Dooper, LLC.
1709 S. Park Street, #W
Madison, WI 53713

RE: Approval of the demolition permit to demolish a single-family residence in order to construct a printing and publishing business at **3226 Commercial Avenue**.

Dear Mr. Langkamp:

At its September 19, 2016 meeting, the Plan Commission found the standards met and **approved** your request for a demolition permit to demolish a single-family residence in order to construct a printing and publishing business in the TE District at **3226 Commercial Avenue** subject to the conditions below. In order to receive final approval of the demolition request, and for any necessary permits to be issued for your project, the following conditions shall be met:

Please contact Brenda Stanley, City Engineering, at 261-9127 if you have questions related to these thirteen (13) items:

1. Prior to approval, the owner or owner's representative shall obtain a permit to plug each existing sanitary sewer lateral that serves a building which is proposed for demolition. For each lateral to be plugged the owner shall complete a sewer lateral plugging application and pay the applicable permit fees. The permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
2. All outstanding Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
3. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in a TMDL ZONE. The project will be expected to meet a higher standard of erosion control than the minimum standards set by the WDNR in order to comply with TMDL limits.
4. The Applicant shall submit, prior to plan sign-off but after all revisions have been completed, a digital CAD file (single file) to the Engineering Division with any private storm and sanitary sewer utilities. The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file

submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)
- f) Lot lines or parcel lines if unplatted
- g) Lot numbers or the words unplatted
- h) Lot/Plat dimensions
- i) Street names
- j) Private on-site sanitary sewer utilities (including all connections to public sanitary)
- k) Private on-site storm sewer utilities (including all connections to public storm)

All other levels (contours, elevations, etc) are not to be included with this file submittal.

NOTE: Email CAD file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West). Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement, private on-site sanitary sewer utilities, or private on-site storm sewer utilities during construction will require a new CAD file.

5. The applicant shall submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West). The digital copies shall be to scale, and shall have a scale bar on the plan set. (POLICY and MGO 37.09(2))
PDF submittals shall contain the following information:
 - a) Building Footprints
 - b) Internal Walkway Areas
 - c) Internal Site Parking Areas
 - d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
 - e) Right-of-Way lines (public and private)
 - f) Lot lines or parcel lines if unplatted
 - g) Lot numbers or the words unplatted
 - h) Lot/Plat dimensions
 - i) Street names
 - j) Stormwater Management Facilities
 - k) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).
6. The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including:
 - a) SLAMM DAT files
 - b) RECARGA files
 - c) TR-55/HYDROCAD/Etc

- d) Sediment loading calculations. If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided. (POLICY and MGO 37.09(2))
7. Storm sewer to serve this development has been designed and constructed. The site plans shall be revised to identify the location of this storm sewer and to show connection of an internal drainage system to the existing public storm sewer. (POLICY AND MGO OVER 10,000 SF OF IMPERVIOUS AREA 10.29 and 37.05(7)(b))
 8. Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project. Include copies of all stormwater, utility, and detail plan sheets that contain stormwater practices on 8.5x14 size paper in the draft document. These drawings do not need to be to scale as they are for informational purposes only. Once City Engineering staff have reviewed the draft document and approved it with any required revisions submit a signed and notarized original copy to City Engineering. Include a check for \$30.00 made out to Dane County Register of Deeds for the recording fee. City Engineering will forward the document and fee for recording at the time of issuance of the stormwater management permit. Draft document can be emailed to Tim Troester (west) at ttroester@cityofmadison.com, or Jeff Benedict at jbenedict@cityofmadison.com final document and fee should be submitted to City Engineering.
 9. For Commercial sites < 1 acre in disturbance the City of Madison is an approved agent of the Department of Commerce and WDNR. As this project is on a site with disturbance area less than one (1) acres, and contains a commercial building, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required. (NOTIFICATION)
 10. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to Reduce TSS by 80% off of the proposed development when compared with the existing site.
 11. Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.
 12. All work in the public right-of-way shall be performed by a City licensed contractor. (MGO 16.23(9)(c)5 and MGO 23.01)
 13. All damage to the pavement on Commercial Ave., adjacent to this development shall be restored in accordance with the City of Madison's Pavement Patching Criteria. For additional information please see the following link: <http://www.cityofmadison.com/engineering/patchingCriteria.cfm> (POLICY)

Please contact Jeff Quamme, Engineering Mapping, at 266-4097 if you have questions regarding the following three (3) items:

14. Provide a site demolition plan showing all pavements, utilities and improvements to be removed.

15. Provide a recorded easement/agreement with the adjacent property for the concrete pad and ingress/egress from the emergency entrance shown in the northwest corner of the site.
16. The address of 3226 Commercial Ave will be retired with the demolition of the house. The address of the proposed commercial building is 3228 Commercial Ave. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.

Please contact Eric Halvorson, Traffic Engineering, at 266-6527 if you have any questions regarding the following three (3) items:

17. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
18. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
19. All parking facility design shall conform to MGO standards, as set in section 10.08(6).

Please contact Jenny Kirchgatter, Assistant Zoning Administrator, at 266-4429 if you have any questions regarding the following thirteen (13) items:

20. Revise the plans so that the proposed building exit and 5' x 5' stoop and proposed new air conditioning unit located on the west side of the building do not encroach over the west side property line.
21. Section 28.185(7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson (608-266-4682).
22. Section 28.185(10) Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition.
23. Section 28.185(9)(a) A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.
24. Show the height of the proposed building on the elevations. The minimum height is 22 feet high. Height is the average of the height of all building facades. For each facade, height is measured from the midpoint of the existing grade to the highest point on the roof of the building or structure.

25. A minimum number of two (2) bicycle spaces (the equivalent of one (1) two-sided bike rack) is required for nonresidential uses. Show the dimensions of the bicycle stalls including the access aisle on the site plan. A bicycle stall is a minimum two (2) feet by six (6) feet with a five (5) foot wide access area. Provide a detail of the proposed bike rack.
26. Provide adequate development frontage landscaping per Section 28.142(5) Development Frontage Landscaping.
27. Landscaping and/or ornamental fencing shall be provided between buildings or parking areas and the adjacent street(s), except where buildings are placed at the sidewalk. One (1) overstory deciduous tree and five (5) shrubs shall be planted for each thirty (30) lineal feet of lot frontage. Two (2) ornamental trees or two (2) evergreen trees may be used in place of one (1) overstory deciduous tree. Note that landscaping must be installed on the private property.
28. Show the refuse disposal area on the site plan. All developments, except single family and two family developments, shall provide a refuse disposal area. If the refuse disposal area is located outside the building, it shall be screened on four (4) sides (including a gate for access) by a solid, commercial-grade wood fence, wall, or equivalent material with a minimum height of six (6) feet and not greater than eight (8) feet. Submit a detail of the trash enclosure if provided outside the building.
29. Show the footprint of the proposed air conditioning unit on the site plan and landscape plan. The HVAC unit may not encroach over the property line. Provide a detail of the proposed screening fence for the HVAC unit.
30. Lighting is not required. However, if it is provided, it must comply with City of Madison General Ordinances Section 10.085 outdoor lighting standards. If exterior site lighting is provided, submit an exterior lighting plan and fixture cut sheets with the final plan submittal.
31. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.
32. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

Please contact Bill Sullivan of the Madison Fire Department at 261-9658 if you have any questions regarding the following two (2) items:

33. Provide a sidewalk (or other surface that is maintained from of snow, ice or other obstructions year round) from all required exits out to the public way.
34. Provide proper exterior wall fire ratings based on distance from the property line as required by IBC Chapter 6 & 7.

Please contact Adam Wiederhoeft, Water Utility, at 266-9121 if you have any questions regarding the following item:

35. The Madison Water Utility shall be notified to remove the water meter prior to demolition.

A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least 48-hour notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumberscontractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

The applicant's utility contractor shall obtain an excavation permit prior to commencing the water main construction. This permit application is available on the City Engineering Division website (<http://www.cityofmadison.com/engineering/permits.cfm>).

The Madison Water Utility shall be notified to remove the water meter prior to demolition.

Please contact my office at 261-9135 if you have any questions about the following item:

36. The supplemental regulations state that a limited production and processing use shall be compatible with adjacent nonindustrial uses and shall be accompanied by a retail component. Submit details including a detailed floor plan for the retail component of the project.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining permits for your project:

1. Please revise your plans per the above conditions and submit **eight (8) copies** of a complete, fully dimensioned and scaled plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off. The final site plan shall be accompanied by the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, Room LL-100, Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard. This submittal shall all also include one complete digital plan set in PDF format. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval.
3. Approval of plans for this project does not include any approval to prune, remove or plant trees in the public right-of-way. Permission for such activities must be obtained from the City Forester, 266-4816.

4. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.
5. A reuse and recycling plan approved by the Recycling Coordinator is required by ordinance prior to the issuance of a wrecking permit. The reuse and recycling plan shall be submitted along with the resubmittal of site plans for forwarding to the Recycling Coordinator.
6. The Madison Water Utility shall be notified to remove the water meters prior to demolition. This property is not in a wellhead protection district. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility. The Water Utility will not need to sign off the final plans, and will not need a copy of the approved plans.

If you have any questions regarding obtaining your conditional use, demolition or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 261-9135.

Sincerely,

Chris Wells
Planner

cc: Brenda Stanley, City Engineering
Jeff Quamme, Engineering Mapping
Eric Halvorson, Traffic Engineering
Jenny Kirchgatter, Asst. Zoning Administrator
Bill Sullivan, Fire Department
Adam Wiederhoeft, Water Utility
Bryan Johnson, Recycling Coordinator

I hereby acknowledge that I understand and will comply with the above conditions of approval for the demolition permit.

Signature of Applicant

Signature of Property Owner (if not the applicant)

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Wells)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Other: