



# City of Madison

City of Madison  
Madison, WI 53703  
www.cityofmadison.com

## Agenda - Approved

### BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

---

Tuesday, April 19, 2016

12:15 PM

215 Martin Luther King, Jr. Blvd.  
Room LL-110 (Madison Municipal Building)

---

If you need an interpreter, translator, materials in alternate formats or other accommodations to access this service, activity or program, please call the phone number below immediately.

Si necesita un intérprete, un traductor, materiales en formatos alternativos u otros arreglos para acceder a este servicio, actividad o programa, comuníquese inmediatamente al número de teléfono que figura a continuación.

Yog tias koj xav tau ib tug neeg txhais lus, ib tug neeg txhais ntawv, cov ntaub ntawv ua lwm yam los sis lwm cov kev pab kom siv tau qhov kev pab, kev ua num los sis kev pab cuam no, thov hu rau tus xov tooj hauv qab no tam sim no.

Building Inspections, (608) 266-4551

#### CALL TO ORDER / ROLL CALL

#### APPROVAL OF MINUTES

March 15, 2016: <http://madison.legistar.com/Calendar.aspx>

#### PUBLIC COMMENT

#### DISCLOSURES AND RECUSALS

Members of the body should make any required disclosures or recusals under the City's Ethics Code.

#### PETITION FOR VARIANCE

1      [42502](#)      115 State Street (M-04-20-2016)

Bill Montelbano appealing MGO 29.37(2)(b). The rule requires that all buildings and additions in the Capital Fire District be non-combustible construction. The variance requested is to allow some wood construction. Additional means of safety is being provided by sprinklering the second floor. In addition, sprinkler outlets shall be provided to sprinkler the first floor. The Madison Fire Department supports the variance with sprinklers as noted above.

**Attachments:**    [115 State St.pdf](#)

**ADJOURNMENT**