



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017

215 Martin Luther King, Jr. Blvd

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

www.cityofmadison.com

September 19, 2023

Kevin Burow
Knothe & Bruce Architects
8401 Greenway Blvd #900
Middleton, WI 53562

RE: Legistar ID 79319 & 79320; Accela 'LNDUSE-2023-00054' -- Approval of demolition permit and conditional use at 680 Grand Canyon Drive

Dear Kevin Burow:

At its September 18 meeting, the Plan Commission, meeting in regular session, found the standards met and approved your requests for a demolition permit to raze a multitenant commercial building and conditional use to construct a four-story mixed-use building at 680 Grand Canyon Drive. In order to receive final approval of your requests, and for any other permits that may need to be issued for your project, the following conditions shall be met:

Please contact my office at (608) 243-0455 if you have any questions regarding the following three (3) items, including item 1, which was added by the Plan Commission and item 2, which was modified by the Plan Commission from the originally recommended condition of approval:

1. In order to create a buffer for purposes of resident safety, that the applicant include a change of elevation, fencing, decorative plantings, structural hardscape, or combination of techniques along the front lot line to separate the front green space from the public right of way.
2. That the applicant is strongly encouraged to include noise attenuation measures in the construction of the building, including, but not limited to noise barriers, noise-insulated windows, additional soundproofing within wall insulation, and wall construction techniques. In the event the City of Madison provides financial support, more specific noise mitigation techniques may be required as part of an agreement for said financial support, and such strategies would be reviewed prior to issuance of building permits and inspected at appropriate stages of construction by Building Inspection staff.
3. No HVAC "wall-pack" penetrations/louvers are shown on the street-facing facades. Unless specifically approved by the Plan Commission, the addition of wall packs on outward-facing walls is not included in this approval and will require approval of an alteration to this conditional use should they be proposed at a later time.

Please contact Jacob Moskowitz, Assistant Zoning Administrator at (608) 266-4560 if you have any questions regarding the following three (3) items:

4. Section 28.185(9)(b) requires that every applicant for a demolition or removal approval that requires approval by the Plan Commission is required to get a Reuse and Recycling Plan approved by the City Recycling Coordinator, Bryan Johnson at streets@cityofmadison.com prior to receiving a raze permit. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(9)(b) shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition. A demolition or removal permit is valid for two (2) years from the date of the Plan Commission approval.
5. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.
6. Provide details demonstrating compliance with bird-safe glass requirements Section 28.129. For building façades where the first sixty (60) feet from grade are comprised of less than fifty percent (50%) glass, at least eighty-five percent (85%) of the glass on glass areas fifty (50) square feet or over must be treated. Of all glass areas over fifty (50) square feet, any glass within fifteen (15) feet of a building corner must be treated. All glass railings must be treated. Identify which glass areas are 50 sq. ft. or greater and which glass areas will be treated. Provide a detail of the specific treatment product that will be used.

Please contact Tim Troester of the City Engineering Division at (608) 267-1995 if you have any questions regarding the following sixteen (16) items:

7. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.
8. Enter into a City / Developer agreement for the required infrastructure improvements. Agreement to be executed prior to sign off. Allow 4-6 weeks to obtain agreement. Contact City Engineering to schedule the development and approval of the plans and the agreement. (MGO 16.23(9)c)
9. Construct sidewalk to a plan as approved by City Engineer
10. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
11. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
12. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.

13. A Storm Water Maintenance Agreement (SWMA) is required for this project. See Storm comments for agreement specific details and requirements.
14. This site appears to disturb over one (1) acre of land and requires a permit from the WDNR for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR216 and NR-151 however a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process. Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line: <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm>. The applicant is notified that the City of Madison is an approved agent of the Department of Safety and Professional Services (DSPS) and no separate submittal to this agency or CARPC is required for this project to proceed.
15. Revise the site plan to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
16. Revise the plans to show a proposed private internal drainage system on the site. Include the depths and locations of structures and the type of pipe to be used. (POLICY AND MGO 10.29)
17. The proposed development proposes to construct underground parking. The proposed entrance to the underground parking is adjacent to a street low point. The applicant shall provide at a minimum of one (1) foot of rise from the adjacent back of walk in the driveway before breaking grade to the down ramp to the underground parking to protect the underground parking from inundation. The stated elevation is intended to be protective but does not guarantee a flood proof structure. The Developer/Owner are strongly encouraged to complete their own calculations and determine an elevation that protects their property to a level of service that they are comfortable with.
18. Provide additional detail how the enclosed depression(s) created by the parking entrance(s) to the below building parking area(s) is/are served for drainage purposes. The building must be protected from receiving runoff up through the 100-yr design storm that is current in Madison General Ordinance Chapter 37. If the enclosed depression(s) is/are to be served by a gravity system provide calculations stamped by a Wisconsin P.E. that show inlet and pipe capacities meet this requirement. If the enclosed depression(s) is/are to be served by a pump system provide pump sizing calculations stamped by a Wisconsin P.E. or licensed Plumber that show this requirement has been met.
19. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in a TMDL ZONE and therefore will be regulated to meet a higher standard.
20. This project will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval.
Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html>
Complete weekly self-inspection of the erosion control practices and post these inspections to the

City of Madison website - as required by Chapter 37 of the Madison General Ordinances.

21. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

Rate Control Redevelopment: By design detain the 10-year post construction design storm such that the peak discharge during this event is reduced 15% compared to the peak discharge from the 10-year design storm in the existing condition of the site. Further, the volumetric discharge leaving the post development site in the 10-year storm event shall be reduced by 5% compared to the volumetric discharge from the site in an existing condition during the 10-year storm event. These required rate and volume reductions shall be completed, using green infrastructure that captures at least the first 1/2 inch of rainfall over the total site impervious area. If additional stormwater controls are necessary beyond the first 1/2 inch of rainfall, either green or non-green infrastructure may be used.

TSS Redevelopment with TMDL: Reduce TSS by 80% off of the proposed development when compared with the existing site.

Oil/Grease Control: Treat the first 1/2 inch of runoff over the proposed parking facility and/or drive up window.

100-year Overflow: The applicant shall demonstrate that water can leave the site and reach the public ROW without impacting structures during a 100-year event storm. This analysis shall include reviewing overflow elevations and unintended storage occurring on site when the storm system has reached capacity.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

22. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West).

Please contact Julius Smith of the City Engineering Division – Mapping Section at (608) 264-9276 if you have any questions regarding the following eight (8) items:

23. Any portion(s) of a public easement that is intended to be released shall be released by separate document prepared by City Office of Real Estate Services. Contact Jule Smith of Engineering Mapping (jsmith4@cityofmadison.com) to coordinate the Real Estate project, and associated information and fees required. Proposed development intends to release a portion of a Public Sanitary Sewer Easement along Grand Canyon Drive and release drainage swale restriction along prior land division

line that new structure is proposed over. Provide legal description and exhibit along with fee.

24. For underground encroachments, provide a signed and sealed Plat of Survey and legal description by a Professional Land Surveyor compliant with Chapter A-E 7 of the Wisconsin Administrative Code showing the improvements with a fully dimensioned and legally described three dimensional boundary of the encroachment area. Dimensions tied to a quarter section line and referenced to the Dane County Coordinate System and NAVD 88(91). Provide an electronic copy of the survey (pdf) and legal description (MS Word) to the Land Records Coordinator, (Jule Smith - jsmith4@cityofmadison.com) for review, comment and coordination. The encroachment agreement shall require Applicant/Owner to be a member of Diggers Hotline throughout the term of this agreement and shall adequately mark the location of underground features upon a Digger's Hotline notification. The plans show a Private Storm connection into the West Platte Road Right-of-Way connecting into a new proposed Public Storm Manhole. Provide legal and exhibits for the private lateral or work with Engineering on preferred routing to avoid extended laterals by changing structure locations or adding structures as approved.
25. Coordinate and request from the utility companies serving this area the easements required to serve this development. Those easements shall be properly shown, dimensioned and labeled on the final plat.
26. MGE and Easements along the common lot line between lots 100 and 101 shall be released and recorded prior to CSM recording and building permit or early start permit.
27. Proposed Grading Plan varies from existing and Plat flow arrows along Easterly line per note on Plat seek approval from City Engineering and consider formal release of the this restriction as well.
28. The address of the proposed apartment building is 686 Grand Canyon Dr. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
29. The pending Certified Survey Map application for this property shall be completed and recorded with the Dane County Register of Deeds (ROD), the new parcel data created by the Assessor's Office and the parcel data available to zoning and building inspection staff prior to issuance of building permits or early start permits for new construction.
30. Submit a site plan and a complete building Floor Plan in PDF format to Lori Zenchenko (lzenchenko@cityofmadison.com) that includes a floor plan of each floor level on a separate sheet/page for the development of a complete interior addressing plan. Also, include a unit matrix for apartment buildings. The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) PRIOR to the verification submittal stage of this LNDUSE with The final approved stamped Addressing Plan shall be included in said Site Plan Verification application materials or a revised plan shall provided for additional review and approval by Engineering. Per 34.505 MGO, a full copy of the approved addressing plan shall be kept at the building site at all times during construction until final inspection by the Madison Fire Department. For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved.

Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following sixteen (16) items:

31. The applicant shall dedicate Right of Way or grant a Public Sidewalk Easement for and be responsible for the construction of a five (5)-foot wide sidewalk, eight (8)-foot terrace, and additional one (1) foot for maintenance along Grand Canyon Drive
32. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be to engineering scale and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
33. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
34. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
35. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
36. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
37. All pedestrian walkways adjacent parking stalls shall be 7 feet wide to accommodate vehicle overhang, signage and impediments to walkway movements. Any request for variance shall be submitted to and reviewed by City Traffic Engineering.
38. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
39. The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). Alteration necessary to achieve compliance may include but are not limited to; substitution to transparent materials, removing sections of the structure and modifying or removing landscaping elements. If applicant believes public safety can be maintained they shall apply for a reduction of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the reduction shall be the determination of the City Traffic Engineer.
40. City of Madison radio systems are microwave directional line of sight to remote towers citywide. The building elevation will need to be reviewed by Traffic Engineering to accommodate the microwave sight and building. The applicant shall submit grade and elevations plans if the building exceeds three

stories prior to sign-off to be reviewed and approved by Andrew Oliver, (267-1979, aoliver@cityofmadison.com) Traffic Engineering Shop, 4151 Nakoosa Trail. The applicant shall return one signed approved building elevation copy to the City of Madison Traffic Engineering office with final plans for sign off.

41. The driveway slope to the underground parking is not identified in the plan set, Traffic Engineering recommends driveway slope under 10%; if the slope is to exceed 10%, the applicant shall demonstrate inclement weather mitigation techniques to provide safe ingress/egress to be approved by the City Traffic Engineer.
42. The applicant shall provide a clearly defined 5' walkway clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
43. "Stop" signs shall be installed at a height of seven (7) feet from the bottom of the sign at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
44. The applicant shall show the dimensions for the proposed class III driveway including the width of the drive entrance, width of the flares, and width of the curb cut.
45. All existing driveway approaches on which are to be abandoned shall be removed and replaced with curb and gutter and noted on the plan.
46. Applicant shall submit for review a waste removal plan. This shall include vehicular turning movements.

Please contact Bill Sullivan of the Fire Department at (608) 866-4691 if you have any questions regarding the following one (1) item:

47. Please consider allowing Madison Fire Dept. to conduct training sequences prior to demolition. Contact MFD Training Division to discuss possibilities: Division Chief Jeff Larson at jtlarson@cityofmadison.com or (608) 2665946.

Please contact Kate Kane of the Parks Division at (608) 261-9671 if you have any questions regarding the following one (1) item:

48. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the West Park-Infrastructure Impact Fee district. Please reference ID# 23033 when contacting Parks about this project.

Please contact Brandon Sly of the Forestry Section at (608) 266-4892 if you have any questions regarding the following eight (8) items:

49. An existing inventory of street trees located within the right of way shall be included on the site, demo,

utility, landscape, grading, fire aerial apparatus and street tree plan sets. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.

50. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the street tree plan set.
51. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at (608) 266-4816. Penalties and remediation shall be required. Add as a note on the site, grading, utility, demolition, and street tree plan set.
52. As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry at (608) 266-4816 prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the site, grading, utility, demolition and street tree plan sets.
53. Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction (website: <https://www.cityofmadison.com/business/pw/specs.cfm>) addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on both the site and street tree plan sets.
54. On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on both the site and street tree plan sets.
55. Street tree pruning shall be coordinated with City Forestry at a minimum of two weeks prior to the start of construction for this project. Contact City Forestry at (608)266-4816. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on both the site and street plan sets.
56. Additional street trees are needed for this project. Tree planting specifications can be found in section 209 of City of Madison Standard Specifications for Public Works Construction (website:

<https://www.cityofmadison.com/business/pw/specs.cfm>) - All street tree planting locations and tree species within the right of way shall be determined by City Forestry. A landscape plan and street tree planting plan shall be submitted in PDF format to City Forestry for approval of planting locations within the right of way and tree species. All available street tree planting locations shall be planted within the project boundaries. Add following note on both the landscape and street tree plan sets: At least one week prior to street tree planting, Contractor shall contact City Forestry at (608) 266-4816 to schedule inspection and approval of nursery tree stock and review planting specifications with the landscaper.

Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following one (1) item:

57. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

Please contact Tim Sobota of Metro Transit at (608) 261-4289 if you have any questions regarding the following two (2) items:

58. Metro Transit operates daily all-day transit service along Gammon Road and Odana Road near this property - with trips at least every 30 to 60 minutes.
59. Metro Transit would initially estimate the following counts of potentially eligible trips towards US Green Building Council/LEED Quality Access to Transit points: 69 Weekday & 53 Weekend (average). Please contact Metro Transit if additional analysis would be of interest.

Please contact Trent Schultz of the Parking Utility at (608) 246-5806 if you have any questions regarding the following one (1) item:

60. The applicant shall submit a Transportation Demand Management (TDM) Plan to tdm@cityofmadison.com. The TDM Plan is required per MGO 16.03. Applicable fees will be assessed after the TDM Plan is reviewed by staff.


Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your demolition permit and conditional use:

1. After the plans have been revised per the above conditions, please **one (1) complete digital plan set in PDF format** of complete, fully dimensioned, and to-scale plans; the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code; and any other documentation requested herein to the Zoning Administrator at SPRapplications@cityofmadison.com. (Note that that an individual email cannot exceed 20MB and it is the responsibility of the applicant to present files in a manner that can be accepted. Please email zoning@cityofmadison.com regarding questions or if you need alternative filing options) The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
3. A demolition or removal permit is valid for two (2) years from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to one (1) year from the expiration date.
4. The conditional use approval is valid for two (2) years from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted. Where the plans have not been altered from the Plan Commission's approval, and the conditional use has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to one (1) year from the expiration date.
5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
6. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0455.

Sincerely,



Colin Punt
Planner

cc: Jacob Moskowitz, Asst. Zoning Administrator
Tim Troester, City Engineering Division
Julius Smith, City Engineering Division – Mapping
Sean Malloy, Traffic Engineering Division
Bill Sullivan, Fire Department
Kate Kane, Parks Division
Brandon Sly, Forestry Section
Jeff Belshaw, Water Utility
Tim Sobota, Metro Transit
Trent Schultz, Parking Utility
Bryan Johnson, Recycling Coordinator

I hereby acknowledge that I understand and will comply with the above conditions of approvals.

Signature of Applicant

Signature of Property Owner (if not the applicant)

LNDUSE-2023-00054			
For Official Use Only, Re: Final Plan Routing			
☒	Planning Div. (Punt)	☒	Engineering Mapping Sec.
☒	Zoning Administrator	☒	Parks Division
☒	City Engineering	☐	Urban Design Commission
☒	Traffic Engineering	☒	Recycling Coord. (R&R)
☒	Fire Department	☒	Water Utility
☒	Metro Transit	☒	Forestry
☒	Water Utility		