# PLANNING DIVISION REPORT DEPARTMENT OF PLANNING AND COMMUNITY AND ECONOMIC DEVELOPMENT May 19, 2008

#### RE: I.D. #10406, Demolition Permit and Conditional Use - 5229 Harbor Court

- 1. Requested Action: Approval to relocate a single-family residence and construct a new single-family residence on a lakefront lot.
- 2. Applicable Regulations: Section 28.04 (22) provides the guidelines and regulations for the approval of demolition permits; Section 28.04 (19) provides the standards for waterfront development; Section 28.12 (11) provides the guidelines and regulations for the approval of conditional uses.
- 3. Report Prepared By: Kevin Firchow, AICP, Planner

#### **GENERAL INFORMATION**

- 1. Applicant: Ted and Sandy Halbach; 202 Acadia Dr; Madison, WI 53717
  - Project Contact: Melissa Destree; Destree Design Architects, Inc; 222 West Washington Avenue #310; Madison, WI
- 2. Development Schedule: The applicant wishes to proceed in July/August 2008 with completion scheduled for February 2009.
- 3. Parcel Location: An approximately 8,260 square foot parcel located at 5229 Harbor Court, near its intersection with Lake Mendota Drive; Aldermanic District 19; Madison Metropolitan School District.
- 4. Existing Conditions: The site includes a one-story, ranch-style home zoned R1.
- 5. Proposed Use: The existing home will be relocated and a new two-story, 3,080 square foot residence with attached 771 square foot garage would be constructed.
- 6. Surrounding Land Use and Zoning: The subject site is located on the shores of Lake Mendota surrounded by other single-family residences in R1 (Single-Family Residence District)
- 7. Adopted Land Use Plan: The <u>Comprehensive Plan</u> recommends low-density residential uses in this area.
- 8. Environmental Corridor Status: The site is not located within a mapped environmental corridor, though a portion of the property nearest the lake is located within the flood fringe adjacent to Lake Mendota.

ID #10406 5229 Harbor Court May 19, 2008 Page 2

9. Public Utilities & Services: This property is served by a full range of urban services

#### STANDARDS FOR REVIEW

This application is subject to the demolition standards of Section 28.04 (22), the conditional use standards of Section 28.12 (11) and the waterfront development standards of Section 28.04 (19).

#### ANALYSIS, EVALUATION AND CONCLUSION

The applicant requests approval to relocate the existing single-family home to allow for the construction of new residence on a lakefront lot. The existing home is proposed for relocation to a site outside the City. Relocations are subject to the City's demolition standards. As an alteration to a waterfront property, the project is also subject to the waterfront development and conditional use standards.

The site is an 8,260 square foot parcel with approximately 90 feet of street frontage on Harbor Court and 51 feet of lake frontage. The house is located among a line of other single-family residences of mixed architectural styles. City records indicate the residence was built in 1958 and contains 1,141 square feet of living space, including two bedrooms and one bath. The existing residence is set back approximately 35.6 feet from the ordinary high-water line of the lake. The City's preservation planner notes that the existing residence is of a simple ranch design and is of no known historic or architectural significance. It is not included in the City's Inventory of Historic Places.

The existing residence will be replaced by a two-story, 3,080 square-foot residence that will include three bedrooms, 2.5 bathrooms, and various other living spaces as depicted on the attached floorplans. Building plans also include an attached 771 square foot garage. The residence would primarily be clad in fiber cement siding, made to look like cedar shake siding. The front loaded garage includes decorative carriage-style doors.

Dimensioned elevation drawings show the new structure is just over 23 feet tall, measured halfway between the roof peak and eave. The applicant notes that the second story roof eave has been lowered to better match the height and mass of surrounding homes. The applicant has submitted two supplementary graphics further depicting this relationship. The first is the aforementioned elevation drawing that includes the height of adjacent homes. A second graphic is a photo rendering showing the proposed lakeside elevation and existing residences.

The proposed residence occupies a larger footprint than the previous structure. To illustrate, the new garage is set closer to the street than the existing one. Similarly, the proposed sun porch is closer to the lake than any portion of the current residence. However, the new residence is slightly narrower and side yards are at least nine feet in width on both sides. The Zoning Administrator has determined that the project meets all dimensional requirements, including waterfront setbacks and therefore, no variance is necessary.

ID #10406 5229 Harbor Court May 19, 2008 Page 3

The applicant's landscape plan shows that existing elm, maple, and white oak trees near the water edge will remain. No other notations regarding tree or shrub removal are included on this plan. Staff recommend that the applicant confirm that no more than 30% of the lake frontage will be cleared of trees and shrubbery.

The Planning Division believes that the demolition, conditional use, and waterfront development standards can be met with the applicant's request for new construction. The proposed home is consistent with the Comprehensive Plan's recommendation for low-density residential land use and the Spring Harbor Neighborhood Plan, adopted to guide redevelopment activities in the Spring Harbor neighborhood, which includes the subject site. While the neighborhood plan does not contain specific recommendations for lakefront residential areas, it does encourage that new and redeveloped homes be of a height and scale that is relative to the neighborhood and is sensitive to its natural character. Many new buildings have been approved with a variety of building sizes and architectural styles, and staff believe that the proposed residence would not be out of character with the neighborhood or the adjacent residences.

#### RECOMMENDATION

Subject to input at the public hearing, the Planning Division recommends that the Plan Commission finds the project meets all applicable demolition, waterfront, and conditional use standards and **approve** the proposed request for residence relocation and new construction on a waterfront lot at 5229 Harbor Court, subject to the conditions stated below.

- 1. Comments from reviewing agencies.
- 2. That the applicant confirms on final site or landscape plans that no more than 30% of the lake frontage will be cleared of trees and shrubbery.



## Department of Public Works City Engineering Division

608 266 4751

Larry D. Nelson, P.E. City Engineer

City-County Building, Room 115 210 Martin Luther King, Jr. Boulevard Madison, Wisconsin 53703 608 264 9275 FAX 1 866 704 2315 Textnet

DATE:

May 2, 2008

TO:

Plan Commission

FROM:

Larry D. Nelson, P.E., City Engineer

SUBJECT

5229 Harbor Court Conditional Use and Demolition

Deputy City Engineer Robert F. Phillips, P.E.

Principal Engineers

Michael R. Dailey, P.E. Christina M. Bachmann, P.E. John S. Fahrney, P.E. Gregory T. Frles, P.E.

Facilities & Sustainability Jeanne E. Hoffman, Manager James C. Whitney, A.I.A.

> Operations Manager Kathleen M. Cryan

Hydrogeologist

Joseph L. DeMorett, P.G.

GIS Manager David A. Davis, R.L.S.

Financial Officer Steven B. Danner-Rivers

The City Engineering Division has reviewed the subject development and has the following comments.

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

Shellier

- 1. Applicant shall obtain a Street Terrace Permit for construction of driveway/drive apron within the street right-of-way.
- 2. Any damage to pavement on Harbor Court will require restoration in accordance with the City's Patching Criteria.
- 3. Foundation elevations shall be tied to USGS elevations so that the foundation can be compared to flood plain elevations.

#### **GENERAL OR STANDARD REVIEW COMMENTS**

In addition, we offer the following General or Standard Review Comments:

Engineering Division Review of Planned Community Developments, Planned Unit Developments and Conditional Use Applications.

Name: 5229 Harbor Court Conditional Use and Demolition

#### General

<u> </u>	.1	The construction of this building will require removal and replacement of sidewalk, curb and gutter and possibly other parts of the City's infrastructure. The applicant shall enter into a City / Developer agreement for the improvements required for this development. The applicant shall be required to provide deposits to cover City labor and materials and surety to cover the cost of construction. The applicant shall meet with the City Engineer to schedule the development of the plans and the agreement. The City Engineer will not sign off on this project without the agreement executed by the developer. The developer shall sign the Developer's Acknowledgement prior to the City Engineer signing off on this project.
----------	----	--

1.3	The site plan shall include all lot/ownership lines, existing building locations, proposed building additions, demolitions, parking stalls, driveways, sidewalks (public and/or private), existing and proposed signage, existing
	and proposed utility locations and landscaping.

1.4 The site plan shall identify the difference between existing and proposed impervious areas.

1

	1.5	The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
	1.6	Submit a PDF of all floor plans to Lori Zenchenko <u>Izenchenko@cityofmadison.com</u> so that a preliminary interior addressing plan can be developed. If there are any changes pertaining to the location of a unit, the deletion or addition of a unit, or to the location of the entrance into any unit, (before, during, or after construction) the addresses may need to be changed. The interior address plan is subject to the review and approval of the Fire Marshall.
	1.7	The site plan shall include a full and complete legal description of the site or property being subjected to this application.
	1.8	The Developer is required to pay Impact Fees for theImpact Fee District for Lot(s)of thePlat/CSM. The current rate is \$/1000SF for a total of \$ The Developer shall select one of the following two options for payment of these fees:
		1) Impact Fees shall be paid in full prior to Engineering sign-off of the plat/csm.
		<ol> <li>The Developer has elected to defer the payments until such time as the building permits are applied for, in which case the owner(s) shall have fourteen (14) days after receiving the invoices to pay the outstanding impact fees. The following shall be required <u>prior</u> to plat sign off;</li> </ol>
		<ul> <li>a) The Developer shall supply an Excel spreadsheet with lot numbers, lot areas, and number of dwelling units per lot. The Developer shall supply a CADD file of the proposed FINAL plat, in a format compatible with Microstation</li> </ul>
		J. This information
		shall be required to calculate the Impact Fees, which will then be recorded at the Register of Deeds against each lot in the subdivision
		b) All information shall transmitted to Janet Dailey by e-mail at <u>Jdailey@cityofmadison.com</u> , or on a CD to:
		Janet Dailey City of Madison Engineering Division 210 Martin Luther King Jr. Blvd Room 115 Madison, WI 53703
		<ul> <li>A minimum of three (3) weeks shall be required for staff to calculate the Impact Fees and record the documents prior to plat sign-off.</li> </ul>
		The Developer shall put the following note on the face of the plat:
		ALL THE LOTS WITHIN THIS SUBDIVISION ARE SUBJECT TO IMPACT FEES THAT ARE DUE AND PAYABLE WITHIN FOURTEEN DAYS OF THE ISSUANCE OF BUILDING PERMIT(S).
Right o	of Way /	Easements
	2.1	The Applicant shall Dedicate a foot wide strip of Right of Way along,
	2.2	The Applicant shall Dedicate a foot wide strip of Right of Way along
	2.3	The Applicant shall Dedicate a Permanent Limited Easement for grading and sloping feet wide along
	2.4	The City Engineer has reviewed the need for pedestrian and bicycle connections through the development and finds that no connections are required.
	2.5	The Applicant shall Dedicate a Permanent Limited Easement for a pedestrian / bicycle easement feet wide from
	2.6	The Developer shall provide a private easement for public pedestrian and bicycle use through the property running from to
	2.7	The developer shall be responsible for the ongoing construction and maintenance of a path within the easement. The maintenance responsibilities shall include, but not be limited to, paving, repairing, marking and plowing. The developer shall work with the City of Madison Real Estate Staff to administer this easement. Applicable fees shall apply.
	2.8	The Public Sanitary Sewer Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:
		a. The property owner reserves the right to use and occupy the Public Sanitary Sewer Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not

- interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public sanitary sewer facilities.

  No above-ground improvements shall be located in the Public Sanitary Sewer Easement Area(s) by the City or the property owner, with the exception that grates, sewer access structure (SAS) covers, and other
- access points to the public sanitary sewer facilities shall be permitted at grade level. (Optional: and with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
  c. Plantings and landscaping within the Public Sanitary Sewer Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be
- d. The property owner shall not change the grade of the Public Sanitary Sewer Easement Area(s) without the prior written approval of the City's Engineering Division.
- e. The Public Sanitary Sewer Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.
- The Public Sidewalk Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey
  Map or Subdivision Plat is/are subject to the following conditions:

removed by the City without replacement or compensation to the property owner.

- The property owner reserves the right to use and occupy the Public Sidewalk Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public sidewalk improvements.
- No above-ground improvements will be allowed in the Public Sidewalk Easement Area(s) by the
  property owner. (Optional: with the exception that pavement and/or concrete for driveway purposes
  shall be permitted.)
- c. Plantings and landscaping within the Public Sidewalk Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
- d. The property owner shall not change the grade of the Public Sidewalk Easement Area(s) without the prior written approval of the City's Engineering Division.
- e. The Public Sidewalk Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.
- 2.10 The Public Storm Sewer Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:
  - a. The property owner reserves the right to use and occupy the Public Storm Sewer Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public storm sewer facilities.
  - b. No above-ground improvements shall be located in the Public Storm Sewer Easement Area(s) by the City or the property owner, with the exception that grates, sewer access structure (SAS) covers, and other access points to the public storm sewer facilities shall be permitted at grade level. (Optional: and with the exception that pavement and/or concrete for driveway purposes shall be permitted.)
  - c. Plantings and landscaping within the Public Storm Sewer Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
  - d. The property owner shall not change the grade of the Public Storm Sewer Easement Area(s) without the prior written approval of the City's Engineering Division.

    The Public Storm Sewer Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.
- 2.11 The Public Water Main Easement(s) dedicated to the City of Madison ("City") on the face of this Certified Survey Map or Subdivision Plat is/are subject to the following conditions:
  - a. The property owner reserves the right to use and occupy the Public Water Main Easement Area(s) in a manner consistent with the rights herein conveyed, provided that such use and occupancy shall not interfere with or disturb the installation, operation, maintenance, repair, replacement and/or modification of the public water main facilities.
  - No above-ground improvements will be allowed in the Public Water Main Easement Area(s) by the
    property owner. (Optional: with the exception that pavement and/or concrete for driveway purposes
    shall be permitted.)
  - c. Plantings and landscaping within the Public Water Main Easement Area(s) shall not obstruct routine maintenance by the City. In the event of repair or reconstruction, plantings and landscaping may be removed by the City without replacement or compensation to the property owner.
  - d. The property owner shall not change the grade of the Public Water Main Easement Area(s) without the prior written approval of the City's Engineering Division.
  - e. The Public Water Main Easement(s) may not be amended, modified, terminated, or released without the written consent of all the parties hereto, or their respective successors-in-interest.

#### Streets and Sidewalks

b.

3.1	The Applicant shall execute a waiver of notice and hearing on the assessments for the improvement of [roadway] in accordance with Section 66.0703(7)(b) Wisconsin
	Statutes and Section 4.09 of the MGO.
3.2	Value of sidewalk installation over \$5000. The Applicant shall Construct Sidewalk to a plan approved by the City Engineer along
3.3	Value of sidewalk installation under \$5000. The Applicant shall install public sidewalk along

		The Applicant shall obtain a Street Excavation Permit for the sidewalk work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. All work must be completed within six months or the succeeding June 1, whichever is later. This permit application is available on line at <a href="http://www.cityofmadison.com/engineering/permits.cfm">http://www.cityofmadison.com/engineering/permits.cfm</a> .
	3.4	The Applicant shall execute a waiver of their right to notice and hearings on the assessments for the installation of sidewalk along [roadway] in accordance with Section 66.0703(7)(b) Wisconsin Statutes and Section 4.09 of the MGO.
	3.5	The Applicant shall grade the property line along to a grade established by the City Engineer. The grading shall be suitable to allow the installation of sidewalk in the future without the need to grade beyond the property line. The Applicant shall obtain a Street Excavation permit prior to the City Engineer signing off on this development. This permit application is available on line at <a href="http://www.cityofmadison.com/engineering/permits.cfm">http://www.cityofmadison.com/engineering/permits.cfm</a> .
	3.6	The Applicant shall close all abandoned driveways by replacing the curb in front of the driveways and restoring the terrace with grass.
	3.7	Value of the restoration work less than \$5,000. When computing the value, do not include a cost for driveways. Do not include the restoration required to facilitate a utility lateral installation. The Applicant's project requires the minor restoration of the street and sidewalk. The Applicant shall obtain a Street Excavation Permit for the street restoration work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. This permit application is available on line at <a href="http://www.cityofmadison.com/engineering/permits.cfm">http://www.cityofmadison.com/engineering/permits.cfm</a> .
	3.8	The Applicant shall make improvements to in order to facilitate ingress and egress to the development. The improvement shall include a (Describe what the work involves or strike this part of the comment.)
	3.9	The Applicant shall make improvements to The improvements shall consist of
	3.10	The approval of this Conditional Use does not include the approval of the changes to roadways, sidewalks or utilities. The applicant shall obtain separate approval by the Board of Public Works and the Common Council for the restoration of the public right of way including any changes requested by developer. The City Engineer shall complete the final plans for the restoration with input from the developer. The curb location, grades, tree locations, tree species, lighting modifications and other Items required to facilitate the development or restore the right of way shall be reviewed by the City Engineer, City Traffic Engineer, and City Forester.
	3.11	The Applicant shall provide the City Engineer with a survey indicating the grade of the existing sidewalk and street. The Applicant shall hire a Professional Engineer to set the grade of the building entrances adjacent to the public right of way. The Applicant shall provide the City Engineer the proposed grade of the building entrances. The City Engineer shall approve the grade of the entrances prior to signing off on this development.
	3.12	The Applicant shall replace all sidewalk and curb and gutter which abuts the property which is damaged by the construction or any sidewalk and curb and gutter which the City Engineer determines needs to be replaced because it is not at a desirable grade regardless of whether the condition existed prior to beginning construction.
	3.13	The Applicant shall obtain a privilege in streets agreement for any encroachments inside the public right of way. The approval of this development does not constitute or guarantee approval of the encroachments.
	3.14	The Applicant shall provide the City Engineer with the proposed soil retention system to accommodate the restoration. The soil retention system must be stamped by a Professional Engineer. The City Engineer may reject or require modifications to the retention system.
	3.15	The Applicant shall complete work on exposed aggregate sidewalk in accordance with specifications provided by the city. The stone used for the exposed aggregate shall be approved by the City. The Construction Engineer shall be notified prior to beginning construction. Any work that does not match the adjacent work or which the City Construction Engineer finds is unacceptable shall be removed and replaced.
$\boxtimes$	3.16	All work in the public right-of-way shall be performed by a City licensed contractor.
	3.17	Installation of "Private" street signage in accordance with 10.34 MGO is required.
	3.18,	All street tree locations and tree species within the right of way shall be reviewed and approved by City Forestry. Please submit a tree planting plan (in PDF format) to Dean Kahl, of the City Parks Department - <a href="mailto:dkahl@cityofmadison.com">dkahl@cityofmadison.com</a> or 266-4816.
Storm	Water Ma	anagement
	4.1	The site plans shall be revised to show the location of all rain gutter down spout discharges.
	4.2	Storm sewer to serve this development has been designed and constructed. The site plans shall be revised to identify the location of this storm sewer and to show connection of an internal drainage system to the existing public storm sewer.

4.3	The plan set shall be revised to show a proposed private internal drainage system on the site. This information shall include the depths and locations of structures and the type of pipe to be used.
4.4	The applicant shall show storm water "overflow" paths that will safely route runoff when the storm sewer is at capacity.
4.5	The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
4.6	The City of Madison is an approved agent of the Department of Commerce. This proposal contains a commercial building and as such, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required.
4.7	This development includes multiple building permits within a single lot. The City Engineer and/or the Director of the Inspection Unit may require individual control plans and measures for each building.
4.8	If the lots within this site plan are inter-dependent upon one another for stormwater runoff conveyance, and/or a private drainage system exists for the entire site an agreement shall be provided for the rights and responsibilities of all lot owners. Said agreement shall be reviewed and placed on file by the City Engineer, referenced on the site plan and recorded at the Dane Co Register of Deeds.
4.9	Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to:
	<ul> <li>□ Detain the 2 &amp; 10-year storm events.</li> <li>□ Detain the 2, 10, &amp; 100-year storm events.</li> <li>□ Control 40% TSS (20 micron particle) off of new paved surfaces</li> <li>□ Control 80% TSS (5 micron particle) off of new paved surfaces</li> <li>□ Provide infiltration in accordance with Chapter 37 of the Madison General Ordinances</li> <li>□ Provide substantial thermal control.</li> <li>□ Provide oil &amp; grease control from the first 1/2" of runoff from parking areas.</li> <li>□ Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website — as required by Chapter 37 of the Madison General Ordinances.</li> </ul>
	Stormwater management plans shall be submitted and approved by City Engineering prior to signoff.
4.10	The plan set shall be revised to show more information on proposed drainage for the site. This shall be accomplished by using spot elevations and drainage arrows or through the use of proposed contours. It is necessary to show the location of drainage leaving the site to the public right-of-way. It may be necessary to provide information off the site to fully meet this requirement.
4.11	A portion of this project comes under the jurisdiction of the US Army Corp of Engineers and WDNR for wetland or flood plain issues. A permit for those matters shall be required prior to construction on any of the lots currently within the jurisdictional flood plain.
4.12	The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The single CAD file submittal can be either AutoCAD (dwg) Version 2001 or older, MicroStation (dgn) Version J or older, or Universal (dxf) format and contain only the following data, each on a separate layer name/level number:
	a) Building Footprints b) Internal Walkway Areas c) Internal Site Parking Areas d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.) e) Right-of-Way lines (public and private) f) All Underlying Lot lines or parcel lines if unplatted g) Lot numbers or the words "unplatted" h) Lot/Plat dimensions i) Street names
	All other levels (contours, elevations, etc) are not to be included with this file submittal.
	NOTE: Email file transmissions preferred <a href="mailto:lzenchenko@cityofmadison.com">lzenchenko@cityofmadison.com</a> . Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement during construction will require a new CAD file.
4.13	NR-151 of the Wisconsin Administrative Code will be effective on October 1, 2004. Future phases of this project shall comply with NR 151 in effect when work commences. Specifically, any phases not covered by a Notice of Intent (NOI) received from the WDNR under NR-216 prior to October 1, 2004 shall be responsible for compliance

with all requirements of NR-151 Subchapter III. As most of the requirements of NR-151 are currently implemented in Chapter 37 of the Madison General Ordinances, the most significant additional requirement shall be that of infiltration.

NR-151 requires infiltration in accord with the following criteria. For the type of development, the site shall comply with one of the three (3) options provided below:

Residential developments shall infiltrate 90% of the predevelopment infiltration amount, 25% of the runoff from the 2-year post development storm or dedicated a maximum of 1% of the site area to active infiltration practices.

Commercial development shall infiltrate 60% of the predevelopment infiltration amount, 10% of the runoff from the 2-year post development storm or dedicate a maximum of 2% of the site area to active infiltration practices.

The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or 4,14 Tim Troester). The digital copies shall be to scale, and shall have a scale bar on the plan set. PDF submittals shall contain the following information: a) Building footprints. b) Internal walkway areas. c) Internal site parking areas. d) Lot lines and right-of-way lines. e) Street names. f) Stormwater Management Facilities. g) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans). 4.15 The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including: a) SLAMM DAT files. b) RECARGA files. c) TR-55/HYDROCAD/Etc... d) Sediment loading calculations If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided. The area adjacent to this proposed development has a known flooding risk. All entrances shall be 2-feet above 4.16 the adjacent sidewalk elevation or 1-foot above the 100-year regional flood elevation (whichever is greater). T This includes garage entrances. **Utilities General** The Applicant shall obtain a Street Excavation permit for the installation of utilities required to serve this project. 5.1 The Applicant shall pay the permit fee, inspection fee and street degradation fee as applicable and shall comply with all the conditions of the permit. This permit application is available on line at http://www.cityofmadison.com/engineering/permits.cfm.  $\boxtimes$ The applicant shall obtain all necessary sewer connection permits and sewer plugging permits prior to any utility 5.2 work. This permit application is available on line at <a href="http://www.cityofmadison.com/engineering/permits.cfm">http://www.cityofmadison.com/engineering/permits.cfm</a>. All proposed and existing utilities including gas, electric, phone, steam, chilled water, etc shall be shown on the 5.3 plan. The applicant's utility contractor shall obtain a connection permit and excavation permit prior to commencing the 5.4 storm sewer construction. This permit application is available on line at http://www.cityofmadison.com/engineering/permits.cfm. The site plans shall be revised to show the location of existing utilities, including depth, type, and size in the 5.5 adjacent right-of-way. The developer shall provide information on how the Department of Commerce's requirements regarding treatment 5.6 of storm water runoff, from parking structures, shall satisfied prior to discharge to the public sewer system.

#### Sanitary Sewer

 $\boxtimes$ 

Prior to approval of the conditional use application, the owner shall obtain a permit to plug each existing sanitary sewer lateral that serves a building that is proposed for demolition. For each lateral to be plugged the owner shall deposit \$1,000 with the City Engineer in two separate checks in the following amounts: (1). \$100 non-refundable deposit for the cost of inspection of the plugging by City staff; and (2). \$900 for the cost of City crews to perform the plugging. If the owner elects to complete the plugging of a lateral by private contractor and the plugging is inspected and approved by the City Engineer, the \$900 fee shall be refunded to the owner. This permit application is available on line at <a href="http://www.cityofmadison.com/engineering/permits.cfm">http://www.cityofmadison.com/engineering/permits.cfm</a>.

Additionally, information shall be provided on which system (storm or sanitary) the pipe shall be connected to.

6.2	All outstanding Madison Metropolitan Sewerage District (MMSD) and City of Madison sanitary sewer connection charges are due and payable prior Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Janet Dailey (608-261-9688) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff.
6.3	Each unit of a duplex building shall be served by a separate and independent sanitary sewer lateral.
6.4	The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the

#### CITY OF MADISON INTERDEPARTMENTAL CORRESPONDENCE

Date:

May 19<sup>h</sup> 2008

To:

Plan Commission

From:

Patrick Anderson, Assistant Zoning Administrator

Subject:

5229 Harbor Court

**Present Zoning District:** 

R2

Proposed Use:

Replace and relocation of single family home & construct a new single

family home

**Conditional Use:** 

28.04(22) Removal/relocation of a principal building requires Plan

Commission approval. 28.04(19): Waterfront development/ additions

or alterations to principal buildings in excess of 500 sq. ft. is a

conditional use.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project). **NONE.** 

#### GENERAL OR STANDARD REVIEW COMMENTS

1. Provide a reuse/recycling plan, to be reviewed and approved prior to a demolition permit being issued.

#### ZONING CRITERIA

Bulk Requirements	Required	Proposed
Lot Area	6,000 sq. ft.	8,260 sq. ft.
Lot width	50'	90'
Usable open space	1,000 sq. ft.	Adequate as shown
Front yard	12.5' (setback average)	12' 10"
Side yards	9'(L), 8' 10" (R)	As shown
Rear yard	27'	27' 2"
Building height	Up to 2 stories	2 story

Site Design	Required	Proposed
Number parking stalls	1	2

Other Critical Zoning Items	
Flood plain	Yes
Utility easements	None shown

With the above conditions, the proposed project does comply with all of the above requirements.



### CITY OF MADISON FIRE DEPARTMENT

#### Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295 Phone: 608-266-4484 • FAX: 608-267-1153

|--|

May 14, 2008

TO:

Plan Commission

FROM:

Edwin J. Ruckriegel, Fire Marshal

SUBJECT:

5229 Harbor Court

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1.	none	•					
	·						

#### **GENERAL OR STANDARD REVIEW COMMENTS**

In addition, we offer the following General or Standard Review Comments:

2. As required by MGO 10.34 and IFC 505.1, all residential and commercial buildings must have the approved address posted. The address numbers shall be 4 inches in height, numbers shall be in contrast to the background and visible from the street.

Please contact Scott Strassburg, New Construction Inspector at 608-261-9843 if you have questions regarding the above items.

cc:

Bill Sullivan