



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Agenda - Approved

BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD

Wednesday, February 22, 2017

12:15 PM

J H Findorff & Son Inc
300 S Bedford St, Madison, WI 53703

If you need an interpreter, translator, materials in alternate formats or other accommodations to access this service, activity or program, please call the phone number below immediately.

Si necesita un intérprete, un traductor, materiales en formatos alternativos u otros arreglos para acceder a este servicio, actividad o programa, comuníquese inmediatamente al número de teléfono que figura a continuación.

Yog tias koj xav tau ib tug neeg txhais lus, ib tug neeg txhais ntawv, cov ntaub ntawv ua lwm yam los sis lwm cov kev pab kom siv tau qhov kev pab, kev ua num los sis kev pab cuam no, thov hu rau tus xov tooj hauv qab no tam sim no.

Building Inspection (608) 266-4551

CALL TO ORDER / ROLL CALL

APPROVAL OF MINUTES

December 20, 2016 <http://madison.legistar.com/Calendar.aspx>

PUBLIC COMMENT

DISCLOSURES AND RECUSALS

Members of the body should make any required disclosures or recusals under the City's Ethics Code.

PETITION FOR VARIANCE

- 1 [46071](#) 4802 Femrite Dr (C-02-05-2017)
JSD Inc appealing IBC 1008.1.7. Threshold shall be less than 3/4 of an inch. The variance requested is to have a threshold of six inches in a cooler addition. The Madison Fire Department supports the variance with a contrasting color on the threshold. 16th Ald. Dist.

Attachments: [4802 FEMRITE DR.pdf](#)

- 2 [46069](#) 1402 Chandler St (M-02-06-2017)
Heather Allen of Chads Design Build appealing SPS 321.04 Stairways and Elevated areas. The variance request is to allow a new railing that does not

extend the full flight of stairs. 13th Ald. Dist.

Attachments: [1402 CHANDLER ST.pdf](#)

ADJOURNMENT