City of Madison Fire Department Position Statement

Owner: Alliant Energy Center of Dane County	Project Name: World Dairy Expo Trade Show Temporary Structure	Contact: Daniel W. McGinnis McGinnis & Associates
Address: 1919 Alliant Energy Center Way Madison, WI 53713	Building Location: 1919 Alliant Energy Center Way	Address: 1110 Westmark Drive St. Louis, MO
Owner Phone: 608-267-3985 Email: Clow.carolyn@alliantenergycenter.com	Building Occupancy or Use: Group A-3 Assembly Expo Hall	Phone: 314-835-1224 Email:

Rule Being Petitioned: IBC 903.2.1.3. & 907.2.1.

l have read th	e application for variance and	recommend: (chec	ck appropriate box)
☐ Approval	X Conditional Approval	☐ Denial	□ No Comment

- The structure shall not be erected for more than 60 days.
- Crowd Managers shall comply with IFC Section 403.11.3. regarding number, training, and duties.
- Operational requirements of IFC 3107 shall be adhered to.
- Any hazardous materials including flammable/combustible gases & liquids shall not exceed the maximum
 allowable quantities and shall comply with all use and storage requirements addressed in MGO 34 & the IFC.
- · Adjust booth layouts such that the short aisles align or mostly align with the proposed exit doors.

Name of Fire Chief or Designee (type or print) Bill Sullivan, Fire Protection Engineer	
City of Madison Fire Department	Telephone Number 608-261-9658
Signature of Fire Chief proesignee	Date Signed December 13, 2021