



Department of Planning & Community & Economic Development

## Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017  
215 Martin Luther King, Jr. Blvd  
P.O. Box 2985  
Madison, Wisconsin 53701-2985  
Phone: (608) 266-4635  
[www.cityofmadison.com](http://www.cityofmadison.com)

November 28, 2022

Colleen O'Meara  
EUA  
309 W Johnson St #202  
Madison, WI 53703

RE: Legistar ID 73820 & 74082; Accela 'LNDUSE-2022-00085' -- Approval of demolition permit and zoning map amendment at 2405 Cypress Way, 825-837 Hughes Place, and 810 West Badger Road

Dear Colleen:

At its November 7 meeting, the Plan Commission, meeting in regular session, found the standards met and approved your demolition permit to raze a commercial building at 833 Hughes Place. At its November 22 meeting, Common Council, meeting in regular session, found the standards met and approved your zoning map amendment to change the zoning at 2405 Cypress Way, 825-837 Hughes Place, and 810 West Badger Road from SR-V1 (Suburban Residential-Varied 1) District and CC-T (Commercial Corridor - Transitional) District to CC-T. In order to receive final approval of your requests, and for any other permits that may need to be issued for your project, the following conditions shall be met:

**Please contact Jacob Moskowitz, Assistant Zoning Administrator at (608) 266-4560 if you have any questions regarding the following nine (9) items:**

1. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect. Provide adequate development frontage landscaping per section 28.142(5) Development Frontage Landscaping. Landscaping and/or ornamental fencing shall be provided between buildings or parking areas and the adjacent street(s), except where buildings are placed at the sidewalk. Note that landscaping must be installed on the private property.
2. Submit a detail showing the model of bike rack to be installed. NOTE: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area.
3. Screening is required adjacent the Zoning district boundary along the south property lines. Screening shall be provided along side and rear property boundaries between commercial/ mixed-use districts and residential districts. Screening shall consist of a solid wall, solid fence, or hedge with year-round foliage, between six (6) and eight (8) feet in height. Submit a detail of the existing screening fence with the final plans.
4. Provide specifications of the bird-safe glass treatment to be used.

5. Provide details showing that the primary street façade meets the door and window opening requirements of Section 28.060(2)(d). For nonresidential uses at ground floor level, windows and doors or other openings shall comprise at least sixty percent (60%) of the length and at least forty percent (40%) of the area of the ground floor of the primary street facade. At least fifty percent (50%) of windows on the primary street facade shall have the lower sill within three (3) feet of grade.
6. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.
7. Section 28.185(7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson (608-266-4682).
8. Section 28.185(10) Every person who is required to submit a reuse and recycling plan pursuant to Sec. 28.185(7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition.
9. Section 28.185(9)(a) A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.

**Please contact Tim Troester of the City Engineering Division at (608) 267-1995 if you have any questions regarding the following fourteen (14) items:**

10. The applicant shall connect to or extend public storm sewer connecting directly to a public storm structure that is either in the public sidewalk or terrace area, or inlet at the curb on the side of the street, adjacent to the development. Any storm lateral extension crossing any lanes of traffic or running longitudinally within a public street right of way for over 20ft, in order to connect to the public system, shall be considered a private storm sewer lateral and will require an approved and recorded privilege in streets agreement. (POLICY)
11. Obtain a permit to Excavate in the Right-of-Way for completing the improvements in the public Right-of-Way. The permit application is available on the City Engineering Division website at <http://www.cityofmadison.com/engineering/Permits.cfm>. As a condition of the permit a deposit to cover estimated City expenses will be required.
12. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
13. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
14. An Erosion Control Permit is required for this project. See Storm comments for permit specific details

and requirements.

15. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.
16. A Storm Water Maintenance Agreement (SWMA) is required for this project. See Storm comments for agreement specific details and requirements.
17. This site appears to disturb less than one (1) acre of land. No submittal to the WDNR, CARPC or Department of Safety and Professional Services (DPS) is required as the City of Madison Building Inspection Department is an approved agent for DPS.
18. Revise the site plan to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
19. Provide additional detail how the enclosed depression(s) created by the parking entrance(s) to the below building parking area(s) is/are served for drainage purposes. The building must be protected from receiving runoff up through the 100-yr design storm that is current in Madison General Ordinance Chapter 37. If the enclosed depression(s) is/are to be served by a gravity system provide calculations stamped by a Wisconsin P.E. that show inlet and pipe capacities meet this requirement. If the enclosed depression(s) is/are to be served by a pump system provide pump sizing calculations stamped by a Wisconsin P.E. or licensed Plumber that show this requirement has been met.
20. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in a TMDL ZONE and therefore will be regulated to meet a higher standard.
21. This project will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at [meberhardt@cityofmadison.com](mailto:meberhardt@cityofmadison.com), or Daniel Olivares (east) at [daolivares@cityofmadison.com](mailto:daolivares@cityofmadison.com), for approval.  
Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html>  
This project appears to require fire system testing that can result in significant amounts of water to be discharged to the project grade. The Contractor shall coordinate this testing with the erosion control measures and notify City Engineering 608-266-4751 prior to completing the test to document that appropriate measures have been taken to prevent erosion as a result of this testing.  
Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.
22. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

This site will have a mix of new and redevelopment requirements noted below.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

Rate Control New Development: Detain the 2, 5, 10, 100, & 200 - year storm events, matching post development rates to predevelopment rates and using the design storms identified in Madison General Ordinances Chapter 37.

Rate Control Redevelopment: By design detain the 10-year post construction design storm such that the peak discharge during this event is reduced 15% compared to the peak discharge from the 10-year design storm in the existing condition of the site. Further, the volumetric discharge leaving the post development site in the 10-year storm event shall be reduced by 5% compared to the volumetric discharge from the site in an existing condition during the 10-year storm event. These required rate and volume reductions shall be completed, using green infrastructure that captures at least the first 1/2 inch of rainfall over the total site impervious area. If additional stormwater controls are necessary beyond the first 1/2 inch of rainfall, either green or non-green infrastructure may be used.

Infiltration: Provide infiltration of 90% of the pre-development infiltration volume.

TSS New Development: Reduce TSS by 80% (control the 5-micron particle) off of newly developed areas compared to no controls.

TSS Redevelopment with TMDL: Reduce TSS by 80% off of the proposed development when compared with the existing site.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

23. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: [bstanley@cityofmadison.com](mailto:bstanley@cityofmadison.com) (East) or [ttroester@cityofmadison.com](mailto:ttroester@cityofmadison.com) (West).

**Please contact Julius Smith of the City Engineering Division – Mapping Section at (608) 264-9276 if you have any questions regarding the following six (6) items:**

24. Prepare a description and exhibit for the release of the 5' wide utility Easement Per the First Addition to Burr Oaks, that will conflict with the proposed development. This shall be released prior to any construction. Any portion(s) of a public easement that is intended to be released shall be released by separate document prepared by City Office of Real Estate Services. Contact Jule Smith of Engineering Mapping ([jsmith4@cityofmadison.com](mailto:jsmith4@cityofmadison.com), 608-264-9276) to coordinate the Real Estate project, and associated information and fees required.
25. Coordinate and request from the utility companies serving this area the easements required to serve this development. Those easements shall be properly shown, dimensioned and labeled on the forthcoming CSM.
26. Identify on the plans the lot and block numbers of recorded Certified Survey Map or Plat.

27. Provide a full and complete legal description of the site or property being subjected to this application on the site plan.
28. The proposed new building crosses an underlying platted lot line. Prepare a Certified Survey Map (CSM) and submit to the Planning Unit to dissolve underlying lot lines to comply with fire codes, City Ordinances and City Policies. The CSM shall be approved by the City, recorded with the Dane County Register of Deeds and new Tax Parcel information available prior to issuance of a building or early start permit.
29. The address of the proposed building is 2403 Cypress Way. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.

**Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following twelve (12) items:**

30. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be to engineering scale and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
31. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
32. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
33. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
34. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
35. All pedestrian walkways adjacent parking stalls shall be 7 feet wide to accommodate vehicle overhang, signage and impediments to walkway movements. Any request for variance shall be submitted to and reviewed by City Traffic Engineering.
36. The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). Alteration necessary to achieve compliance may include but are not limited to; substitution to transparent materials, removing sections of the structure and

modifying or removing landscaping elements. If applicant believes public safety can be maintained they shall apply for a reduction of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the reduction shall be the determination of the City Traffic Engineer.

37. The applicant shall provide a clearly defined 5' walkway from the front door to the public Right of Way clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
38. The driveway slope to the underground parking is not identified in the plan set, Traffic Engineering recommends driveway slope under 10%; if the slope is to exceed 10%, the applicant shall demonstrate inclement weather mitigation techniques to provide safe ingress/egress to be approved by the City Traffic Engineer.
39. All existing driveway approaches on which are to be abandoned shall be removed and replaced with curb and gutter and noted on the plan.
40. Applicant shall submit for review a waste removal plan. This shall include vehicular turning movements.
41. Applicant shall submit for review a Commercial Delivery Plan. This plan will include times, vehicle size, use of loading zones and all related turning movements.

**Please contact Brandon Sly of the Forestry Section at (608) 266-4816 if you have any questions regarding the following twelve (12) items:**

42. An existing inventory of street trees located within the right of way shall be included on the site, demo, utility, landscape, grading, fire aerial apparatus and street tree plan sets. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.
43. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the street tree plan set.
44. City Forestry will issue a street tree removal permit for (X) tree(s) (dbh) diameter (variety) tree due to (reason) at (location). The Contractor shall contact City Forestry at (608)266-4816 to obtain permit. Add as a note on both the demolition and street tree plan set.
45. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at (608) 266-4816.

Penalties and remediation shall be required. Add as a note on the site, grading, utility, demolition, and street tree plan set.

46. As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry at (608) 266-4816 prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the site, grading, utility, demolition and street tree plan sets.
47. Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction (website: <https://www.cityofmadison.com/business/pw/specs.cfm>) addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on both the site and street tree plan sets.
48. On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on both the site and street tree plan sets.
49. Street tree pruning shall be coordinated with City Forestry at a minimum of two weeks prior to the start of construction for this project. Contact City Forestry at (608)266-4816. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on both the site and street plan sets.
50. The Developer shall submit a Street Tree Report performed by International Society of Arboriculture Certified Arborist prior to the Plan Commission meeting for City Forestry's review of project. This report shall identify all street trees on proposed project site, species type, canopy spread, tree condition, proposed tree removals, the impacts of proposed construction, and any requested pruning.
51. The Developer shall post a security deposit prior to the start of the development to be collected by City Engineering as part of the Developers Agreement. In the event that street trees are damaged during the construction process, City Forestry will draw from this deposit for damages incurred.
52. Additional street trees are needed for this project. Tree planting specifications can be found in section 209 of City of Madison Standard Specifications for Public Works Construction (website: <https://www.cityofmadison.com/business/pw/specs.cfm>) - All street tree planting locations and tree species within the right of way shall be determined by City Forestry. A landscape plan and street tree planting plan shall be submitted in PDF format to City Forestry for approval of planting locations within the right of way and tree species. All available street tree planting locations shall be planted within the project boundaries. Add following note on both the landscape and street tree plan sets: At least one week prior to street tree planting, Contractor shall contact City Forestry at (608) 266-4816 to schedule inspection and approval of nursery tree stock and review planting specifications with the landscaper.

53. Applicant shall work with City Forestry and Engineering during the right of way design process to address street tree and utility conflicts. Any street tree removals due to utility improvements within the right of way shall be reviewed and approved by the Board of Public Works. Any approval of Privilege in Streets Agreements shall be reviewed by City Forestry for street tree impacts.

**Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following one (1) item:**

54. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

**Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.**


**Please now follow the procedures listed below for obtaining your demolition permit and conditional use:**

1. After the plans have been revised per the above conditions, please submit **one (1) complete digital plan set in PDF format** of complete, fully dimensioned, and to-scale plans; the appropriate site plan review application and [site plan review fee pursuant to Section 28.206](#) of the Zoning Code; and any other documentation requested herein to the Zoning Administrator at [SPRapplications@cityofmadison.com](mailto:SPRapplications@cityofmadison.com). (Note that that an individual email cannot exceed 20MB and it is the responsibility of the applicant to present files in a manner that can be accepted. Please email [zoning@cityofmadison.com](mailto:zoning@cityofmadison.com) regarding questions or if you need alternative filing options) The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
3. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.



If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0455.

Sincerely,



Colin Punt  
 Planner

- cc: Jacob Moskowitz, Asst. Zoning Administrator  
 Tim Troester, City Engineering Division  
 Julius Smith, City Engineering Division – Mapping  
 Sean Malloy, Traffic Engineering Division  
 Jeff Belshaw, Water Utility  
 Brandon Sly, Forestry Section  
 Bryan Johnson, Streets Division

I hereby acknowledge that I understand and will comply with the above conditions of approvals.

\_\_\_\_\_  
*Signature of Applicant*

\_\_\_\_\_  
*Signature of Property Owner (if not the applicant)*

LNDUSE-2022-00085			
For Official Use Only, Re: Final Plan Routing			
<input type="checkbox"/>	Planning Div. (Punt)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Other: Forestry