



Department of Planning & Community & Economic Development

## Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017  
215 Martin Luther King, Jr. Blvd  
P.O. Box 2985  
Madison, Wisconsin 53701-2985  
Phone: (608) 266-4635  
[www.cityofmadison.com](http://www.cityofmadison.com)

**\*\*BY E-MAIL ONLY\*\***

January 17, 2023

Mike Oates  
Eppstein Uhen Architects  
309 W Johnson Street, 202  
Madison, WI 53703

RE: Consideration of a demolition permit to demolish a public parking garage; Consideration of a Zoning Map Amendment from the Urban Mixed-Use (UMX) District to Planned Development District-General Development Plan-Specific Implementation Plan (PD-GDP-SIP); Consideration of a conditional use to allow the elevator penthouse of a building or structure located within one mile of the center of the State Capitol Building to exceed the elevation of the base of the columns of said Capitol Building or one hundred eighty-seven and two-tenths (187.2) feet, City datum (§28.134(3) MGO). (ID [74054](#), [74426](#), [74055](#) LNDUSE-2022-00092)

Dear Mike Oates:

On December 12, 2022, the Plan Commission found the standards met and **conditionally approved** your demolition permit and conditional use for 415 North Lake Street. On January 3, 2023, the Common Council conditionally approved your planned development request for 415 North Lake Street. In order to receive final approval of the demolition permit, conditional use and for any other permits that may need to be issued for your project, the following conditions shall be met:

**Please contact Lisa McNabola, with the Planning Division at (608) 243-0554 if you have any questions regarding the following three (3) items:**

1. The Planned Development-General Development Plan- Specific Implementation Plan shall not be recorded and building permits shall not be issued until the Urban Design Commission grants final approval and determines that the standards for Public Projects 33.02(4)(b) and the Planned Development design objectives listed in Sections 28.098(1) and (2) and other requirements of the Sections 28.098(1) and (2) have been met. The applicant may appeal the Urban Design Commission's decision to the Plan Commission, which may affirm, reverse, or modify the Urban Design Commission's decision.
  - Incorporate more substantial plantings along Lake Street.

As a reference the following approval conditions were made by the UDC as part of their initial approval regarding the public building component of this request:

- That more detail be provided at the pedestrian level both along Hawthorne Court and Lake Street with regard to building design, materials and renderings,
  - Refinement of the finish treatment of the columns, including materials selection,
  - Refinement of the level of design/articulation at the building corners and north/south elevations along Hawthorne court and the exposed garage walls.
2. Applicant will submit a management plan on the form provided by staff to be reviewed and approved by the Planning Division Director and Zoning Administrator, or their designees. Information shall include, but shall not be limited to: move in and move out, vehicle and moped parking management, parking management, snow management, building access, lighting and security cameras, property management contact, delivery and rideshare loading, and pet waste areas.
  3. Prior to final sign-off, the applicant shall work with Planning and Building Inspection Division staff to identify ways to minimize the overall area of the projections into to the Capitol View limit so they are the minimum necessary to provide elevator access to the rooftop amenity space.

**Please contact Tim Troester of the Engineering Division at (608) 267-1995 if you have any questions regarding the following seventeen (17) items:**

4. The Applicant shall provide projected wastewater flow calculations for the proposed development. Offsite sanitary sewer improvements may be required by the developer as a condition for

5. Enter into a City / Developer agreement for the required infrastructure improvements. Agreement to be executed prior to sign off. Allow 4-6 weeks to obtain agreement. Contact City Engineering to schedule the development and approval of the plans and the agreement. (MGO 16.23(9)c)
6. Construct sidewalk, terrace, curb & gutter and pavement on Lake St. to a plan as approved by City Engineer
7. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
8. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))

9. Obtain a permit to plug each existing storm sewer. This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 37.05(7))
10. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.
11. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.
12. A Storm Water Maintenance Agreement (SWMA) is required for this project. See Storm comments for agreement specific details and requirements.
13. This site appears to disturb over one (1) acre of land and requires a permit from the WDNR for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR216 and NR-151 however a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process. Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line: <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm>.

The applicant is notified that the City of Madison is an approved agent of the Department of Safety and Professional Services (DSPS) and no separate submittal to this agency or CARPC is required for this project to proceed.

14. Reconstruct Hawthorne Ct from University Ave to north lot line.
15. Complete work on exposed aggregate sidewalk in accordance with specifications provided by the city. The stone used for the exposed aggregate must be approved by the City. Notify the Construction Engineer prior to beginning construction. Any work that does not match the adjacent work or which the City Construction Engineer finds is unacceptable shall be removed and replaced. (POLICY)
16. Revise the site plan to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
17. Revise plan to show the location of all rain gutter down spout discharge locations. Downspouts shall be directed to drain to public Right of Way (ROW). (POLICY)

This project will disturb 4,000 sf or more of land area and require an Erosion Control Permit. Submit the Erosion Control Permit Application (with USLE calculations and associated fee) to Megan Eberhardt (west) at [meberhardt@cityofmadison.com](mailto:meberhardt@cityofmadison.com), or Daniel Olivares (east) at [daolivares@cityofmadison.com](mailto:daolivares@cityofmadison.com), for approval. The permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

This project will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at [meberhardt@cityofmadison.com](mailto:meberhardt@cityofmadison.com), or Daniel Olivares (east) at [daolivares@cityofmadison.com](mailto:daolivares@cityofmadison.com), for approval.

Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html>

This project will require a concrete management plan and a construction dewatering plan as part of the erosion control plan to be reviewed and approved by the City Engineer's Office. If contaminated soil or groundwater conditions exist on or adjacent to this project additional WDNR, Public Health, and/or City Engineering approvals may be required prior to the issuance of the required Erosion Control Permit. (POLICY)

This project appears to require fire system testing that can result in significant amounts of water to be discharged to the project grade. The Contractor shall coordinate this testing with the erosion control measures and notify City Engineering 608-266-4751 prior to completing the test to document that appropriate measures have been taken to prevent erosion as a result of this testing.

Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.

18. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

Rate Control New Development: Detain the 2, 5, 10, 100, & 200 - year storm events, matching post development rates to predevelopment rates and using the design storms identified in Madison General Ordinances Chapter 37.

Rate Control Redevelopment: By design detain the 10-year post construction design storm such that the peak discharge during this event is reduced 15% compared to the peak discharge from the 10-year design storm in the existing condition of the site. Further, the volumetric discharge leaving the post development site in the 10- year storm event shall be reduced by 5% compared to the volumetric discharge from the site in an existing condition during the 10-year storm event. These required rate and volume reductions shall be completed, using green infrastructure that captures at least the first 1/2 inch of rainfall over the total site impervious area. If additional stormwater controls

are necessary beyond the first 1/2 inch of rainfall, either green or non-green infrastructure may be used.

Unintended detention: If the plat or subdivision has an enclosed area with provides existing storage, the existing storage will need to be accounted for in addition to meeting the requirements for detention.

Infiltration: Provide infiltration of 90% of the pre-development infiltration volume.

TSS New Development: Reduce TSS by 80% (control the 5-micron particle) off of newly developed areas compared to no controls.

TSS Redevelopment not TMDL: Reduce TSS by 40% (control the 20-micron particle) off of new paved surfaces as compared to no controls.

TSS Redevelopment with TMDL: Reduce TSS by 80% off of the proposed development when compared with the existing site.

Oil/Grease Control: Treat the first 1/2 inch of runoff over the proposed parking facility and/or drive up window.

Volume Control: Provide onsite volumetric control limiting the post construction volumetric discharge to the predevelopment discharge volume as calculated using the 10-year storm event.

Thermal Control: Provide substantial thermal control to reduce runoff temperature in cold water community or trout stream watersheds.

100-year Overflow: The applicant shall demonstrate that water can leave the site and reach the public ROW without impacting structures during a 100-year event storm. This analysis shall include reviewing overflow elevations and unintended storage occurring on site when the storm system has reached capacity.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

19. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: [bstanley@cityofmadison.com](mailto:bstanley@cityofmadison.com) (East) or [ttroester@cityofmadison.com](mailto:ttroester@cityofmadison.com) (West).
20. The project will require storm sewer upgrades in Hawthorne Court the applicant shall work with the City Engineer to coordinate or include those improvements with the development.

**Please contact Jeffrey Quamme of the City Engineering Division – Mapping Section at (608) 266-4097 if you have any questions regarding the following thirteen (13) items:**

21. The plans note that the parcel boundary is not per a boundary survey completed by a Professional Land Surveyor. A full and complete boundary survey shall be required for the site plans and will likely note a building encroachment on the north (westerly half) side of this property. The encroachment is permitted until 2037 per a lease with the City of Madison per Document NO 4295324. The adjacent building essentially abuts the existing parking structure and the parking structure is a couple of feet southerly of the property line. The final plans shall acknowledge this lease area and be modified accordingly. Any necessary agreements with the Lessee to allow for the new construction abutting the existing structure (soil retention, subterranean support, etc) shall be provided prior to issuance of the demolition or construction permit.
22. A Declaration of Public Access Easement will be required to accommodate public vehicular traffic exiting Hawthorne Court through the aisle also serving the Bus Terminal westerly to N. Lake Street.
23. Grant a Public Sidewalk and Bike Path Easement(s) to the City on the face of the future Certified Survey Map along N Lake Street as required for terrace and sidewalks by Traffic Engineering and/or Engineering.
24. There is an existing air space quit claim to the City of Madison per Document No 1723281 for the current bridge crossings of Hawthorne Court. A new Notice of Encroachment within a public right of way shall be drafted and recorded for the specific new proposed two bridge connections crossing Hawthorne Court. Coordinate the Real Estate Project with Jeff Quamme (jrquamme@cityofmadison.com). Three dimensional Map exhibits and legal descriptions will be required for the Notice.
25. The Site Plan indicates a fixed canopy encroaching into the N. Lake Street right of way. The Applicant shall confirm any planned encroachments into any public right of way and note them on the plans, including, (but not limited to) fixed canopies, balconies, roof overhangs and underground vaults. Any encroachment benefitting the private development within this project shall make an application with City of Madison Real Estate for a privilege in streets agreement. Link as follows - <http://www.cityofmadison.com/developmentcenter/landdevelopment/streetencroachment.cfm>. An approval of the development does not constitute or guarantee approval of any encroachments within a public right of way. Any public encroachment (City of Madison related encroachment) shall be subject to a recorded notice of encroachment agreement by the City of Madison.
26. Provide any required agreements with adjacent properties necessary for soil retention requirements allowing for the construction of the new structure to be constructed abutting the existing property lines and existing adjacent buildings.
27. Identify on the plans the lot and block numbers of recorded Certified Survey Map or Plat.
28. Provide a full and complete legal description of the site or property being subjected to this application on the site plan.

29. The proposed new building crosses underlying platted lot lines. Prepare a Certified Survey Map (CSM) and submit to the Planning Unit to dissolve underlying lot lines to comply with fire codes, City Ordinances and City Policies. The CSM shall be approved by the City, recorded with the Dane County Register of Deeds and new Tax Parcel information available prior to issuance of a building permit or early start permit.
30. The address of the apartments is 427 N Lake St. Additional addresses for ramp and terminal area will be determined at a later date.
31. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
32. Submit a site plan and a complete building Floor Plan in PDF format to Lori Zenchenko (lzenchenko@cityofmadison.com) that includes a floor plan of each floor level on a separate sheet/page for the development of a complete interior addressing plan. Also, include a unit matrix for apartment buildings.

The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) PRIOR to the verification submittal stage of this LNDUSE with Zoning. The final approved stamped Addressing Plan shall be included in said Site Plan Verification application materials or a revised plan shall provided for additional review and approval by Engineering.

Per 34.505 MGO, a full copy of the approved addressing plan shall be kept at the building site at all times during construction until final inspection by the Madison Fire Department.

For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved.

33. Update the sheet L1.0 to show the official street name of N Lake St.

**Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following twenty-one (21) items:**

34. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be to engineering scale and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
35. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all

associated costs including engineering, labor and materials for both temporary and permanent installations.

36. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
37. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
38. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
39. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
40. The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). Alteration necessary to achieve compliance may include but are not limited to; substitution to transparent materials, removing sections of the structure and modifying or removing landscaping elements. If applicant believes public safety can be maintained they shall apply for a reduction of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the reduction shall be the determination of the City Traffic Engineer.
41. The applicant shall provide a clearly defined 5' walkway from the front door to the public Right of Way clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired.
42. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
43. All parking ramps as they approach the public Right-of-Way shall not have a slope to exceed 5% for 20 feet; this is to ensure drivers have adequate vision of the Right-of-Way. If applicant believes public safety can be maintained they shall apply for a waiver, approval or denial of the waiver shall be the determination of the City Traffic Engineer.
44. Parking deck is insufficiently labeled/dimensioned for a proper review. If the parking does not meet MGO 10.08 the applicant can expect to be required to make major alteration which may or may not impact structural elements of this site.
45. City of Madison radio systems are microwave directional line of sight to remote towers citywide. The building elevation will need to be reviewed by Traffic Engineering to accommodate the microwave sight and building. The applicant shall submit grade and elevations plans if the building exceeds three stories prior to sign-off to be reviewed and approved by Andrew Oliver, (267-1979, aoliver@cityofmadison.com) Traffic Engineering Shop, 4151 Nakoosa Trail. The applicant shall return one signed approved building elevation copy to the City of Madison Traffic Engineering office with final plans for sign off.



46. The driveway slope to the underground parking is not identified in the plan set, Traffic Engineering recommends driveway slope under 10%; if the slope is to exceed 10%, the applicant shall demonstrate inclement weather mitigation techniques to provide safe ingress/egress to be approved by the City Traffic Engineer.
47. "Stop" signs shall be installed at a height of seven (7) feet from the bottom of the sign at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
48. One way operation of the site shall be secured by placing a "One Way" sign at the entrance and a "Do Not Enter" sign at the Exit.
49. The applicant shall show the dimensions for the proposed class III driveway including the width of the drive entrance, width of the flares, and width of the curb cut.
50. Applicant shall submit for review a waste removal plan. This shall include vehicular turning movements.
51. The applicant shall prepare a TDMP (Traffic Demand Management Plan) to be reviewed and approved by the City Traffic Engineer. MGO (28.183(6)(a)(6)
52. Applicant shall submit for review a Commercial Delivery Plan. This plan will include times, vehicle size, use of loading zones and all related turning movements.
53. Please refer to memo from City of Madison Department of Transportation on November 2, 2022 for additional information
54. The applicant shall submit a turning movement diagram depicting inter-city buses utilizing the bus terminal.

**Please contact Jacob Moskowitz, Assistant Zoning Administrator at (608) 266-4560 if you have any questions regarding the following ten (10) items:**

55. Provide a breakdown of unit count and number of bedrooms. Bicycle parking requirements will be based on the number of units and bedrooms.
56. Bicycle parking shall comply with City of Madison General Ordinances Sections 28.141(4)(g) Table 28I-3 and 28.141.11 and shall be designated as short-term or long-term bicycle parking. A minimum of 1 resident bicycle stall per unit up to 2 bedrooms, and ½ stall per additional bedrooms are required plus a minimum of 25 short-term guest stall. Up to twenty-five percent (25%) of bicycle parking may be structured parking, vertical parking or wall mount parking, provided there is a five (5) foot access aisle for wall mount parking. NOTE: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area. Many of the stalls within the parking facility do not appear to have a code compliant access aisle.

57. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.
58. Provide a detail of the rooftop area labeled "mechanical." NOTE: Any rooftop amenities not required by the building code for access constitute a story. This includes the third elevator, trash room, and mechanical room.
59. Label EV ready and EV installed spaces on the site plan. A total of 10% (50) EV ready spaces and 2% (10) EV installed spaces are required.
60. Provide revised elevations demonstrating compliance with Sec. 28.129 Bird-Safe Glass Requirements. Provide a detail of the glass treatment to be used.
61. Section 28.185(7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson (608-266-4682).
62. Section 28.185(10) Every person who is required to submit a reuse and recycling plan pursuant to Sec. 28.185(7) (a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition.
63. Section 28.185(9)(a) A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.
64. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances and Chapter 33 Urban Design District ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

**Please contact William Sullivan of the Fire Department at (608) 866-4691 if you have any questions regarding the following four (4) items:**

65. The building shall comply with all applicable building and fire codes, specifically, the 2021 edition of the International Fire Code and the 2022 editions of NFPA 13, 14, 20 & 72.
66. Egress shall comply with the International Building Code. Potential issues are the exit discharge from the dedicated parking exit stair along Hawthorne Ct back into the building and access to the second exit stair from the occupied roof elevator lobby.
67. Provide a fire command center with direct line of sight from the main entrance to the building.
68. Please consider allowing Madison Fire Dept. to conduct training sequences prior to demolition. Contact MFD Training Division to discuss possibilities: Division Chief Jeff Larson at [jtlarson@cityofmadison.com](mailto:jtlarson@cityofmadison.com) or (608) 266- 5946.

**Please contact Ann Freiwald of the Parks Division at (608) 243-2848 if you have any questions regarding the following one (1) item:**

69. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the Central Park-Infrastructure Impact Fee district. Please reference ID# 22022 when contacting Parks about this project.

**Please contact Bradley Hofmann of the Forestry Section at (608) 267-4908 if you have any questions regarding the following one (1) item:**

70. An existing inventory of street trees located within the right of way shall be included on the site, demo, utility, landscape, grading, fire aerial apperatus and street tree plan sets. The inventory shall include the following: location, size (diamater at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.
71. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the street tree plan set.
72. City Forestry will issue a street tree removal permit for two trees: 6" Maple & 7" Locust due to construction conflicts. The Contractor shall contact City Forestry at (608)266-4816 to obtain permit. Add as a note on both the demolition and street tree plan set.
73. Additional street trees are needed for this project. Tree planting specifications can be found in section 209 of City of Madison Standard Specifications for Public Works Construction (website: <https://www.cityofmadison.com/business/pw/specs.cfm>) - All street tree planting locations and tree species within the right of way shall be determined by City Forestry. A landscape plan and street tree planting plan shall be submitted in PDF format to City Forestry for approval of planting locations within the right of way and tree species. All available street tree planting locations shall be planted within the project boundaries. Add following note on both the landscape and street tree plan sets: At least one week prior to street tree planting, Contractor shall contact City Forestry at (608) 266-4816 to schedule inspection and approval of nursery tree stock and review planting specifications with the landscaper.
74. On this project, the installation of a pavement support system (Silva Cell<sup>®</sup>, GreenBlue<sup>®</sup> or equivalent as approved by city) surrounding tree grate locations is required where the terrace is concrete. The Contractor shall contact City Forestry at (608) 266-4816 to identify and locate underground conflicts (utilities, vaults, conduit) or other underground obstructions and determine grate locations before support system installation. Add as a note on both the site and street tree plan set.
75. No later than five business days prior to forming concrete and constructing tree grate sites, the Contractor shall contact City Forestry at (608) 266-4816 to identify and locate underground conflicts (utilities, vaults, conduit) or other underground obstructions and determine grate locations. The Contractor will be required to obtain the grate, matching frame and/or tree guard. Tree grate type

and matching frame: Neenah 4x8 (R-8815-A). Tree guard Neenah (R-8501-4818). Add as a note on both the landscape and street tree plan set.

76. Tree grates are the property of the City of Madison. The Contractor shall contact City Forestry at (608) 266-4816 to schedule delivery of salvaged tree grates to City Forestry facility. Add as a note on the demolition and street tree plan set.

**Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following one (1) item:**

77. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

**Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.**

**Please now follow the procedures listed below for obtaining your final approval:**


1. After the plans have been revised per the above conditions, please submit one (1) complete digital plan set in PDF format and any other supporting materials that are necessary, as specified in this letter to [sprapplications@cityofmadison.com](mailto:sprapplications@cityofmadison.com) (note: A 20MB email limit applies and multiple transmittals may be required). The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. A check for the site plan review fee shall be mailed to the City of Madison Building Inspection Division; PO Box 2984; Madison, WI 53701-2984.
3. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
4. The conditional use approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or

additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.

6. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.
7. City Agencies who submitted conditions of approval will review your revised plans to verify that their conditions, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.
8. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.

**If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551.** If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0554 or [lmcnabola@cityofmadison.com](mailto:lmcnabola@cityofmadison.com).

Sincerely,



Lisa McNabola  
 Planner

cc: Jacob Moskowitz, Asst. Zoning Administrator  
 Sean Malloy, Traffic Engineering Division  
 Tim Troester, Engineering Division  
 Ann Freiwald, Parks Division  
 Bradley Hofmann, Forestry Section  
 Jeff Belshaw, Water Utility  
 Jeffrey Quamme, Mapping Section  
 William Sullivan, Fire Department

I hereby acknowledge that I understand and will comply with the above conditions of approval for conditional uses.


---

*Signature of Applicant*


---

*Signature of Property Owner (if not the applicant)*

LNDUSE-2022-00092			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div.	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Other: Forestry