



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King, Jr. Blvd
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
www.cityofmadison.com

December 14, 2022

Marc Ott
JLA
200 W. Broadway #200
Monona, WI 53713

RE: Legistar ID 74056 & 74721; Accela 'LNDUSE-2022-00093' -- Approval of conditional uses at 2007 Roth Street

Dear Marc:

At its December 12 meeting, the Plan Commission, meeting in regular session, found the standards met and approved your requested conditional uses to construct a six-story, 250-unit apartment building and a seven-story, 303-unit apartment building on two lots created via CSM at 2007 Roth Street. In order to receive final approval of your request and for any other permits that may need to be issued for your project, the following conditions shall be met:

Please contact my office at (608) 243-0455 if you have any questions regarding the following four (4) items:

1. Final elevation drawings for the Lot 1 building shall be revised to include the modifications demonstrated in the applicant's recent conceptual renderings as noted below. The following shall be provided on both black and white and color elevations and floor and site plans for review and approval by Planning Division Staff:
 - With the required removal of parking in front of the *porte cochere*, add additional landscaping and pedestrian connections, and minimize the size of the canopy structure to the extent possible;
 - Extend the masonry brick up the entire vertical element above the *porte cochere* (as depicted by the applicant);
 - Include more or larger windows and include at least one additional direct connection to the public sidewalk at the end of the southern-most building wing on the first floor facing Huxley Street;
 - Replace the yellow accent panel with a red accent panel (as depicted by the applicant);
 - Replace the existing masonry brick color with a more red color (as depicted by the applicant);
 - Remove the solid partial wall treatment on balconies to reflect a more open rail design that was depicted on the original submittal in order to provide more vertical modulation along the facades.
2. Per the UDC's advisory recommendation, the applicant shall make the following modifications to Lot 2 for review and approval by Planning Division Staff:
 - Consider including community garden planting beds on Lot 2 for use by building residents.
 - Minimize the appearance of the rooftop parking to the greatest extent possible by utilizing lighting cutoffs and minimizing infrastructure and structural protrusions.

3. No HVAC “wall-pack” penetrations/louvers are shown on the street-facing facades. Unless specifically approved by the Plan Commission, the addition of wall packs on outward-facing walls is not included in this approval and will require approval of an alteration to this conditional use should they be proposed at a later time.
4. This property was historically associated with locations of Native American effigy mounds and archeological sites, but no intact effigy mounds or archeological sites currently remain. If a burial site disturbance occurs during the construction work the work shall stop immediately until the Wisconsin Historical Society is able to assess the site.

Please contact Jenny Kirchgatter, Assistant Zoning Administrator at (608) 266-4429 if you have any questions regarding the following thirteen (13) items:

5. Lot 1: Eliminate the surface parking stalls located between the front of the building and Huxley St. For new large multi-family building forms, parking shall be located behind or beside each building, below the building, or in a common parking court in the interior of a block.
6. Lots 1 and 2: Update the useable open space exhibit to exclude the useable open space areas that are shown within the front and street side yard setbacks. Usable open space at ground level shall be in a compact area of not less than two hundred (200) square feet, with no dimension less than eight (8) feet and no slope grade greater than ten percent (10%). Usable open space shall be located outside of a required front or corner side yard, as extended to the rear lot line.
7. Lots 1 and 2: Submit a dwelling unit summary including the numbers and types of dwelling units per floor. Verify that the vehicle parking counts and bicycle parking counts are listed accurately and consistently throughout the plan set.
8. Lot 1: Provide electric vehicle stalls per Section 28.141(8)(e) Electric Vehicle Charging Station Requirements. A minimum of 10% of the residential parking stalls (28 stalls) must be electric vehicle ready, and a minimum of 2% of the stalls (6 stalls) must be electric vehicle installed. One (1) of the electric vehicle installed stalls must be an accessible stall. Identify the locations of the electric vehicle ready and installed stalls on the plans.
9. Lot 2: Provide electric vehicle stalls per Section 28.141(8)(e) *Electric Vehicle Charging Station Requirements*. A minimum of 10% of the residential parking stalls (38 stalls) must be electric vehicle ready, and a minimum of 2% of the stalls (8 stalls) must be electric vehicle installed. One (1) of the electric vehicle installed stalls must be an accessible stall. Identify the locations of the electric vehicle ready and installed stalls on the plans.
10. Lot 1: Bicycle parking for the residential dwelling units shall comply with the requirements of MGO Sections 28.141(4)(g) and 28.141(11) and shall be designated as short-term or long-term bicycle parking. A minimum of 250 resident bicycle stalls are required plus a minimum of 25 short-term guest stalls. Up to twenty-five percent (25%) of bicycle parking may be structured parking, vertical parking or wall mount parking, provided there is a five (5) foot access aisle for wall mount parking. NOTE: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area. Submit a detail showing the model of bike rack to be installed.
11. Lot 2: Bicycle parking for the residential dwelling units shall comply with the requirements of MGO

Sections 28.141(4)(g) and 28.141(11) and shall be designated as short-term or long-term bicycle parking. A minimum of 382 resident bicycle stalls are required plus a minimum of 30 short-term guest stalls. Up to twenty-five percent (25%) of bicycle parking may be structured parking, vertical parking or wall mount parking, provided there is a five (5) foot access aisle for wall mount parking. NOTE: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area. Submit a detail showing the model of bike rack to be installed.

12. Lots 1 and 2: Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.
13. Lots 1 and 2: Provide details for the outside refuse staging enclosure and the dog run fencing.
14. Lots 1 and 2: Provide a complete Exterior Materials Schedule with the building elevations. Submit the building elevations for the courtyards.
15. Lots 1 and 2: Verify whether bird-safe glazing will be required on the courtyard elevations. Provide details of the specific bird-safe glass treatment product that will be used in compliance with Section 28.129.
16. Lots 1 and 2: Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.
17. Lots 1 and 2: Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

Please contact Brenda Stanley of the City Engineering Division at (608) 261-9127 if you have any questions regarding the following twenty-one (21) items:

18. Storm sewer shall be installed up Roth Street to serve this development. No stormwater discharge from this development shall be allowed to enter the adjacent wetland in any event up to and including the 200-year event.
19. A portion of the development is in the environmental corridor - a request from the Planning Department to CARPC is required to reduce the environmental corridor prior to the development.
20. Enter into a City / Developer agreement for the required infrastructure improvements. Agreement to be executed prior to sign off. Allow 4-6 weeks to obtain agreement. Contact City Engineering to schedule the development and approval of the plans and the agreement. (MGO 16.23(9)c)
21. Enter into a City / Developer agreement for the required infrastructure improvements. Agreement to be executed prior to sign off. Allow 4-6 weeks to obtain agreement. Contact City Engineering to schedule the development and approval of the plans and the agreement. (MGO 16.23(9)c)

22. Construct Madison Standard street, multi-use path, and sidewalk improvements for all streets within the plat/csm. (MGO 16.23(9)(d)6). Extend N/S street to current Ruskin St termination.
23. Construct public sanitary sewer, storm sewer, and drainage improvements as necessary to serve the lots within the plat/csm. (MGO 16.23(9)(d))
24. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
25. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.
26. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.
27. A Storm Water Maintenance Agreement (SWMA) is required for this project. See Storm comments for agreement specific details and requirements.
28. This site appears to disturb over one (1) acre of land and requires a permit from the WDNR for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR216 and NR-151 however a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process. Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line: <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm>.
The applicant is notified that the City of Madison is an approved agent of the Department of Safety and Professional Services (DSPS) and no separate submittal to this agency or CARPC is required for this project to proceed.
29. A portion of this plat/csm/project may come under the jurisdiction of the US Army Corp of Engineers and Wisconsin Department of Natural Resources for wetland, flood plain, or navigable waterway issues. A permit for these items may be required prior to construction. Contact the WDNR & USACOE for a jurisdictional determination. Provide digital copy of the wetland delineation. Wetland delineations shall be <5 years old. (NOTIFICATION)
30. Submit a soil boring report that has been prepared by a Professional Engineer two weeks prior to recording the final plat to the City Engineering Division indicating the ground water table and rock conditions in the area. If the report indicates a ground water table or rock condition less than 9' below proposed street grades, a restriction shall be added to the final plat, as determined necessary by the City Engineer. (MGO 16.23(9)(d)(2) and 16.23(7) (a)(13))
31. Confirm that adequate sight distance exists where public streets intersect per AASHTO design standards for intersection sight distance. If adequate sight distance does not exist, change the location of the street intersection or agree to make improvements to the roadways such that the sight distance is achieved or make the mitigating improvements as required by the City. Caution - The improvements

indicated may require right-of-way outside of the plat/csm.

32. Revise the site plan to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
33. Revise plan set to show more information on proposed drainage for the site. Use either spot elevations and drainage arrows or proposed contours to show the required drainage information. It is necessary to show the location of drainage leaving the site to the public right-of-way. It may be necessary to provide information off the site to fully meet this requirement. (POLICY)
34. The proposed development proposes to construct underground parking. The proposed entrance to the underground parking is adjacent to a street low point. The applicant shall provide at a minimum of one (1) foot of rise from the adjacent back of walk in the driveway before breaking grade to the down ramp to the underground parking to protect the underground parking from inundation. The stated elevation is intended to be protective but does not guarantee a flood proof structure. The Developer/Owner are strongly encouraged to complete their own calculations and determine an elevation that protects their property to a level of service that they are comfortable with.
35. Provide additional detail how the enclosed depression(s) created by the parking entrance(s) to the below building parking area(s) is/are served for drainage purposes. The building must be protected from receiving runoff up through the 100-yr design storm that is current in Madison General Ordinance Chapter 37. If the enclosed depression(s) is/are to be served by a gravity system provide calculations stamped by a Wisconsin P.E. that show inlet and pipe capacities meet this requirement. If the enclosed depression(s) is/are to be served by a pump system provide pump sizing calculations stamped by a Wisconsin P.E. or licensed Plumber that show this requirement has been met.
36. This project will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval. Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html>
This project will require a concrete management plan and a construction dewatering plan as part of the erosion control plan to be reviewed and approved by the City Engineer's Office. If contaminated soil or groundwater conditions exist on or adjacent to this project additional WDNR, Public Health, and/or City Engineering approvals may be required prior to the issuance of the required Erosion Control Permit. (POLICY)
This project appears to require fire system testing that can result in significant amounts of water to be discharged to the project grade. The Contractor shall coordinate this testing with the erosion control measures and notify City Engineering 608-266-4751 prior to completing the test to document that appropriate measures have been taken to prevent erosion as a result of this testing.
Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.
37. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances

regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

Rate Control New Development: Detain the 2, 5, 10, 100, & 200 - year storm events, matching post development rates to predevelopment rates and using the design storms identified in Madison General Ordinances Chapter 37.

Infiltration: Provide infiltration of 90% of the pre-development infiltration volume.

TSS New Development: Reduce TSS by 80% (control the 5-micron particle) off of newly developed areas compared to no controls.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

38. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West).

Please contact Jeff Quamme of the City Engineering Division – Mapping Section at (608) 266-4097 if you have any questions regarding the following eleven (11) items:

39. There is a gas house, private gas lines and gas bridge improvements encroaching into the proposed Coolidge Street right of way. These are privately owned improvements. They are not owned by MG&E. MG&E provides the gas to a meter set within the Gas House. These private improvements will need to be removed from the proposed Coolidge Street right of way, or a plan for removal shall be approved by the City Engineer, as a condition of approval. Removal can be included within the work to be performed under the developer's agreement, or the owner may enter into a lease for the use of the unimproved Coolidge Street right of way occupied by the Gas House, private gas lines and Bridge. Any such lease shall require removal of the private improvements from the dedicated right of way upon termination, and provide that if this is not done the costs thereof shall be recovered from the adjoining lots (Lots 1 and 2 of the proposed CSM) as special charges. Any such agreement allowing for a delayed removal of these improvements shall be entered into contemporaneously with the recording of the pending CSM.
40. Grant a 20' wide Public Sanitary Sewer Easement(s) to the City on the face of the pending Certified Survey Map near the east line of the Hartmeyer Parcel outside of the existing private encroachment easement extending northerly to where the sanitary sewer is to end after removal to the north to allow for a future relocate of sanitary sewer from under the existing ice arena. Contact Jeff Quamme of Engineering Mapping (jrquamme@cityofmadison.com, 608-266-4097) for the final required

language.

41. Grant a 20' wide Public Sanitary Sewer Easement(s) to the City on the face of the pending Certified Survey Map near the Hartmeyer Parcel centered on the existing Public Sanitary Sewer to remain after the abandonment further to the north. Contact Jeff Quamme of Engineering Mapping (jrquamme@cityofmadison.com, 608-2664097) for the final required language. Also show and label the portion of the existing sanitary sewer " Portion of existing Public Sanitary Sewer to be abandoned and removed."
42. Grant a 20' Wide Public Sanitary Sewer Easement to the City on the face of the pending Certified Survey Map for the relocated sanitary sewer over the easterly side of proposed lots 1 and 2 as shown on the site plans. The easement shall contain consent to occupy easement language for the private improvements planned within the easement. If the private improvements are required to be removed by the City for maintenance, repair or construction of the sanitary sewer, the owner is responsible for the replacement of the private improvements and / or associated costs. Contact Jeff Quamme of Engineering Mapping (jrquamme@cityofmadison.com, 608266-4097) for the final required language.
43. The existing storm sewer that conveys public storm water bisecting this site is not subject to an easement of public record. The public storm sewer, as part of the plan, is to be rerouted from Roth Ave to Commercial Avenue via the proposed public streets per the pending CSM. Upon the rerouting of the storm sewer to Commercial being completed and the removal of the northern portion of the storm sewer, the remaining portion of storm sewer within proposed lots 2 shall be considered abandoned by the City of Madison and the Owner of proposed Lot 2 assumes (now private) ownership of the storm sewer.
44. Show a temporary limited easement for a temporary cul-de-sac on Coolidge St having a radius and a reverse curve radius as required by City of Madison Traffic Engineering and Engineering Division. The easement text is as follows: Temporary Limited Easement benefitting the City of Madison for temporary turnaround improvement purposes. Said Easement shall terminate upon the extension of Coolidge Street Easterly of this CSM along with the removal of the public temporary turnaround improvements within the easement area.
45. Private improvements are shown planned within an existing MG&E gas utility easement per Document No. 1211659 along the east side of both Lots. Applicant is responsible to obtain rights / permission for the construction of private improvements within the easement area. A conveyance of rights in land from MG&E for the portion of the easement within the proposed dedicated right of way shall also be required.
46. There is private storm sewer along the east sides of both proposed Lots 1 and 2 that runs longitudinally near the proposed Public Sanitary Sewer. The layout of the private storm sewer shall be revised to cross the sanitary sewer as near perpendicular as possible when crossing the sanitary sewer. Also the private storm sewer running longitudinally in the Roth Street right of way along the north side of Lot 1 shall be moved into the Lot.
47. The senior housing building address is 1003 Huxley St. The family housing building address is 905 Huxley St. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.

48. The pending Certified Survey Map application for this property shall be completed and recorded with the Dane County Register of Deeds (ROD), the new parcel data created by the Assessor's Office and the parcel data available to zoning and building inspection staff prior to issuance of building permits for new construction or early start permit.
49. Submit a site plan and a complete set of building Floor Plans (for each individual building) in PDF format to Lori Zenchenko (lzenchenko@cityofmadison.com) that includes a floor plan of each floor level on a separate sheet/page for the development of an interior and building addressing plan for the proposed multi-building complex. Each building page should include a key locator and north arrow. Also, include a unit matrix for the apartment buildings. The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) PRIOR to the Verification submittal stage of this LNDUSE with Zoning. The final approved stamped Addressing Plan shall be included in said Site Plan Verification application materials or a revised plan shall be provided for additional review and approval by Engineering. Per 34.505 MGO, a full copy of the approved addressing plan shall be kept at the building site at all times during construction until final inspection by the Madison Fire Department. For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved.

Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following eighteen (18) items:

50. The applicant shall remove their driveway connection on Coolidge Street as it may compromise the City's future ability to secure a railroad crossing. The applicant shall work with City staff to provide an alternative site plan that does not include the proposed Coolidge Street driveway connection.
51. Parking deck is insufficiently labeled/dimensioned for a proper review. If the parking does not meet MGO 10.08 the applicant can expect to be required to make major alteration which may or may not impact structural elements of this site.
52. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be to engineering scale and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
53. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
54. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.

55. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
56. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
57. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
58. The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). Alteration necessary to achieve compliance may include but are not limited to; substitution to transparent materials, removing sections of the structure and modifying or removing landscaping elements. If applicant believes public safety can be maintained they shall apply for a reduction of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the reduction shall be the determination of the City Traffic Engineer.
59. The applicant shall provide a clearly defined 5' walkway from the front door to the public Right of Way clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
60. City of Madison radio systems are microwave directional line of sight to remote towers citywide. The building elevation will need to be reviewed by Traffic Engineering to accommodate the microwave sight and building. The applicant shall submit grade and elevations plans if the building exceeds three stories prior to sign-off to be reviewed and approved by Andrew Oliver, (267-1979, aoliver@cityofmadison.com) Traffic Engineering Shop, 4151 Nakoosa Trail. The applicant shall return one signed approved building elevation copy to the City of Madison Traffic Engineering office with final plans for sign off.
61. The driveway slope to the underground parking is not identified in the plan set, Traffic Engineering recommends driveway slope under 10%; if the slope is to exceed 10%, the applicant shall demonstrate inclement weather mitigation techniques to provide safe ingress/egress to be approved by the City Traffic Engineer.
62. "Stop" signs shall be installed at a height of seven (7) feet from the bottom of the sign at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
63. The applicant shall show the dimensions for the proposed class III driveway including the width of the drive entrance, width of the flares, and width of the curb cut.
64. All existing driveway approaches on which are to be abandoned shall be removed and replaced with curb and gutter and noted on the plan.
65. Applicant shall submit for review a Trash Removal Plan. This plan will include times, vehicle size, use of loading zones and all related steps to remove trash from its location.

66. The applicant shall prepare a TDMP (Traffic Demand Management Plan) to be reviewed and approved by the City Traffic Engineer. MGO (28.183(6)(a)(6)

67. Items in the Right-of-Way are not approvable through the site plan approval process. Make a note on all pages showing improvements in the ROW that states: The Right-of-Way is the sole jurisdiction of the City of Madison and is subject to change at anytime per the recommendation/plan of Traffic Engineering and City Engineering Divisions.

Please contact Bill Sullivan of the Fire Department at (608) 866-4691 if you have any questions regarding the following one (1) item:

68. The fire sprinkler systems shall comply with the 2022 edition of NFPA 13.

Please contact Kate Kane of the Parks Division at (608) 261-9671 if you have any questions regarding the following three (3) items:

69. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the North Park-Infrastructure Impact Fee district. Please reference ID# 22041 when contacting Parks about this project.

70. Pursuant to the authority established under Wis. Stat. § 66.0617(7), and in the interests of promoting the development of low-cost housing in the City, low-cost housing is exempt from the park impact fees beginning January 1, 2017. This exemption only applies to those dwelling units or bedrooms within a development that are determined to be low-cost housing. This exemption does not extend to the land dedication requirements set forth under Sec. 16.23(8)(f), MGO, nor any other impact fees that may apply to a development.

71. The park impact fee will be exempt for developments that meet the “low-cost housing” requirements, as defined as rental or owner-occupied housing units that are affordable, as that term is defined in Sec. 4.22(2), MGO, and which meet the deed restriction requirements of Sec. 4.22(7). The determination whether a proposed development will create low-cost housing, and how much low-cost housing it will create, shall be made by the Community Development Division.

Please contact Jeffrey Heinecke of the Parks Division at (608) 266-4890 if you have any questions regarding the following one (1) item:

72. Additional street trees are needed for this project. Tree planting specifications can be found in section 209 of City of Madison Standard Specifications for Public Works Construction (website: <https://www.cityofmadison.com/business/pw/specs.cfm>) - All street tree planting locations and tree species within the right of way shall be determined by City Forestry. A landscape plan and street tree planting plan shall be submitted in PDF format to City Forestry for approval of planting locations within the right of way and tree species. All available street tree planting locations shall be planted within the project boundaries. Add following note on both the landscape and street tree plan sets: At least one week prior to street tree planting, Contractor shall contact City Forestry at (608) 266-4816 to schedule inspection and approval of nursery tree stock and review planting specifications with the landscaper.

Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following two (2) items:

73. The developer shall construct the public water distribution system and services required to serve the proposed subdivision plat/CSM per MGO 16.23(9)(d)(3).
74. All public water mains and water service laterals shall be installed by a standard City subdivision contract / CityDeveloper agreement. Applicant shall contact City Engineering Division to schedule the development of plans and the agreement. See Engineering Division comments for additional information.

Please contact Tim Sobota of Metro Transit at (608) 261-4289 if you have any questions regarding the following two (2) items:

75. To facilitate City transit planning efforts, the applicant shall identify the accessible pedestrian connection between the building entrance(s) and public sidewalk along the nearest point of the Roth Street (Lot 1) or Coolidge Street (Lot 2) public rights-of-way.
76. The applicant shall include the location of these facilities on the final documents filed with their permit application, so that Metro Transit may review and effectively plan for City transit access to this property.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.


Please now follow the procedures listed below for obtaining your demolition permit and conditional use:

1. After the plans have been revised per the above conditions, please submit **one (1) complete digital plan set in PDF format** of complete, fully dimensioned, and to-scale plans; the appropriate site plan review application and [site plan review fee pursuant to Section 28.206](#) of the Zoning Code; and any other documentation requested herein to the Zoning Administrator at SPRapplications@cityofmadison.com. (Note that that an individual email cannot exceed 20MB and it is the responsibility of the applicant to present files in a manner that can be accepted. Please email zoning@cityofmadison.com regarding questions or if you need alternative filing options) The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
3. The conditional use approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.

4. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
5. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0455.

Sincerely,



Colin Punt
 Planner

- cc: Jenny Kirchgatter, Asst. Zoning Administrator
 Brenda Stanley, City Engineering Division
 Jeff Quamme, City Engineering Division – Mapping
 Sean Malloy, Traffic Engineering Division
 Bill Sullivan, Fire Department
 Kate Kane, Parks Division
 Jeff Heinecke, Forestry Section
 Jeff Belshaw, Water Utility
 Tim Sobota, Metro Transit

I hereby acknowledge that I understand and will comply with the above conditions of approvals.

Signature of Applicant

Signature of Property Owner (if not the applicant)

LNDUSE-2022-00093			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Punt)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input checked="" type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Forestry