



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King, Jr. Blvd
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
www.cityofmadison.com jm

****BY E-MAIL ONLY****

January 17, 2023

Jon Hoffmann
Hammersley Stone Co. Inc.
6291 Lacy Road
Fitchburg, WI 53593

RE: Consideration of a demolition permit to demolish a financial institution at 3809 East Washington Avenue. (ID [74540](#), LNDUSE-2022-00108)

Dear Jon Hoffman:

On January 9, 2023, the Plan Commission found the standards met and **conditionally approved** your demolition permit for 3809 E Washington Avenue. In order to receive final approval of the demolition permit, the following conditions shall be met:

Please contact Tim Sobota of Metro Transit at (608) 261-4289 if you have any questions regarding the following four (4) items:

1. In coordination with any public works improvements, the applicant shall maintain or replace the concrete boarding pad surface at the existing Metro bus stop on the south side of East Washington Avenue, east of Mendota Street (#9573).
2. The existing curbside bus stop zone and accessible pedestrian sidewalk and concrete boarding pad on the south side of East Washington Avenue, east of Mendota Street, provides critical access to the City's transit operations, and any planned or permitted obstruction of the existing bus stop zones in excess of thirty (30) days may require additional right-of-way improvements and/or other mitigation measures in coordination with Traffic Engineering and Metro Transit staff - in order to create an alternate bus stop zone that would serve the East Washington Avenue at Mendota Street intersection area in a comparable operational and accessible manner.
3. The applicant shall include the location of these transit amenities on the final documents filed with their permit application so that Metro Transit may review the design.

4. Metro Transit operates daily all-day transit service along East Washington Avenue adjacent this property - with trips at least every 30 minutes.

Please contact Jacob Moskowitz, Assistant Zoning Administrator at (608) 266-4560 if you have any questions regarding the following three (3) items:

5. Section 28.185(7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson (608-266-4682).
6. Section 28.185(10) Every person who is required to submit a reuse and recycling plan pursuant to Sec. 28.185(7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition.
7. Section 28.185(9)(a) A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.

Please contact Brenda Stanley of the Engineering Division at (608) 261-9127 if you have any questions regarding the following one (1) item:

8. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))

Please contact William Sullivan of the Fire Department at (608) 886-4691 if you have any questions regarding the following one (1) item:

9. Please consider allowing Madison Fire Dept. to conduct training sequences prior to demolition. Contact MFD Training Division to discuss possibilities: Division Chief Jeff Larson at jtlarson@cityofmadison.com or (608) 266- 5946.

Please contact Jeffrey Heinecke of the Forestry Section at (608) 444-2673 if you have any questions regarding the following five (5) items:

10. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at (608) 266-4816. Penalties and remediation shall be required. Add as a note on the site, grading, utility, demolition, and street tree plan set.
11. As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches inc diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry at (608) 266-4816 prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications

can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the site, grading, utility, demolition and street tree plan sets.

12. Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction (website: <https://www.cityofmadison.com/business/pw/specs.cfm>) addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on both the site and street tree plan sets.
13. On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on both the site and street tree plan sets.
14. Street tree pruning shall be coordinated with City Forestry at a minimum of two weeks prior to the start of construction for this project. Contact City Forestry at (608)266-4816. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on both the site and street plan sets.

Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following one (1) item:

15. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.

Please contact Jeffrey Quamme of the City Engineering Division – Mapping Section at (608) 266-4097 if you have any questions regarding the following three (3) items:

16. The City of Madison has made an offer for acquisition of part of this property adjacent to E Washington Ave. Refer to City of Madison Real Estate Project No. 12560 and Transportation Plat No. 12777-2-4.10 Amendment No: 1, Parcel 39.
17. Provide a demolition plan showing the parcel boundary, improvements to be demolished and any impervious areas to remain or to be added. Also show and label the existing public sanitary sewer within the easterly corner of the lot and also show and label the Sanitary Sewer Easements per Doc No's 1005924 and 998712.
18. The Survey attached to this review is not of the parcel of the demolition. Note there are several ALTA boundary surveys that have been filed at the County Surveyor's Office of the HyVee site that include this parcel.


Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your demolition permit:

1. After the plans have been revised per the above conditions, please submit one (1) complete digital plan set in PDF format and any other supporting materials that are necessary, as specified in this letter to sprapplications@cityofmadison.com (note: A 20MB email limit applies and multiple transmittals may be required). The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. A check for the site plan review fee shall be mailed to the City of Madison Building Inspection Division; PO Box 2984; Madison, WI 53701-2984.
3. City Agencies who submitted conditions of approval will review your revised plans to verify that their conditions, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.
4. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0554 or lmcnabola@cityofmadison.com.

Sincerely,



Lisa McNabola
Planner

cc: Jacob Moskowitz, Asst. Zoning Administrator
Jeffrey Quamme, Mapping Section
Brenda Stanley, Engineering Division
Jeff Belshaw, Water Utility
William Sullivan, Fire Department
Bradley Hofmann, Forestry Division
Tim Sobota, Metro Transit

LNDUSE-2022-00108			
For Official Use Only, Re: Final Plan Routing			
<input type="checkbox"/>	Planning Div.	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input checked="" type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Other: Forestry