



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4635
www.cityofmadison.com

****BY E-MAIL ONLY****

February 14, 2023

Colin Meisel
Ruekert and Mielke
4630 S Biltmore Lane
Madison, WI 53718

RE: Consideration of a conditional use in the Suburban Employment (SE) District for warehousing and storage to allow construction of an office/warehouse/distribution facility for the South Central Library System at 1650 Pankratz Street. (LNDUSE-2022-00122; ID [75245](#))

Dear Colin,

At its February 13, 2023 meeting, the Plan Commission found the standards met and **approved** your client's conditional use request for 1650 Pankratz Street. Prior to issuance of permits for the project, the conditions of approval in the following sections shall be satisfied:

Please contact Brenda Stanley of the City Engineering Division—Main Office at (608) 261-9127 if you have questions regarding the following eleven (11) items:

1. This proposed building is adjacent to the closed Dane County Truax Landfill. City of Madison zoning requires certain approved construction practices and safety precautions for buildings and homes adjacent to existing landfills. These requirements are outlined in subsection 29.23(11) of the Madison General Ordinance. You will be required to provide proof of compliance when applying for your building permit. Contact Brynn Bemis, City of Madison Engineering, with questions: bbemis@cityofmadison.com, 608.267.1986.
2. Obtain a Street Terrace permit for restoration. This permit application is available and must be completed on line at <http://www.cityofmadison.com/engineering/permits.cfm> (MGO 10.08)
3. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
4. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.
5. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.

6. This site appears to disturb less than one (1) acre of land. No submittal to the WDNR, CARPC or Department of Safety and Professional Services (DSPS) is required as the City of Madison Building Inspection Department is an approved agent for DSPS.
7. The proposed development proposes to construct a loading dock with storm sewer that does not have an overflow out of the enclosed depression created by the loading dock. The applicant shall provide information on flood protection for this area.
8. Provide additional detail how the enclosed depression(s) created by the loading dock is served for drainage purposes. The building must be protected from receiving runoff up through the 100-yr design storm that is current in Madison General Ordinance Chapter 37. If the enclosed depression(s) is/are to be served by a gravity system provide calculations stamped by a Wisconsin P.E. that show inlet and pipe capacities meet this requirement. If the enclosed depression(s) is/are to be served by a pump system provide pump sizing calculations stamped by a Wisconsin P.E. or licensed Plumber that show this requirement has been met.
9. This project will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval.

Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html>

This project will require a concrete management plan and a construction dewatering plan as part of the erosion control plan to be reviewed and approved by the City Engineer's Office. If contaminated soil or groundwater conditions exist on or adjacent to this project additional WDNR, Public Health, and/or City Engineering approvals may be required prior to the issuance of the required Erosion Control Permit. (POLICY)

Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.

10. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

Rate Control Redevelopment: By design detain the 10-year post construction design storm such that the peak discharge during this event is reduced 15% compared to the peak discharge from the 10-year design storm in the existing condition of the site. Further, the volumetric discharge leaving the post development site in the 10- year storm event shall be reduced by 5% compared to the volumetric discharge from the site in an existing condition during the 10-year storm event. These required rate and volume reductions shall be completed, using green infrastructure that captures at least the first 1/2 inch of rainfall over the total site impervious area. If additional stormwater controls are necessary beyond the first 1/2 inch of rainfall, either green or non-green infrastructure may be used.

TSS Redevelopment with TMDL: Reduce TSS by 80% off of the proposed development when compared with the existing site.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

11. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West).

Please contact Julius Smith of the City Engineering Division–Mapping Section, at (608) 264-9276 if you have questions regarding the following six (6) items:

12. Upon approval of the proposed Wing/dock wall, screen wall, curb and pavement lying within the City of Madison Easement for Sanitary Sewer per Doc No. 3268680 a Consent to Occupy Easement document shall be drafted and recorded by City of Madison Office of Real Estate Services defining responsibilities and requirements in conjunction with the proposed improvements. Coordinate with Julius Smith at jsmith4@cityofmadison.com Note: plantings existing or proposed in L1.0 within the easement limits are also subject to removal as needed at any time the city may need to use the easement and will not cover any costs to replace
13. Show and label all of the existing easements and platted DOT highway Setback Restriction on the Site plans.
14. Identify on the plans the lot and block numbers of recorded Certified Survey Map or Plat.
15. Provide a full and complete legal description of the site or property being subjected to this application on the site plan.
16. The proposed building is very nearly on and or almost encroaching, the 50' Public Sanitary Sewer Easement Per Document No. 3268680. This easement needs to be shown on the site plan, and done so accurately. it appears there has been a survey performed on this parcel from the plans provided. Given the proximity of the proposed structure provide the survey as part of the plan submittal to ensure easement was located and shown properly on the site.

17. When comparing the location as shown of the new addition from the existing southwesterly Building corner of the existing structure to be remolded, it appears that the westerly face of the new building addition is located about 16.3' East per the site plan location. This results in the projection of the screen wall and the loading dock wall crossing slightly into the 50' sanitary easement as shown on sheet C5.0. However on sheet A1.3 the new addition is show to be about 16.6' from the existing corner of the remolded building, which then shows the projecting walls located outside the easement limits.

Confirm the location of the proposed structure and note it on the site plan. If the building is no longer crossing the easement no consent to occupy for these elements in this area will be required. Coordinate with arch and structural plans to avoid confusion.

Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following nine (9) items:

18. The applicant shall work with the Traffic Engineering and Engineering Divisions on providing a wider easement along Packers Avenue to accommodate a future path.
19. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be to engineering scale and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
20. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
21. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
22. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
23. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
24. All pedestrian walkways adjacent parking stalls shall be 7 feet wide to accommodate vehicle overhang, signage and impediments to walkway movements. Any request for variance shall be submitted to and reviewed by City Traffic Engineering.
25. The applicant shall provide a clearly defined 5' walkway from the front door to the public Right of Way clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.

26. Applicant shall submit for review a Commercial Delivery Plan. This plan will include times, vehicle size, use of loading zones and all related turning movements.

Please contact Jenny Kirchgatter of the Zoning Division at (608) 266-4429 if you have any questions regarding the following eleven (11) items:

27. Show the height of the existing building on the elevations. The minimum building height is 22 feet measured to the building cornice. If the existing building height is less than 22 feet, then a portion of the proposed addition must be a minimum of 22 feet in height.

28. Submit an overall site plan exhibit for the zoning lot, including the property located to the south at 1402 Pankratz St and property to the north at 1702 Pankratz St.

29. Bicycle parking shall comply with the requirements of Sections 28.141(4)(g) and 28.141(11). Work with Zoning staff to verify that the existing number of bicycle stalls will be adequate. A minimum of one (1) bicycle stall is required per 2,000 sq. ft. of floor area for the office space. A minimum of one (1) bicycle stall is required per ten (10) employees in the warehouse area. Clearly identify the location and number of the existing bicycle stalls on the site plan.

30. Provide details showing that the landscape islands contain at least 75% vegetative cover. Per Sections 28.142(3)(c) and 28.142(4)(e), planting beds or planted areas must contain at least 75% vegetative cover mulched. Mulch shall consist of shredded bark, chipped wood or stone installed at a minimum depth of two (2) inches. If stone is used, it shall be spread over weed barrier fabric.

31. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.

32. Submit a rooftop plan showing the location of any proposed rooftop mechanical equipment and screening. All rooftop and ground level mechanical equipment and utilities shall be fully screened from view from any street or residential district per Section 28.142(9)(d).

33. The refuse enclosure area shall be screened on four (4) sides (including a gate for access) by a solid, commercial-grade wood fence, wall, or equivalent material with a minimum height of six (6) feet and not greater than eight (8) feet.

34. Provide details demonstrating compliance with bird-safe glass requirements Section 28.129. For building façades where the first sixty (60) feet from grade are comprised of less than fifty percent (50%) glass, at least eighty-five percent (85%) of the glass on glass areas fifty (50) square feet or over must be treated. Of all glass areas over fifty (50) square feet, any glass within fifteen (15) feet of a building corner must be treated. Identify which glass areas are 50 sq. ft. or greater and which glass areas will be treated. Provide a detail of the specific treatment product that will be used.

35. Verify whether new parking lot or site lighting will be installed. New parking lot lighting must comply with City of Madison General Ordinances Section 10.085 outdoor lighting standards. If parking lot site lighting is provided, submit a lighting photometric plan and fixture cut sheets with the final plan submittal.

36. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.
37. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances and Chapter 33 Urban Design District ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

Please contact Bill Sullivan of the Madison Fire Department at (608) 261-9658 if you have any questions regarding the following two (2) items:

38. Provide a fire apparatus access plan.
39. The existing fire alarm and fire sprinkler systems shall be extended into the new addition and altered to accommodate new layout in the existing building.

Please contact Jeff Belshaw of the Madison Water Utility at (608) 261-9835 if you have any questions regarding the following item:

40. A Water Meter Application Form and fees must be submitted before connecting to the existing water lateral. Provide at least two working days notice between the application submittal and the scheduled lateral connection/extension. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining permits for your project:

1. After the plans have been revised per the above conditions, please **one (1) complete digital plan set in PDF format** of complete, fully dimensioned, and to-scale plans; the appropriate site plan review application and [site plan review fee \(pursuant to Section 28.206 of the Zoning Code\)](#); and any other documentation requested herein to the Zoning Administrator at SPRApplications@cityofmadison.com. (Note that that an individual email cannot exceed 20MB and it is the responsibility of the applicant to present files in a manner that can be accepted. Please email SPRApplications@cityofmadison.com regarding questions or if you need alternative filing options. The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. The [site plan review fee pursuant to Section 28.206](#) can be mailed in, dropped in the drop box at the Madison Municipal Building, or you can make an appointment at the Zoning counter to pay the fee. Checks should be made out to "City Treasurer." If you mail in the check or use the drop box, please include the application form with the project address and contact information. Zoning staff typically suggest using the drop box or making an appointment with the Zoning counter to pay the fee as they are the quickest.

Mailing Address: City of Madison Building Inspection. P.O. Box 2984. Madison, WI 53701-2984

Drop Box Location: Madison Municipal Building, Doty Street Entrance. 215 Martin Luther King Jr Blvd. Madison, WI 53701-2984

Zoning Counter Appointment: <https://www.cityofmadison.com/dpced/bi/schedule-a-counter-appointment/3423/>

3. City Agencies who submitted conditions of approval will review your revised plans to verify that their conditions, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.
4. This letter shall be signed by the applicant and property owner (if not the applicant) to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval. [Signature block on last page]
5. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. No alteration of a conditional use shall be permitted unless approved by the Plan Commission provided, however, the Zoning Administrator following consideration by the alderperson of the district, may approve minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the Plan Commission and the conditional use standards. This approval shall become null and void one (1) year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within 6 months of the issuance of said building permit. Where the plans have not been altered from the Plan Commission's approval, and the conditional use has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.

If you have any questions regarding obtaining your building permits, please contact the Zoning Administrator at (608) 266-4551. If you have any other questions or if you may be of any further assistance, please do not hesitate to contact my office at cwells@cityofmadison.com or (608) 261-9135.

Sincerely,



Chris Wells
Planner

I hereby acknowledge that I understand and will comply with the above conditions of approval for this project.

Signature of Applicant

Signature of Property Owner (if not the applicant)

cc: Brenda Stanley, Engineering
Jeff Quamme, Engineering Division – Mapping Section
Sean Malloy, Traffic Engineering
Jenny Kirchgatter, Zoning Administrator
Bill Sullivan, Fire Department
Jeff Belshaw, Water Utility
Jessica Vaughn, Urban Design Commission

LNDUSE-2022-00122			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Wells)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input type="checkbox"/>	Metro Transit	<input type="checkbox"/>	Other: Forestry