



Department of Planning & Community & Economic Development

Planning Division

Meagan Tuttle, Director

Madison Municipal Building, Suite 017

215 Martin Luther King, Jr. Blvd

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

www.cityofmadison.com

****BY E-MAIL ONLY****

November 12, 2024

Kevin Burow
Knothe & Bruce Architects
8401 Greenway Boulevard, Suite 900
Middleton, WI 53562

RE: Consideration of a conditional use in the Traditional Residential-Urban 2 (TR-U2) District for a multi-family dwelling with greater than 60 units; and consideration of a conditional use in the TR-U2 District for outdoor recreation, all to allow construction of a four-story, 136-unit multifamily building with an accessory outdoor pool. (ID [85319](#), LNDUSE-2024-00083)

On November 4, 2024, the Plan Commission found the standards met and **conditionally approved** your conditional uses for 8421 Mansion Hill Drive. In order to receive final approval of the conditional use and for any other permits that may need to be issued for your project, the following conditions shall be met:

Please contact Tim Troester of the Engineering Division at (608) 267-1995 if you have any questions regarding the following fourteen (14) items:

1. Enter into a City / Developer agreement for the required infrastructure improvements. Agreement to be executed prior to sign off. Allow 4-6 weeks to obtain agreement. Contact City Engineering to schedule the development and approval of the plans and the agreement. (MGO 16.23(9)c)
2. Construct sidewalk, terrace, curb and gutter and pavement to a plan as approved by City Engineer
3. This development is subject to impact fees for the Upper Badger Mill Creek Storm and Sanitary Impact Fee Districts. All impact fees are due and payable at the time building permits are issued (MGO Ch 20). Add the following note on the face of the plans: LOTS / BUILDINGS WITHIN THIS DEVELOPMENT ARE SUBJECT TO IMPACT FEES THAT ARE DUE AND PAYABLE AT THE TIME BUILDING PERMIT(S) ARE ISSUED
4. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to

Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))

5. All outstanding City of Madison sanitary sewer connection charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. This property is subject to Sanitary Connection charges for the Valley Ridge Interceptor Assessment District (\$90.86/ 1000 sf 2024 rate).
6. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.
7. A Storm Water Management Report and Storm Water Management Permit is required for this project. See Storm comments for report and permit specific details and requirements.
8. A Storm Water Maintenance Agreement (SWMA) is required for this project. See Storm comments for agreement specific details and requirements.
9. This site appears to disturb over one (1) acre of land and requires a permit from the WDNR for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR216 and NR-151 however a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process. Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line: <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm>.

The applicant is notified that the City of Madison is an approved agent of the Department of Safety and Professional Services (DSPS) and no separate submittal to this agency or CARPC is required for this project to proceed.

10. The proposed development proposes to construct underground parking. The proposed entrance to the underground parking is adjacent to a street low point. The applicant shall provide at a minimum of one (1) foot of rise from the adjacent back of walk in the driveway before breaking grade to the down ramp to the underground parking to protect the underground parking from inundation. The stated elevation is intended to be protective but does not guarantee a flood proof structure. The Developer/Owner are strongly encouraged to complete their own calculations and determine an elevation that protects their property to a level of service that they are comfortable with.
11. Provide additional detail how the enclosed depression(s) created by the parking entrance(s) to the below building parking area(s) is/are served for drainage purposes. The building must be protected from receiving runoff up through the 100-yr design storm that is current in Madison General Ordinance Chapter 37. If the enclosed depression(s) is/are to be served by a gravity system provide calculations stamped by a Wisconsin P.E. that show inlet and pipe capacities meet this requirement. If the enclosed depression(s)

is/are to be served by a pump system provide pump sizing calculations stamped by a Wisconsin P.E. or licensed Plumber that show this requirement has been met.

12. Include calculations in the stormwater management report that show how a 500-year storm event, as identified in Madison General Ordinance Chapter 37, would be handled by the proposed site design. These calculations are required to show that the proposed building does not flood during this design storm event using the site grades proposed.
13. This project will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval.

Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html>

Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.

14. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

Rate Control New Development: Detain the 2, 5, 10, 100, & 200 - year storm events, matching post development rates to predevelopment rates and using the design storms identified in Madison General Ordinances Chapter 37.

Infiltration: Provide infiltration of 90% of the pre-development infiltration volume.

TSS New Development: Reduce TSS by 80% (control the 5-micron particle) off of newly developed areas compared to no controls.

Oil/Grease Control: Treat the first 1/2 inch of runoff over the proposed parking facility and/or drive up window. Thermal Control: Provide substantial thermal control to reduce runoff temperature in cold water community or trout stream watersheds.

100-year Overflow: The applicant shall demonstrate that water can leave the site and reach the public ROW without impacting structures during a 100-year event storm. This analysis shall include reviewing overflow elevations and unintended storage occurring on site when the storm system has reached capacity.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

Please contact Luke Peters of the Traffic Engineering Division at (608) 266-6543 if you have any questions regarding the following twelve (12) items:

15. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be to engineering scale and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
16. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
17. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
18. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
19. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.

20. All pedestrian walkways adjacent parking stalls shall be 7 feet wide to accommodate vehicle overhang, signage and impediments to walkway movements. Any request for variance shall be submitted to and reviewed by City Traffic Engineering.
21. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
22. The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). If applicant believes public safety can be maintained they shall apply for a waiver of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the waiver shall be the determination of the City Traffic Engineer. The current plans show a reduction of the vision triangle at the corner of Mansion Hill Ave. and Mica Road, contact Jeremy Nash with Traffic Engineering at 608-266-6585 or jnash@cityofmadison.com to begin waiver process.
23. All parking ramps as the approach the public Right-of-Way shall not have a slope to exceed 5% for 20 feet; this is to ensure drivers have adequate vision of the Right-of-Way. If applicant believes public safety can be maintained they shall apply for a waiver, approval or denial of the waiver shall be the determination of the City Traffic Engineer.
24. City of Madison radio systems are microwave directional line of sight to remote towers citywide. The building elevation will need to be reviewed by Traffic Engineering to accommodate the microwave sight and building. The applicant shall submit grade and elevations plans if the building exceeds three stories prior to sign-off to be reviewed and approved by Andrew Oliver, (267-1979, aoliver@cityofmadison.com) Traffic Engineering Shop, 4151 Nakoosa Trail. The applicant shall return one signed approved building elevation copy to the City of Madison Traffic Engineering office with final plans for sign off.
25. The driveway slope to the underground parking is not identified in the plan set, Traffic Engineering recommends driveway slope under 10%; if the slope is to exceed 10%, the applicant shall demonstrate inclement weather mitigation techniques to provide safe ingress/egress to be approved by the City Traffic Engineer.
26. The applicant shall provide a clearly defined 5' walkway, from the front door to the public sidewalk, clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
27. "Stop" signs shall be installed at a height of seven (7) feet from the bottom of the sign at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.

28. The applicant shall show the dimensions for the proposed class III driveway including the width of the drive entrance, width of the flares, and width of the curb cut.
29. All existing driveway approaches on which are to be abandoned shall be removed and replaced with curb and gutter and noted on the plan.
30. Applicant shall submit for review a waste removal plan. This shall include vehicular turning movements.

Please contact Kathleen Kane of the Parks Division at (608) 261-9671 if you have any questions regarding the following three (3) items:

31. Excess parkland dedication occurred under the Springs at Pleasant View Plat (Outlots 2 and 3) and has been credited to the 136 MF units proposed on Lot 3 of the plat.
32. Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2)) are not required for this proposal.

33. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)) will be required for all new residential development associated with this project. This development is within the West Park- Infrastructure Impact Fee district. Please reference ID# 20023.2 when contacting Parks about this project.

Please contact Bradley Hofmann of the Forestry Section at (608) 267-4908 if you have any questions regarding the following one (1) item:

34. As defined by Madison General Ordinance 10.10, City Forestry will assess the full cost of the street tree installation to the adjacent property owner. City Forestry will determine street tree planting sites and tree species type. Street tree planting will be scheduled after there is substantial completion of the new plat development along the street segment.

Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following one (1) item:

35. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-

4646.

Please contact Timothy Sobota of Metro Transit at (608) 261-4289 if you have any questions regarding the following three (3) items:

36. The proposed development is outside Metro Transit's paratransit service area. The closest bus stop with regularly scheduled bus service is over one and one quarter miles walking distance, and the parcels would be greater than the $\frac{3}{4}$ mile regulatory distance from all day scheduled service - for passengers who might be eligible for door-to-door paratransit service.

37. Metro Transit operates limited weekday peak hour only commuter transit service along Waldorf Boulevard near this property.

38. Metro Transit would initially estimate the following counts of potentially eligible trips towards US Green Building Council/LEED Quality Access to Transit points: 10 Weekday & 0 Weekend. Please contact Metro Transit if additional analysis would be of interest.

Please contact Jeffrey Quamme of the City Engineering Division – Mapping Section at (608) 266-4097 if you have any questions regarding the following one (1) item:

39. If there are frost walls and/or footings required for any of the stoops/stairs within the Public Utility Easements on the perimeter of the site, written permission from the utilities shall be required.

Please contact Trent Schultz of the Parking Utility at (608) 246-5806 if you have any questions regarding the following one (1) item:

40. The applicant shall submit a Transportation Demand Management (TDM) Plan to tdm@cityofmadison.com. The TDM Plan is required per MGO 16.03. Applicable fees will be assessed after the TDM Plan is reviewed by staff.

Please contact Jacob Moskowitz, Assistant Zoning Administrator at (608) 266-4560 if you have any questions regarding the following three (3) items:

41. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect. Provide adequate development frontage landscaping per Section 28.142(5) Development Frontage Landscaping. Landscaping and/or ornamental fencing shall be provided between buildings or parking areas and the adjacent street(s), except where buildings are placed at the sidewalk. Note that landscaping must be installed on the private property.

42. Provide details demonstrating compliance with bird-safe glass requirements Section 28.129. For building façades where the first sixty (60) feet from grade are comprised of less

than fifty percent (50%) glass, at least eighty-five percent (85%) of the glass on glass areas fifty (50) square feet or over must be treated. Of all glass areas over fifty (50) square feet, any glass within fifteen (15) feet of a building corner must be treated. All glass railings must be treated. Identify which glass areas are 50 sq. ft. or greater and which glass areas will be treated. Provide a detail of the specific treatment product that will be used.

43. As proposed, the new rooftop mechanical equipment will not be visible to view. Upon installation, if the new rooftop mechanical equipment is visible, screening will be required per Section 28.142(9)(d).

Please now follow the procedures listed below for obtaining your conditional use:

1. After the plans have been revised per the above conditions, please submit one (1) complete digital plan set in PDF format and any other supporting materials that are necessary, as specified in this letter to sprapplications@cityofmadison.com (note: A 20MB email limit applies and multiple transmittals may be required). The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. A check for the site plan review fee shall be mailed to the City of Madison Building Inspection Division; PO Box 2984; Madison, WI 53701-2984.
3. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
4. The conditional use approval is valid for two (2) years from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
6. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0554 or lmcnabola@cityofmadison.com.

Sincerely,



Lisa McNabola
Planner

cc: Jacob Moskowitz, Zoning
Jeff Quamme, Engineering - Mapping Section
Tim Sobota, Metro Transit
Luke Peters, Traffic Engineering
Trent Schultz, Parking Utility
Jeff Belshaw, Water Utility
Tim Troester, Engineering
Kathleen Kane, Parks Division
Bradley Hofmann, Forestry

I hereby acknowledge that I understand and will comply with the above conditions of approval for conditional uses.

Signature of Applicant

Signature of Property Owner (if not the applicant)

LNDUSE-2024-00083			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div.	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input checked="" type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Other: Parking, Forestry