

LEGEND:

	PROJECT BOUNDARY - SEE CO11 FOR LIMIT OF WORK
—— STM ———	STORM PIPE
SAN	SANITARY PIPE
====	PERFORATED UNDERDRAIN
w	WATER PIPE
GAS	GAS LINE
0	WATER VALVE
	YARD HYDRANT
D	MANHOLE
	INLET
	UNDERDRAIN CLEANOUT
\bigcirc	STORM WATER CATCH BASIN
	ROCK TRENCH

NOTES:

- 1. SEE EXISTING CONDITIONS PLAN CO10 FOR LEGEND OF EXISTING FEATURES BENCHMARKS, AND CONTROL MONUMENTS.
- 2. CONTRACTOR SHALL PROTECT ALL UNEXPECTED UTILITIES ENCOUNTERED DURING CONSTRUCTION UNLESS DESIGNATED FOR DEMOLITION OR PERMISSION IS GIVEN IN WRITING BY UNIVERSITY OF WISCONSIN PLUMBING SUPERVISOR.
- 3. WATER MAIN SHALL HAVE 7.0 FT MIN COVER.
- 4. MAINTAIN CLEARANCE BETWEEN WATERMAINS AND EXISTING OR PROPOSED SEWER LINES AS IN CONFORMANCE WITH SPECIFICATIONS. 5. WATER MAIN SHALL BE INSULATED AT ALL CROSSINGS WITH STORM SEWER IN
- ACCORDANCE WITH \####J
- 6. CONTRACTOR SHALL COORDINATE LOCATIONS OF UNDERDRAINS IN PLANTING AREAS WITH LANDSCAPE PLAN. ADJUST HORIZONTAL UNDERDRAIN LOCATIONS AS NEED TO AVOID PLANTINGS.
- . CONTRACTOR SHALL CONNECT ALL UTILITIES SHOWN ON DRAWING TO BUILDING OUTLETS 5-0" OUTSIDE THE FACE OF BUILDING.
- 8. SEE SHEET XXX FOR SANITARY AND WATER SERVICE PROFILES.
- 9. COORDINATE WITH MEP REQUIRED FOR VERTICAL PROFILE OF SANITARY AND WATER SERVICE AT SOUTHWEST CORNER OF BUILDING. WATER AND SANITARY SERVICE WILL NEED TO BE COORDINATED WITH:
 CHILLED WATER ALIGNMENT AND PROFILE
 STEAM ALIGNMENT AND PROFILE
 PRIMARY AND SIGNAL DUCTS AND STRUCTURE ALIGNMENT AND PROFILE
 UW PRIVATE WATER MAIN ALIGNMENT AND PROFILE



