

Department of Planning & Community & Economic Development **Planning Division**

Website: www.cityofmadison.com

Madison Municipal Building 215 Martin Luther King, Jr. Boulevard P.O. Box 2985 Madison, Wisconsin 53701-2985 TDD 608 266-4747 FAX 608 266-8739 PH 608 266-4635

May 31, 2012

John Krebs JSD Professional Services, Inc. 161 Horizon Drive, Suite 101 Verona, Wisconsin 53593

RE: File No. LD 1215 – Certified Survey Map – 501 Moose Trail (Habitat for Humanity of Dane Co.)

Dear Mr. Krebs;

The three-lot certified survey of your client's property located at 501 Moose Trail, Section 26, Township 8N, Range 9E, City of Madison, Dane County, Wisconsin, is hereby **conditionally approved**. The site is zoned PUD-SIP. The conditions of approval from the reviewing agencies to be satisfied before final approval and recording of the CSM are:

Please contact Janet Dailey of the City Engineering Division at 261-9688 if you have questions regarding the following eight (8) conditions:

- 1. Prior to approval the owner shall enter into a Development Agreement, or complete an addendum to the existing agreement, for the installation of public sanitary sewer to serve the proposed Lot 3. The owner shall dedicate a public easement as needed for this sewer.
- As noted in the December 6, 2011 correspondence from City Engineering, all remaining warranty work associated with the Northport Commons Development Agreement for Contract 1982 shall be completed prior to the release of any further building permits. Contact Janet Dailey at 261-9688 for details on this requirement.
- 3. Provide information on the proposed side yard setbacks for the lots to determine the size of the drainage easement that will be required.
- 4. The developer shall enter into a City / Developer agreement for the installation of public improvements required to serve this CSM. The developer shall be required to provide deposits to cover City labor and materials and surety to cover the cost of construction. The developer shall meet with the City Engineer to schedule preparation of the plans and the agreement. The City Engineer will not sign off on this CSM without the agreement executed by the developer.
- 5. An erosion control plan and land disturbing activity permit shall be submitted to the City Engineering Division for review and approval prior to grading or any other construction activities. The Preconstruction Meeting for Public Improvements shall not be scheduled prior to issuance of this permit. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.

- 6. Arrows shall be added to the Certified Survey Map indicating the direction of drainage for each property line not fronting on a public street. In addition, the certified survey map shall include lot corner elevations, for all lot corners, to the nearest 0.25-foot. The following notes shall be added to the certified survey map:
 - a. Arrows indicate the direction of surface drainage swale at individual property lines. Said drainage swale shall be graded with the construction of each principal structure and maintained by the lot owner unless modified with the approval of the City Engineer. Elevations given are for property corners at ground level and shall be maintained by the lot owner.
 - b. All lots within this certified survey are subject to public easements for drainage purposes which shall be a minimum of 6-feet in width measured from the property line to the interior of each lot except that the easements shall be 12-feet in width on the perimeter of the certified survey. For purposes of two (2) or more lots combined for a single development site, or where two (2) or more lots have a shared driveway agreement, the public easement for drainage purposes shall be a minimum of six (6) feet in width and shall be measured only from the exterior property lines of the combined lots that create a single development site, or have a shared driveway agreement, except that the easement shall be twelve (12) feet in width along the perimeter of the certified survey. Easements shall not be required on property lines shared with greenways or public streets. No buildings, driveways, or retaining walls shall be placed in any easement for drainage purposes. Fences may be placed in the easement only if they do not impede the anticipated flow of water.

NOTE: In the event of a City of Madison Plan Commission and/or Common Council approved re-division of a previously subdivided property, the underlying public easements for drainage purposes are released and replaced by those required and created by the current approved subdivision.

<u>Information to Surveyor's</u>: In addition to notes such as this, WI State Plat Review now enforces the requirement that easements or other reference lines/areas be graphically shown, dimensioned and tied when they represent fixed locations. They will accept a "typical detail" when the easement or restriction can be effectively described and retraced from the typical detail.

7. Prior to the issuance of building permits, the developer shall submit a master stormwater drainage plan to the City Engineering Division for review and approval which shows lot corner elevations to the nearest 0.25-foot. For purposes of the plan, it shall be assumed that grading shall be done on a straight line grade between points unless other information is provided. The proposed slope between points shall always be greater than or equal to .0075 ft/ft. If a break in grade is required between lot corners a shot shall be taken at that break in grade to provide the Engineer with enough information to interpret the plan. The Developer shall also show proposed drainage arrows on the plan to indicate the proposed direction of drainage. The master storm water drainage plan shall be submitted to City Engineering in digital format with elevations/grades/contours shown on the recorded plat map of the development. The digital record shall be provided using the state plane coordinate system – NAD 27. No building permits shall be issued prior to City Engineering's approval of this plan.

The following note shall accompany the master storm water drainage plan:

"For purposes of this plan, it is assumed that grading shall be a straight line grade between points unless otherwise indicated. All slopes shall be 0.75% or steeper. Grade breaks between lot corners are shown by elevation or through the use of drainage arrows."

8. A minimum of 2 working days prior to requesting City Engineering Division signoff on the CSM, the applicant shall contact Janet Dailey (261-9688) to obtain the final stormwater utility charges that are due and payable prior to sub-division of the properties. The stormwater utility charges (as all utility charges) are due for the previous months of service. All charges shall be cleared prior to the land division (and subsequent obsolesces of the existing parcel).

Please contact Dennis Cawley of the Madison Water Utility at 261-9243 if you have questions about the following item:

 All operating private wells shall be identified and permitted by the Water Utility in accordance with MGO Section 13.21. All unused private wells shall be abandoned in accordance with MGO section 13.21.

Please contact Kay Rutledge of the Parks Division at 266-4714 if you have questions about the following item:

10. Any park dedication and park development impact fees for the three proposed single-family lots will be determined prior to the final recording of the CSM. Park impact fees shall be paid prior to the issuance of building permits for the single-family lots. All park impact fees due will be based on the year that building permits are issued.

Please contact Bill Sullivan of the Madison Fire Department at 261-9658 if you have questions about the following item:

- 11. Note: The Madison Fire Department recommends the installation of a residential fire sprinkler system in accordance with NFPA 13D and Comm. 82.40(3)(e). Additional information is available at the Home Fire Sprinkler Coalition website:
 - → http://www.homefiresprinkler.org/Consumer/ConsHome.html

Please contact my office at 261-9632 if you have any questions about the following item:

12. A minor alteration to the approved Planned Unit Development–Specific Implementation Plan showing the proposed land division in its final form in addition to the salient features of the future development of these lots (including but not limited to buildings, driveways, landscaping, etc.) shall be approved for recording by the Director of the Planning Division prior to final approval and recording of the Certified Survey Map.

Please note that the City's Office of Real Estate Services is reviewing the report of title provided with this survey and may have comments. That office will send any comments to you by fax or e-mail. If you have any questions, please contact Jenny Frese at 267-8719 for more information.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

A resolution approving the CSM and authorizing the City to sign it and any other documents related to the proposed land division was approved by the Common Council on May 15, 2012.

As soon as the comments and conditions have been satisfied as verified with a completed affidavit form (attached), the original along with the revised Certified Survey Map, with all signatures and approvals from the reviewing agencies, shall be brought to this office for final signoff. You or your client may then

LD 1215 501 Moose Trail May 31, 2012 Page 4

record the certified survey at the Dane County Register of Deeds. For information on recording procedures and fees, contact the Register of Deeds at 266-4141.

Prior to City Engineering final sign-off by the main office of the CSM, the final CSM shall be submitted to the Engineering Division Surveyor/ Land Records Coordinator for final technical review and approval. This submittal must occur a minimum of two working days prior to final Engineering Division signoff. E-mail submittal of the final CSM in PDF form is preferred. Transmit to epederson@cityofmadison.com.

Upon acceptance and recording of the certified survey map by the Dane County Register of Deeds, please transfer the recorded volume, document number, and page numbers to the copies and forward a copy to this office for our records. The original survey map with the recording information is permanently kept on file in the Dane County Register of Deeds Office. A copy of the recorded document can be obtained from the Register of Deeds Office, Room 110, City-County Building or the Real Estate Office in the Madison Department of Planning and Development.

Any appeal from this action, including the conditions of approval, must be filed with the Circuit Court within 30 days from the date of this letter. The approval of this CSM shall be null and void if not recorded six (6) months from the date of the approving resolution or this letter, whichever is later. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at 261-9632.

Sincerely,

Timothy M. Parks Planner

cc: Janet Dailey, City Engineering Division
Kay Rutledge, Parks Division
Dennis Cawley, Madison Water Utility
Bill Sullivan, Madison Fire Department
Jennifer Frese, Office of Real Estate Services
Dan Everson, Dane County Land Records and Regulations