



NOTE: Available fire flow based on the demand at hour 85 of a Maximum 10-Day scenario and is equivalent to Maximum Day demand.

|  |   |  |  |  |  |
|--|---|--|--|--|--|
|  | <b>Pipe Diameter</b><br>8 inch or less<br>10 - 14 inch<br>16 inch and greater | <b>Fire Flow Criteria</b><br>0 gpm<br>1,000 gpm<br>2,000 gpm<br>2,500 gpm<br>3,500 gpm | <b>Junction Fire flow Category</b><br>Available Flow Meets Criteria<br>Available Flow 75% - 99% Criteria<br>Available Flow 50% - 74% Criteria<br>Available Flow < 50% Criteria | <b>Legend</b><br>Floating Storage<br>Booster Pump Station<br>Well<br>Pressure Zone Boundary<br>Streets | <b>Figure B6</b><br><b>2010 East Side</b><br><b>Maximum Day</b><br><b>Fire Flow Availability</b><br><br> |
|--|---|--|--|--|--|