



CAPACITY REVIEW LETTER

**Department of Planning
& Community & Economic Development
Building Inspection Division**

215 Martin Luther King, Jr. Blvd.
Madison, Wisconsin 53703
608 266-4551 Fax 608 266-6522

Date: 5/6/13

FERCH ARCHITECTURE
2704 GREGORY ST
MADISON WI 53711

RE: Occupancy: Assembly Grp. A2
Tenant: The Fountain
Owner: 122 State Street Group
Square Feet: N/A

Project Location 122 STATE ST

THIS BUILDING HAS BEEN CLASSIFIED AS TYPE **IB** CONSTRUCTION.

CAPACITY:

DSPS 361.31 provide a first floor plan for this occupancy.

IEBC 904.1 The application was submitted showing that this is a non-sprinklered building. In order to increase the occupancy of this tenant space, the building shall be sprinklered.

This review only sets a capacity. There has been no review for compliance with applicable codes.

Inspector(s): **Roger Schrader**

Phone: 266-4553

Reviewed By: **Mike Van Erem, Plan Examiner** Phone: **266-4559**

Supervisor: **Harry Sulzer**