



January 10, 2017

Dear Resident / Business Owner / Owner:

The City of Madison Board of Public Works will hold a public hearing on the issue of allowing construction activities, with associated noise impacts, outside the period of 7:00 AM to 7:00 PM for certain work items associated with the Madison Metropolitan Sewerage District 2017 West Interceptor Rehabilitation 0200302014A Project located on Regent Street and North Randall Ave. The Public Hearing will be on January 25th, 2017 at 5:00 PM at the City of Madison, City-County Building Room 108, 210 Martin Luther King Jr. Blvd.

Madison General Ordinance section 24.08(3) provides the Common Council the ability to allow construction activities outside of the hours of 7:00 AM to 7:00 PM, with the passage of a resolution and a hearing before the Board of Public Works.

The Madison Metropolitan Sewerage District sanitary sewer located in Regent Street and North Randall Avenue is scheduled to be rehabilitated using Cured-in-Place Pipe (CIPP). The work is scheduled between April 3rd and June 30th, 2017. This process will extend the life of the sanitary sewer pipe and extend the time until the pipe needs to be removed and replaced. The CIPP process reduces the extent of disruptions compared to those associated with excavated pipe replacement.

The work requires pipe cleaning and pipe lining equipment located in the street. Some excavation is required to provide access to the underground pipes. Sewage flow must be bypassed around the pipe being rehabilitated. Pumps and pipes for bypass will be located above ground in the Right of Way. Limited restoration of street pavement will follow completion of the pipe lining. The noise associated with the work is caused by bypass pumps, generators, power winch equipment, boilers, and refrigeration trucks.

Much of the work will be scheduled to occur during nighttime hours to minimize disruption of traffic and Metro Transit service. Work outside of the normally allowed hours will also reduce the impact of water and sewer service interruption on businesses and residences. The work completed at night occurs when flows in the pipe are lower which facilitates bypass pumping. Also, the length of time the liner needs to cure exceeds the normal working hours.

If you have any questions in regards to the construction activities, please contact Jeff Klawes, MMSD at 222-1201 Ext 238 or at jeffk@madsewer.org

Sincerely,

A handwritten signature in black ink that reads "D. Michael Mucha". The signature is written in a cursive style with a large, stylized "D" at the beginning.

Michael Mucha, P.E.
Madison Metropolitan Sewerage District

cc by email: Ald. Sarah Eskrich, District 13
Bruce Borelli, MMSD
Greg Fries, City Engineering
Kyle Frank, City Engineering
Mark Moder, City Engineering

