

## Putnam, William

---

**From:** Sapp, John  
**Sent:** Friday, December 01, 2017 7:45 AM  
**To:** Putnam, William  
**Subject:** Anchor Bank: Carroll Parking Accessibility  
**Attachments:** 20171130155220293.pdf

Bill, I had noticed the Anchor Bank handicap parking access might be steep for typical wheelchair standards (2% from what I could find). The actual slopes are 4% and 5.7%. I took another look and these grades were unavoidable and nothing could be done to achieve 2% both directions for any of the spots on Carroll.

The sidewalk ramp on is all within ADA standards. The spots are signed as disabled parking spots and not specifically wheel chair accessible so we might be ok. I guess the question comes down to is it better to have some spots for use, despite steeper grades, or none at all because users would encounter unexpected conditions. I'll defer to you as on street angled parking is something I have limited experience with. Thanks!

John Sapp, P.E.  
Department of Public Works  
Engineering Division  
City-County Bldg., Rm. 115  
210 Martin Luther King, Jr. Blvd.  
Madison, WI 53703  
608-261-5580  
jsapp@cityofmadison.com