



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

126 S. Hamilton Street
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
Fax (608) 267-8739
www.cityofmadison.com

July 18, 2018

Mark Pearson
Amcor
4101 Lien Road
Madison, WI 53704

RE: Legistar #51954; Accela 'LNDUSE-2018-00062' -- Approval of a conditional use to construct a private parking facility at **1602 Parkside Drive**.

Dear Mr. Pearson:

At its July 16, 2018 meeting, the Plan Commission, meeting in regular session, found the standards met and approved your conditional use request to construct a private parking facility (parking lot) in a Commercial Corridor - Transitional (CC-T) zoning district at **1602 Parkside Drive**. In order to receive final approval of the conditional use for any permits that may need to be issued for your project, the following conditions shall be met:

Please contact Jenny Kirchgatter, Assistant Zoning Administrator, at 266-4429 if you have any questions regarding the following three (3) items:

1. Provide a calculation and plan detail for lot coverage with the final submittal. The lot coverage maximum is 85%. Lot coverage is defined as the total area of all buildings, measured at grade, all accessory structures, and all paved areas as a percentage of the total area of the lot, with the following exceptions: sidewalks or paved paths no wider than five (5) feet, pervious pavement, green roofs and decks.
2. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.
3. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.

Please contact Brenda Stanley of the Engineering Division at 261-9127 if you have any questions regarding the following seventeen (17) items:

4. The adjacent property (3939 Lien Rd) is a former dry cleaner being investigated under DNR

supervision. Contamination from 3939 Lien Rd may extend onto this property. It is recommended that the developer coordinate with the DNR to ensure proper soil testing and disposal. Contact the DNR project manager Trevor Bannister with questions (608.275.3490, trevora.bannister@Wisconsin.gov).

5. This site has no storm sewer immediately available for connection to the required detention system. The applicant shall either find a means to design the storm system to discharge to the curb or shall be required to extend storm up Parkside Drive approximately 200 feet to serve this parcel. An alternate option would be to connect to the existing inlet located within a public easement behind 3841 E Washington Ave (Howard Johnsons). If this option is chosen the applicant will be required to obtain off-site storm sewer easement from the necessary properties, for the privately owned storm sewer system.
6. All outstanding Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO16.23(9)(d)(4))
7. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in a TMDL ZONE. The project will be expected to meet a higher standard of erosion control than the minimum standards set by the WDNR in order to comply with TMDL limits.
8. The Applicant shall submit, prior to plan sign-off but after all revisions have been completed, a digital CAD file (single file) to the Engineering Division with any private storm and sanitary sewer utilities. The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number:
 - a. Building Footprints
 - b. Internal Walkway Areas
 - c. Internal Site Parking Areas
 - d. Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
 - e. Right-of-Way lines (public and private)
 - f. Lot lines or parcel lines if unplatted
 - g. Lot numbers or the words unplatted
 - h. Lot/Plat dimensions
 - i. Street names
 - j. Private on-site sanitary sewer utilities (including all connections to public sanitary)
 - k. Private on-site storm sewer utilities (including all connections to public storm)

All other levels (contours, elevations, etc) are not to be included with this file submittal.

NOTE: Email CAD file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West). Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks,

parking/pavement, private on-site sanitary sewer utilities, or private on-site storm sewer utilities during construction will require a new CAD file.

9. The applicant shall submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West). The digital copies shall be to scale, and shall have a scale bar on the plan set. (POLICY and MGO 37.09(2))PDF submittals shall contain the following information:
 - a. Building Footprints
 - b. Internal Walkway Areas
 - c. Internal Site Parking Areas
 - d. Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
 - e. Right-of-Way lines (public and private)
 - f. Lot lines or parcel lines if unplatted
 - g. Lot numbers or the words unplatted
 - h. Lot/Plat dimensions
 - i. Street names
 - j. Stormwater Management Facilities
 - k. Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).
10. The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including:a) SLAMM DAT filesb) RECARGA filesc) TR-55/HYDROCAD/Etcd) Sediment loading calculations. If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided.
11. This project appears to require construction dewatering. A dewatering plan shall be submitted to City Engineering as part of the Erosion Control Permit application and plan. If contaminated soil or groundwater conditions exist on or adjacent to this project additional WDNR, Public Health, and/or City Engineering approvals may be required prior to the issuance of the required Erosion Control Permit.
12. Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project. Include copies of all stormwater, utility, and detail plan sheets that contain stormwater practices on 8.5x14 size paper in the draft document. These drawings do not need to be to scale as they are for informational purposes only. Once City Engineering staff have reviewed the draft document and approved it with any required revisions submit a signed and notarized original copy to City Engineering. Include a check for \$30.00 made out to Dane County Register of Deeds for the recording fee. City Engineering will forward the document and fee for recording at the time of issuance of the stormwater management permit. Draft document can be emailed to Tim Troester (west) at ttroester@cityofmadison.com, or Jeff Benedict at jbenedict@cityofmadison.com final document and fee should be submitted to City Engineering.
13. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal

Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year.

14. This site appears to disturb over one (1) acre of land and requires a permit from the WDNR for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR216 and NR-151 however a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process. Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm> (NOTIFICATION)
15. This project will require a concrete management plan as part of the erosion control plan to be reviewed and approved by the City Engineer's Office. (POLICY)
16. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to detain the 2, 10, & 100 -year storm events, matching post development rates to predevelopment rates.
17. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to reduce TSS by 80% (control the 5 micron particle) off of newly developed areas compared to no controls.
18. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to provide infiltration in accordance with Chapter 37 of the Madison General Ordinances.
19. Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.
20. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to provide oil/grease control treating the first 1/2 inch of runoff over the entire parking lot in accordance with Chapter 37 of the Madison General Ordinances.

Please contact Jeff Quamme of City Engineering – Mapping Section at 266-4097 if you have any questions regarding the following two (2) items:

21. The fencing and parking improvements along the north line are within very close proximity of a public sanitary sewer manhole along the north side of the site. Applicant shall provide a map exhibit of planned improvements (fence and parking) within the Public Sanitary Sewer Easement (Doc No. 1368992 plat of Colony Heights) and \$500 administrative fee to Jeff Quamme (jrquamme@cityofmadison.com) to set up a Real Estate project for a Consent to Occupy Easement Agreement.
22. The fencing along the north line of the site requires written consent by MG&E per Doc No 2096062. Coordination with MG&E is the responsibility of the applicant prior to construction.

Please contact Sean Malloy of Traffic Engineering at 266-5987 if you have any questions regarding the following two (2) items:

23. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
24. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.

Please contact Brad Hofmann of the Parks/Forestry Division at 266-4816 if you have any questions regarding the following two (2) items:

25. Additional street trees are needed for this project. All street tree planting locations and trees species within the right of way shall be determined by City Forestry. Please submit a site plan (in PDF format) to Brad Hofmann – bhofmann@cityofmadison.com or 266-4816. Tree planting specifications can be found in section 209 of City of Madison Standard Specifications for Public Works Construction -
26. Contractor shall contact City Forestry Brad Hofmann bhofmann@cityofmadison.com or 266-4816 at least one week prior to planting to schedule inspecting the nursery stock and review planting specifications with the landscaper.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your conditional use:


1. Please revise your plans per the above conditions and submit **six (6) copies** of a complete, fully dimensioned and scaled plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off. The final site plan shall be accompanied by the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, **126 S. Hamilton Street**. This submittal shall all also include one complete digital plan set in PDF format. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
3. The approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence

within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.

4. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
5. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0455.

Sincerely,



Colin Punt
Planner

I hereby acknowledge that I understand and will comply with the above conditions of approval for conditional use.

Signature of Applicant

Signature of Property Owner (if not the applicant)

cc: Jenny Kirchgatter, Asst. Zoning Administrator
Brenda Stanley, Engineering Division
Jeff Quamme, Engineering Division – Mapping
Sean Malloy – Traffic Engineering
Brad Hofmann – Parks/Forestry Division

LNDUSE-2018-00062			
For Official Use Only, Re: Final Plan Routing			
<input type="checkbox"/>	Planning Div. (Punt)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input type="checkbox"/>	Fire Department	<input type="checkbox"/>	Water Utility
<input type="checkbox"/>	Metro Transit	<input type="checkbox"/>	Other: