



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King, Jr. Blvd
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
www.cityofmadison.com

December 18, 2018

Brian Stoddard
Knothe & Bruce Architects, LLC
7601 University Avenue #201
Middleton, WI 53704

RE: Legistar #53611; Accela 'LNDUSE-2018-00112' -- Approval of a demolition permit to demolish a restaurant building and a conditional use to construct a four-story 96-unit mixed use building with 4,000 square feet of rentable commercial space at **5614 Schroeder Road**.

Dear Mr. Stoddard:

At its December 17, 2018 meeting, the Plan Commission, meeting in regular session, found the standards met and approved your demolition permit to demolish a restaurant building and a conditional use to construct a four-story, 96-unit mixed-use building with 4,000 square feet of leasable commercial space and parking on the lower level in Urban Design District #2 at **5614 Schroeder Road**. In order to receive final approval of the conditional use and for any permits that may need to be issued for your project, the following conditions shall be met:

Please contact Colin Punt of the Planning Division, at 243-0455, if you have any questions regarding the following five (5) items, including items 3-5, added by the Plan Commission in its approval motion:

1. No HVAC "wall-pack" penetrations/louvers are shown on the street-facing facades. Unless specifically approved by the Plan Commission, the addition of wall packs on outward-facing walls is not included in this approval and will require approval of an alteration to this conditional use should they be proposed at a later time.
2. Make the changes and enhancements to the landscaping plan as required by the UDC in its motion for final approval, dated December 5, 2018.
3. That the applicant work with City Forestry and other City staff to save the existing terrace canopy trees along Schroeder Road.
4. That the applicant make every effort to underground utilities along the property's Schroeder Road frontage.
5. That the applicant make every effort to install solar facilities on the building's roof.

Please contact Jacob Moskowitz, Assistant Zoning Administrator, at 266-4429 if you have any questions regarding the following five (5) items:

6. Section 28.185(7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson (608-266-4682).
7. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition.
8. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.
9. No approval for an outdoor eating area is being sought at this time. Any future outdoor eating area will require a new conditional use.
10. As each tenant space is leased, the entire development must reflect compliance in the required amount, type and number of auto and bicycle parking spaces, to be reviewed prior to obtaining zoning approval for each use.

Please contact Tim Troester of the Engineering Division, at 267-1995 if you have any questions regarding the following fourteen (14) items:

11. Prior to approval, the owner or owner's representative shall obtain a permit to plug each existing sanitary sewer lateral that serves a building which is proposed for demolition. For each lateral to be plugged the owner shall complete a sewer lateral plugging application and pay the applicable permit fees. The permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
12. All outstanding Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff.
13. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service.
14. Plan shows using existing sanitary sewer laterals for sanitary sewer service. Recommend installing new lateral. Existing laterals to site are most likely vitrified clay and are not large enough for this redevelopment.
15. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in a TMDL ZONE. The project will be expected to meet a higher standard of erosion control than the minimum standards set by the WDNR in order to comply with TMDL limits.
16. The applicant shall submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West). The digital copies

shall be to scale, and shall have a scale bar on the plan set. PDF submittals shall contain the following information:

- a) Building Footprints
- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)
- f) Lot lines or parcel lines if unplatted
- g) Lot numbers or the words unplatted
- h) Lot/Plat dimensions
- i) Street names
- j) Stormwater Management Facilities
- k) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).

17. The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including:
 - a) SLAMM DAT files
 - b) RECARGA files
 - c) TR-55/HYDROCAD/Etc
 - d) Sediment loading calculations. If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided.
18. Provide additional detail how the enclosed depression(s) created by the parking entrance(s) to the below building parking area(s) is/are served for drainage purposes. The building must be protected from receiving runoff up through the 24-hr, 100-yr design storm. If the enclosed depression(s) is/are to be served by a gravity system provide calculations stamped by a Wisconsin P.E. that show inlet and pipe capacities meet this requirement. If the enclosed depression(s) is/are to be served by a pump system provide pump sizing calculations stamped by a Wisconsin P.E. or licensed Plumber that show this requirement has been met.
19. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year.
20. This site appears to disturb over one (1) acre of land and requires a permit from the WDNR for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR216 and NR-151 however a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process. Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line <http://dnr.wi.gov/Runoff/stormwater/constrformsinfo.htm>
21. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to Reduce TSS by 80% off of the proposed development when compared with the existing site.

22. Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.
23. The applicant's utility contractor shall obtain a connection permit and excavation permit prior to commencing the storm sewer construction. MGO 37.05(7) This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.
24. The Applicant's project requires the minor restoration of the street and sidewalk. The Applicant shall obtain a Street Excavation Permit for the street restoration work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. (MGO 16.23(9)(d)(6)) This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.

Please contact Lori Zenchenko of the Engineering Division – Mapping Section, at 266-5952 if you have any questions regarding the following five (5) items:

25. The proposed parking lot and curbing encroach into the Public Utility Easement along the east side of this site. The applicant/owner is responsible to contact the affected utility companies to coordinate and obtain permission to place the improvements over the existing underground facilities.
26. The proposed new building will cross an underlying platted lot line. Current fire code and City enforcement requires the underlying platted lot line be dissolved by Certified Survey Map (CSM) prior to issuance of a building permit. A CSM and required supporting information shall be prepared and submitted to the City of Madison Planning Department. The CSM shall be approved by the City and recorded with the Dane County Register of Deeds prior to issuance of a building permit.
27. The address of 5614 Schroeder Rd will be retired with the demolition of the existing building. The base address for the apartments is 5630 Schroeder Rd. Some of the townhouses & the commercial address will be determined when the official addressing plan is created and approved.
28. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
29. Submit a Floor Plan in PDF format to Lori Zenchenko (lzenchenko@cityofmadison.com) that includes a floor plan for each floor on a separate sheet for the development of a complete interior addressing plan. The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) prior to the application submittal for the final Site Plan Approval with Zoning. The approved Addressing Plan shall be included in the final application. For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved. The final revised Addressing Plan shall be submitted by the applicant to Zoning to be attached to the final filed approved site plans.

Please contact Sean Malloy of the Traffic Engineering Division, at 266-5987 if you have any questions regarding the following twelve (12) items:

30. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
31. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
32. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
33. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
34. The applicant(s) shall maintain a 5 foot wide, Americans with Disabilities Act (ADA) compliant, pedestrian walkway for the duration of the project on all street frontages classified as a collector or higher. The applicant shall also maintain a 5 foot wide bicycle lane for the duration of the project on all street frontages with existing bicycle facilities. Exceptions to this requirement may be granted by Traffic Engineering on a limited term basis if and when the applicant can show a public safety concern and they also provide a clear date when the pedestrian/bicycle facilities are to be restored. All closures shall be designed by the applicant, in accordance with the Manual on Uniform Traffic Control Devices (MUTCD), to be submitted and approved by Traffic Engineering.
35. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
36. All pedestrian walkways adjacent parking stalls shall be 7 feet wide to accommodate vehicle overhang, signage and impediments to walkway movements. Any request for variance shall be submitted to and reviewed by City Traffic Engineering.
37. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
38. Include a parking plan demonstrating how specific stalls, to be used by the commercial site, will be reserved. Include any signage to be used to achieve this goal in the submitted plans.
39. Secure parking facility. This is usually done with continuous six (6) inch curb, timbers, preformed

wheel stops, guardrail erected at a height of eighteen (18) inches or fencing of sufficient strength to act as a vehicle bumper.

40. The applicant shall provide a pedestrian connection from Schroeder Court to the Northwest corner of the parking lot.
41. The applicant shall provide a clearly defined 5' walkway clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.

Please contact Bill Sullivan of the Fire Department, at 261-9658 if you have any questions regarding the following one (1) item:

42. Please consider allowing Madison Fire Dept. to conduct training sequences prior to demolition. Contact MFD Training Division to discuss possibilities: Division Chief Tracy Burrus at tburrus@cityofmadison.com or (608)266-5959.

Please contact Timothy Sobota of Metro Transit, at 261-4289 if you have any questions regarding the following one (1) item:

43. Metro Transit provides daily bus service along Schroeder Road, at stops just to the west and east of the project site. Trips operate at least once every 30 minutes on weekdays, but only pass once an hour on weekends.

Please contact Sarah Lerner of the Parks/Forestry Division, at 261-4281 if you have any questions regarding the following seven (7) items:

44. Pursuant to the authority established under Wis. Stat. § 66.0617(7), and in the interests of promoting the development of low-cost housing in the City, low-cost housing is exempt from the park impact fees beginning January 1, 2017. This exemption only applies to those dwelling units or bedrooms within a development that are determined to be low-cost housing. This exemption does not extend to the land dedication requirements set forth under Sec. 16.23(8)(f), MGO, nor any other impact fees that may apply to a development.
45. The park impact fee will be exempt for developments that meet the "low-cost housing" requirements, as defined as rental or owner-occupied housing units that are affordable, as that term is defined in Sec. 4.22(2), MGO, and which meet the deed restriction requirements of Sec. 4.22(7). The determination whether a proposed development will create low-cost housing, and how much low-cost housing it will create, shall be made by the Community Development Division.
46. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project that is not exempted. This development is within the West Park -Infrastructure Impact Fee district. Please reference ID# 18167 when contacting Parks about this project.

47. An existing inventory of trees (location, species, & DBH) and any tree removal plans (in PDF format) shall be submitted to the plans and Brad Hofmann – bhofmann@cityofmadison.com or 266-4816. All proposed street tree removals within the right of way shall be reviewed by City Forestry. Approval and permitting of street tree removals shall be obtained from the City Forester and/or the Board of Public Works prior to the approval of the site plan.
48. Existing street trees shall be protected. Please include the following note on the site plan: Contractor shall install tree protection fencing in the area between the curb and sidewalk and extend it at least 5 feet from both sides of the tree along the length of the terrace. No excavation is permitted within 5 feet of the outside edge of a tree trunk. If excavation within 5 feet of any tree is necessary, contractor shall contact City Forestry (266- 4816) prior to excavation to assess the impact to the tree and root system. Tree pruning shall be coordinated with City Forestry prior to the start of construction. Tree protection specifications can be found in section 107.13 of City of Madison Standard Specifications for Public Works Construction - <http://www.cityofmadison.com/business/pw/documents/StdSpecs/2018/Part1.pdf>. Any tree removals that are required for construction after the development plan is approved will require at least a 72 hour wait period before a tree removal permit can be issued by Forestry, to notify the Alder of the change in the tree plan.
49. Contractor shall contact City Forestry Brad Hofmann bhofmann@cityofmadison.com or 266-4816 at least one week prior to planting to schedule inspecting the nursery stock and review planting specifications with the landscaper.
50. Additional street trees are needed for this project. All street tree planting locations and trees species within the right of way shall be determined by City Forestry. Please submit a site plan (in PDF format) to Brad Hofmann – bhofmann@cityofmadison.com or 266-4816. Tree planting specifications can be found in section 209 of City of Madison Standard Specifications for Public Works Construction.

Please contact Adam Wiederhoeft of the Water Utility, at 266-9121 if you have any questions regarding the following five (5) items:

51. This property is in a Wellhead Protection District–Zone (WP-12). Owner/Applicant shall provide the Madison Water Utility with confirmation that no hazardous and/or toxic materials will be stored on site, and that all proposed uses of this site comply with the City of Madison Wellhead Protection Ordinance. Any future change in use for this property will require review by the Madison Water Utility General Manager or his designated representative. Contact Adam Wiederhoeft at awiederhoeft@madisonwater.org for additional information, including a summary of the submittal requirements.
52. The site utility plan depicts water service is to be provided by reconnecting to an existing 1966 3/4-IN diameter water lateral. Please revise site utility plan to depict correct location for new water service lateral and size required, or confirm intent to connect to existing 3/4-IN diameter copper lateral.
53. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.

54. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumberscontractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.
55. Madison Water Utility will be required to sign off as part of the approval review associated with this Land Use Application/Site Plan Review prior to the issuance of building permits for the proposed development

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your conditional use:


1. Please revise your plans per the above conditions and submit **twelve (12) copies** of a complete, fully dimensioned and scaled plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off. The final site plan shall be accompanied by the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, **215 Martin Luther King, Jr. Blvd.** This submittal shall all also include one complete digital plan set in PDF format. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
3. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.
4. The conditional use approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or

additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.

- The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0455.

Sincerely,



Colin Punt
 Planner

I hereby acknowledge that I understand and will comply with the above conditions of approval for demolition permit and conditional use.

Signature of Applicant

Signature of Property Owner (if not the applicant)

- cc: Jenny Kirchgatter, Asst. Zoning Administrator
 Sean Malloy, Traffic Engineering
 Brenda Stanley, Engineering Division
 Lori Zenchenko, Engineering Division – Mapping
 Bill Sullivan, Fire Department
 Tim Sobota, Metro Transit
 Adam Wiederhoeft, Water Utility
 Kathleen Kane, Parks/Forestry Division
 Janine Glaeser, UDC Secretary
 Bryan Johnson, Streets Division

LNDUSE-2018-00112			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Punt)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input checked="" type="checkbox"/>	Metro Transit	<input type="checkbox"/>	Other: