



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King, Jr. Blvd
P.O. Box 2985
Madison, Wisconsin 53701-2985
Phone: (608) 266-4635
www.cityofmadison.com

April 25, 2019

Kevin Burow
Knothe & Bruce Architects, LLC
7601 University Avenue #201
Middleton, WI 53704

RE: Legistar #55023; Accela 'LNDUSE-2019-00020' -- Approval of demolition permits to demolish five residential buildings and conditional use to construct a five-story 58-unit apartment building at 616-632 West Wilson Street.

Dear Mr. Burow:

At its April 22, 2019 meeting, the Plan Commission, meeting in regular session, found the standards met and approved your demolition permits to demolish five residential buildings and conditional use to construct a five-story 58-unit apartment building at **616-632 West Wilson Street**. In order to receive final approval of the demolition permits and conditional use and for any permits that may need to be issued for your project, the following conditions shall be met:

Please contact Colin Punt of the Planning Division, at 243-0455, if you have any questions regarding the following five (5) items, including items 4 and 5, added by the Plan Commission in its approval motion:

1. A historic file shall be created for 616 West Wilson Street, including floor plans, photographs of the building's interior and exterior, and photographs of the house within the context of the other houses on the block. The file shall be filed with the City's Preservation Planner.
2. Any relocation of the existing houses may be considered by the Director of DPCED as a minor alteration. Prior to submittal, the applicant shall receive a recommendation from the alderperson. If the alderperson of the district and the Director of DPCED do not agree that a request for minor alteration should be approved, then the request for minor alteration shall be decided by the Plan Commission. In applying for the minor alteration, the applicant must provide a route and plan for relocating the house(s) to allow the City Forester to prepare a report regarding the impact the proposed building relocation(s) could have on City terrace trees. Receivership sites for any relocated buildings may require addition land use approvals.
3. No HVAC "wall-pack" penetrations/louvers are shown on the street-facing facades. Unless specifically approved by the Plan Commission, the addition of wall packs on outward-facing walls is not included in this approval and will require approval of an alteration to this conditional use should they be proposed at a later time.

4. That wall-mounted bicycle racks be mounted in front of all vehicle parking spaces adjacent to walls.
5. That the parking garage ventilation intakes and exhaust louvers be generally located at the southwest and northeast corners of the building.

Please contact Jenny Kirchgatter, Assistant Zoning Administrator, at 266-4429 if you have any questions regarding the following nine (9) items:

6. Section 28.185(7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson (608-266-4682).
7. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition.
8. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.
9. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.
10. Show the dimensions of the parking garage openings on the plans. Parking garage openings visible from the sidewalk shall have a clear maximum height of sixteen (16) feet and a maximum width of twenty-two (22) feet.
11. Show the dimensions of the rear balconies. The balconies may extend a maximum of six (6) feet into the rear yard setback.
12. Provide details showing that the street-facing façade meets the door and window opening requirements of Section 28.071(3)(e). For street-facing facades with ground story residential uses, ground story openings shall comprise a minimum of fifteen percent (15%) of the façade area, and upper story openings shall comprise a minimum of fifteen (15%) of the façade area per story.
13. Submit a rooftop plan showing the location of any proposed rooftop mechanical equipment and screening. All rooftop equipment except for solar and wind equipment shall be screened from view from adjacent streets and public rights-of-way per Sections 28.071(3)(h) and 28.142(9)(d). Screens shall be of durable, permanent materials that are compatible with the primary building materials.
14. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.

Please contact Tim Troester of the Engineering Division, at 267-1995 if you have any questions regarding the following fifteen (15) items:

15. The Plan set submitted shows surface stormwater drainage discharge at the northwest corner of the site to the RR ROW. This is not allowed. All stormwater shall be discharged to the Public Road ROW directly or through an approved private stormwater easement. Additionally the east underground garage entrance drains an enclosed depression below street grade back to the street storm sewer via gravity. This is not allowed. A pump system shall be designed isolated from the storm sewer with backflow preventer.
16. Prior to approval, the owner or owner's representative shall obtain a permit to plug each existing sanitary sewer lateral that serves a building which is proposed for demolition. For each lateral to be plugged the owner shall complete a sewer lateral plugging application and pay the applicable permit fees. The permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
17. This development appears to have multiple existing laterals extended to the property line. In an effort to reduce inflow and contamination to the City's sanitary system our policy is to plug at the main laterals that are no longer active when associated with a new or redevelopment project. City Engineering will complete a TV inspection of the main to help clarify which laterals are active and which need to be plugged as a condition of approval for this application. The applicant is notified that as a condition of approval a sewer plug permit will be required for one or more laterals associated with this project that will no longer be used at its completion.
18. All outstanding Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
19. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
20. This property has five (5) 6-inch diameter sewer laterals and the proposed lateral is also 6-inch diameter. Confirm that one lateral is sufficient or install additional laterals if necessary to address the development's needs.
21. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in a TMDL ZONE. The project will be expected to meet a higher standard of erosion control than the minimum standards set by the WDNR in order to comply with TMDL limits.
22. The Applicant shall submit, prior to plan sign-off but after all revisions have been completed, a digital CAD file (single file) to the Engineering Division with any private storm and sanitary sewer utilities. The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number:
 - a) Building Footprints

- b) Internal Walkway Areas
- c) Internal Site Parking Areas
- d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
- e) Right-of-Way lines (public and private)
- f) Lot lines or parcel lines if unplatted
- g) Lot numbers or the words unplatted
- h) Lot/Plat dimensions
- i) Street names
- j) Private on-site sanitary sewer utilities (including all connections to public sanitary)
- k) Private on-site storm sewer utilities (including all connections to public storm)

All other levels (contours, elevations, etc) are not to be included with this file submittal.

NOTE: Email CAD file transmissions are preferred to: bstanley@cityofmadison.com (East) or ttroester@cityofmadison.com (West). Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement, private on-site sanitary sewer utilities, or private on-site storm sewer utilities during construction will require a new CAD file.

23. This project appears to require construction dewatering. A dewatering plan shall be submitted to City Engineering as part of the Erosion Control Permit application and plan. If contaminated soil or groundwater conditions exist on or adjacent to this project additional WDNR, Public Health, and/or City Engineering approvals may be required prior to the issuance of the required Erosion Control Permit.
24. This project appears to require permanent dewatering. A permit to connect to the public stormwater system shall be required from City Engineering. Additionally, a permit for non-storm discharge to the storm sewer system from the City/County Health Department shall also be required. If contaminated soil or groundwater conditions exist on or adjacent to this project additional WDNR, Public Health, and/or City Engineering approvals may be required prior to issuance of the connection and non-storm discharge permits.
25. Provide additional detail how the enclosed depression(s) created by the parking entrance(s) to the below building parking area(s) is/are served for drainage purposes. The building must be protected from receiving runoff up through the 24-hr, 100-yr design storm. If the enclosed depression(s) is/are to be served by a gravity system provide calculations stamped by a Wisconsin P.E. that show inlet and pipe capacities meet this requirement. If the enclosed depression(s) is/are to be served by a pump system provide pump sizing calculations stamped by a Wisconsin P.E. or licensed Plumber that show this requirement has been met.
26. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year.
27. For Commercial sites < 1 acre in disturbance the City of Madison is an approved agent of the Department of Commerce and WDNR. As this project is on a site with disturbance area less than one (1) acres, and contains a commercial building, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of

Commerce. No separate submittal to Commerce or the WDNR is required.

28. Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.
29. The Applicant's project requires the minor restoration of the street and sidewalk. The Applicant shall obtain a Street Excavation Permit for the street restoration work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. (MGO 16.23(9)(d)(6)) This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.

Please contact Jeff Quamme of the Engineering Division – Mapping Section, at 266-4097 if you have any questions regarding the following six (6) items:

30. Provide confirmation of the permit from WisDOT / Wisconsin Southern RR for the storm sewer pipe crossing railroad lands at the northeasterly corner of the site.
31. The pending Certified Survey Map application for this property shall be completed and recorded with the Dane County Register of Deeds (ROD) prior to issuance of any building permits for new construction. When the recorded CSM image is available from the ROD, the Assessor's Office can then create the new Address-Parcel- Owner (APO) data in GEO so that the Accela system can upload this data and permit issuance made available for this new land record
32. Provide the recorded release of the private shared driveway easement per Document No. 1727490.
33. The building encroaches into the Underground Electric Easement to MG&E per Doc No 2048977. Provide the necessary recorded easement release or partial release by MG&E.
34. The address of the proposed apartment building is 622 W Wilson St. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
35. Submit a Floor Plan in PDF format to Lori Zenchenko (lzenchenko@cityofmadison.com) that includes a floor plan for each floor on a separate sheet for the development of a complete interior addressing plan. The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) prior to the application submittal for the final Site Plan Approval with Zoning. The approved Addressing Plan shall be included in the final application. For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved. The final revised Addressing Plan shall be submitted by the applicant to Zoning to be attached to the final filed approved site plans.

Please contact Sean Malloy of the Traffic Engineering Division, at 266-5987 if you have any questions regarding the following fourteen (14) items:

36. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
37. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
38. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
39. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
40. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
41. The applicant shall not utilize public row to satisfy code requirement unless approved by the City Traffic Engineer
42. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
43. All parking ramps as the approach the public Right-of-Way shall not have a slope to exceed 5% for 20 feet; this is to ensure drivers have adequate vision of the Right-of-Way. If applicant believes public safety can be maintained they shall apply for a waiver, approval or denial of the waiver shall be the determination of the City Traffic Engineer.
44. Parking deck is insufficiently labeled/dimensioned for a proper review. If the parking does not meet MGO 10.08 the applicant can expect to be required to make major alteration which may or may not impact structural elements of this site.
45. City of Madison radio systems are microwave directional line of sight to remote towers citywide. The building elevation will need to be reviewed by Traffic Engineering to accommodate the microwave sight and building. The applicant shall submit grade and elevations plans if the building exceeds four stories prior to sign-off to be reviewed and approved by Austin Scheib, (266-4766) Traffic Engineering Shop, 1120 Sayle Street. The applicant shall return one signed approved building elevation copy to the City of Madison Traffic Engineering office with final plans for sign off.
46. The driveway slope to the underground parking is not identified in the plan set, Traffic Engineering recommends driveway slope under 10%; if the slope is to exceed 10%, the applicant

shall demonstrate inclement weather mitigation techniques to provide safe ingress/egress to be approved by the City Traffic Engineer.

47. "Stop" signs shall be installed at a height of seven (7) feet at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
48. All existing driveway approaches on which are to be abandoned shall be removed and replaced with curb and gutter and noted on the plan.
49. Covered parking is not dimensioned and as such not reviewable at this time. The applicant should be aware this may lead to major site changes once the dimensions are provided.

Please contact Bill Sullivan of the Fire Department, at 261-9658 if you have any questions regarding the following one (1) item:

50. Please consider allowing Madison Fire Dept. to conduct training sequences prior to demolition. Contact MFD Training Division to discuss possibilities: Division Chief Tracy Burrus at tburrus@cityofmadison.com or (608)266- 5959

Please contact Sarah Lerner of the Parks Division, at 261-4281 if you have any questions regarding the following three (3) items:

51. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the North Park - Infrastructure Impact Fee district. Please reference ID# 19019 when contacting Parks about this project.
52. The following note should be included on the CSM: "LOTS WITHIN THIS CSM ARE SUBJECT TO IMPACT FEES THAT ARE DUE AND PAYABLE AT THE TIME BUILDING PERMIT(S) ARE ISSUED."
53. Parks Division will be required to sign off on this CSM

Please contact Brad Hofmann of the Forestry Division, at 267-4908 if you have any questions regarding the following two (2) items:

54. An existing inventory of trees (location, species, & DBH) and any tree removal plans (in PDF format) shall be submitted to the plans and Brad Hofmann – bhofmann@cityofmadison.com or 266-4816. All proposed street tree removals within the right of way shall be reviewed by City Forestry. Approval and permitting of street tree removals shall be obtained from the City Forester and/or the Board of Public Works prior to the approval of the site plan.
55. Existing street trees shall be protected. Please include the following note on the site plan: Contractor shall install tree protection fencing in the area between the curb and sidewalk and extend it at least 5 feet from both sides of the tree along the length of the terrace. No excavation is permitted within 5 feet of the outside edge of a tree trunk. If excavation within 5 feet of any tree is

necessary, contractor shall contact City Forestry (266- 4816) prior to excavation to assess the impact to the tree and root system. Tree pruning shall be coordinated with City Forestry prior to the start of construction. Tree protection specifications can be found in section 107.13 of City of Madison Standard Specifications for Public Works Construction - <http://www.cityofmadison.com/business/pw/documents/StdSpecs/2018/Part1.pdf>. Any tree removals that are required for construction after the development plan is approved will require at least a 72 hour wait period before a tree removal permit can be issued by Forestry, to notify the Alder of the change in the tree plan.


Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your conditional use:

1. Please revise your plans per the above conditions and submit **nine (9) copies** of a complete, fully dimensioned and scaled plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off. The final site plan shall be accompanied by the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, **215 Martin Luther King, Jr. Blvd.** This submittal shall all also include one complete digital plan set in PDF format. The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
3. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.
4. The conditional use approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
6. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 243-0455.

Sincerely,



Colin Punt
Planner

I hereby acknowledge that I understand and will comply with the above conditions of approval for demolition permit and conditional use.

Signature of Applicant

Signature of Property Owner (if not the applicant)

cc: Jenny Kirchgatter, Asst. Zoning Administrator
Sean Malloy, Traffic Engineering
Tim Troester, Engineering Division
Jeffrey Quamme, Engineering Division – Mapping
Bill Sullivan, Fire Department
Sarah Lerner, Parks Division
Brad Hofmann, Forestry Division
Bryan Johnson, Streets Division

LNDUSE-2019-00020			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Punt)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Water Utility
<input type="checkbox"/>	Metro Transit	<input type="checkbox"/>	Other: