



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

www.cityofmadison.com

May 24, 2019

Steve Harms
Tri-North Builders
2625 Research Park Drive
Fitchburg, WI 53711

RE: Legistar #[55029](#) & [54674](#) | Accela ID: 'LNDUSE-2019-00013' -- A Proposal involving three requests: 1) Approval of the demolition of the two 2-story office buildings located along the western property line; 2) Approval to rezone the parcel at 330 S. Whitney Way and 5402 Mineral Point Road from the Suburban Employment (SE) District to the Commercial Corridor - Transitional (CC-T) District; and 3) Three conditional use approvals – a) for a multi-family dwelling with eight (8) or more units in the CC-T District; b) for a multi-tenant building exceeding 40,000 square feet of floor area in the CC-T District; and c) for development adjacent to a park (Garner Park) – all in order to construct a three-story, 48-unit apartment building with 48 under-building automobile parking stalls at **330 S. Whitney Way and 5402 Mineral Point Road.**

Dear Mr. Harms;

At its May 6, 2019 meeting, the Plan Commission found the standards met and **conditionally approved** your client's requests for a demolition permit and conditional uses for 330 S. Whitney Way and 5402 Mineral Point Road. At its May 21, 2019 meeting, the Common Council **approved** the rezoning of the Mineral Point parcel to CC-T (Commercial Corridor-Transitional District). Prior to issuance of demolition or building permits for the project, the conditions of approval in the following sections shall be satisfied:

Please contact Timothy Troester of the City Engineering Division – Main Office at (608) 267-1995 if you have any questions regarding the following fourteen (14) items:

1. Prior to approval, the owner or owner's representative shall obtain a permit to plug each existing sanitary sewer lateral that serves a building which is proposed for demolition. For each lateral to be plugged the owner shall complete a sewer lateral plugging application and pay the applicable permit fees. The permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
2. All outstanding Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
3. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)

4. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in a TMDL ZONE. The project will be expected to meet a higher standard of erosion control than the minimum standards set by the WDNR in order to comply with TMDL limits.
5. The Applicant shall submit, prior to plan sign-off but after all revisions have been completed, a digital CAD file (single file) to the Engineering Division with any private storm and sanitary sewer utilities. The digital CAD file shall be to scale and represent final construction. The CAD file shall be in a designated coordinate system (preferably Dane County WISCRS, US Ft). The single CAD file submittal can be either AutoCAD (dwg) Version 2013 or older, MicroStation (dgn) V8i Select Series 3 or older, or Universal (dxf) format and shall contain the only the following data, each on a separate layer name/level number:
 - a) Building Footprints
 - b) Internal Walkway Areas
 - c) Internal Site Parking Areas
 - d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
 - e) Right-of-Way lines (public and private)
 - f) Lot lines or parcel lines if unplatted
 - g) Lot numbers or the words unplatted
 - h) Lot/Plat dimensions
 - i) Street names
 - j) Private on-site sanitary sewer utilities (including all connections to public sanitary)
 - k) Private on-site storm sewer utilities (including all connections to public storm)

All other levels (contours, elevations, etc) are not to be included with this file submittal.

NOTE: Email CAD file transmissions are preferred to: bstanley@cityofmadison.com (East) or troester@cityofmadison.com (West). Include the site address in the subject line of this transmittal. Any changes or additions to the location of the building, sidewalks, parking/pavement, private on-site sanitary sewer utilities, or private on-site storm sewer utilities during construction will require a new CAD file.

6. The applicant shall submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: bstanley@cityofmadison.com (East) or troester@cityofmadison.com (West). The digital copies shall be to scale, and shall have a scale bar on the plan set. (POLICY and MGO 37.09(2))PDF submittals shall contain the following information:
 - a) Building Footprints
 - b) Internal Walkway Areas
 - c) Internal Site Parking Areas
 - d) Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)
 - e) Right-of-Way lines (public and private)
 - f) Lot lines or parcel lines if unplatted
 - g) Lot numbers or the words unplatted
 - h) Lot/Plat dimensions
 - i) Street names
 - j) Stormwater Management Facilities
 - k) Detail drawings associated with Stormwater Management Facilities (including if applicable planting plans).

7. The Applicant shall submit prior to plan sign-off, electronic copies of any Stormwater Management Files including:
 - a) SLAMM DAT files
 - b) RECARGA files
 - c) TR-55/HYDROCAD/Etc
 - d) Sediment loading calculations. If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided. (POLICY and MGO 37.09(2))
8. Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project. Include copies of all stormwater, utility, and detail plan sheets that contain stormwater practices on 8.5x14 size paper in the draft document. These drawings do not need to be to scale as they are for informational purposes only. Once City Engineering staff have reviewed the draft document and approved it with any required revisions submit a signed and notarized original copy to City Engineering. Include a check for \$30.00 made out to Dane County Register of Deeds for the recording fee. City Engineering will forward the document and fee for recording at the time of issuance of the stormwater management permit. Draft document can be emailed to Tim Troester (west) at ttroester@cityofmadison.com, or Daniel Olivares at DAOlivares@cityofmadison.com final document and fee should be submitted to City
9. Provide additional detail how the enclosed depression(s) created by the parking entrance(s) to the below building parking area(s) is/are served for drainage purposes. The building must be protected from receiving runoff up through the 24-hr, 100-yr design storm. If the enclosed depression(s) is/are to be served by a gravity system provide calculations stamped by a Wisconsin P.E. that show inlet and pipe capacities meet this requirement. If the enclosed depression(s) is/are to be served by a pump system provide pump sizing calculations stamped by a Wisconsin P.E. or licensed Plumber that show this requirement has been met.
10. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year.
11. For Commercial sites < 1 acre in disturbance the City of Madison is an approved agent of the Department of Commerce and WDNR. As this project is on a site with disturbance area less than one (1) acres, and contains a commercial building, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required. (NOTIFICATION)
12. The lots within this site plan are inter-dependent upon one another for stormwater runoff conveyance, and/or a private drainage system exists for the entire site an agreement shall be provided for the rights and responsibilities of all lot owners. Said agreement shall be reviewed and placed on file by the City Engineer, referenced on the site plan and recorded at the Dane Co Register of Deeds. (POLICY)

13. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to Reduce TSS by 80% off of the proposed development when compared with the existing site.
14. The Applicant's project requires the minor restoration of the street and sidewalk. The Applicant shall obtain a Street Excavation Permit for the street restoration work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. (MGO 16.23(9)(d)(6) This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.

Please contact Jeff Quamme of the City Engineering–Mapping Section at (608) 266-4097 if you have any questions regarding the following eight (8) items:

15. The public water main is shown to have portions outside of the easement of record. Consultant shall contact David Renaud of the Madison Water Utility to coordinate confirmation of the location of the watermain and to coordinate any easement amendments required to Doc No. 1397139 to assure all public water improvements are within the recorded easement and to provide consent of the proposed private improvements within the final amended easement.
16. Provide for review, a comprehensive reciprocal easements and agreements including, but not limited to, common access, parking, utilities (private storm sewer, sanitary sewer and water services, common areas, storm water drainage / management that are necessary to accomplish the land division and site development as proposed prior to final sign off. The document(s) shall be executed and recorded immediately subsequent to the pending CSM recording and prior to building permit issuance.
17. The pending Certified Survey Map application for this property shall be completed and recorded with the Dane County Register of Deeds (ROD) prior to issuance of any building permits for new construction. When the recorded CSM image is available from the ROD, the Assessor's Office can then create the new Address-Parcel-Owner (APO) data in GEO so that the Accela system can upload this data and permit issuance made available for this new land record
18. The current Whitney Point Condominium shall be terminated & removal documents recorded prior to CSM and prior to issuance of any building permits for new construction.
19. The address of the new apartment building is 5414 Mineral Point Rd.
20. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
21. Update all sheets to show the full official street name (S Whitney Way).

22. Submit a Floor Plan in PDF format to Lori Zenchenko (lzenchenko@cityofmadison.com) that includes a floor plan for each floor on a separate sheet for the development of a complete interior addressing plan. The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) prior to the application submittal for the final Site Plan Approval with Zoning. The approved Addressing Plan shall be included in the final application. For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved. The final revised Addressing Plan shall be submitted by the applicant to Zoning to be attached to the final filed approved site plans.

Please contact Sean Malloy, Traffic Engineering, at (608) 266-5987 if you have questions regarding the following fourteen (14) items:

23. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
24. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
25. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
26. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
27. The applicant(s) shall maintain a 5 foot wide, Americans with Disabilities Act (ADA) compliant, pedestrian walkway for the duration of the project on all street frontages classified as a collector or higher. The applicant shall also maintain a 5 foot wide bicycle lane for the duration of the project on all street frontages with existing bicycle facilities. Exceptions to this requirement may be granted by Traffic Engineering on a limited term basis if and when the applicant can show a public safety concern and they also provide a clear date when the pedestrian/bicycle facilities are to be restored. All closures shall be designed by the applicant, in accordance with the Manual on Uniform Traffic Control Devices (MUTCD), to be submitted and approved by Traffic Engineering.
28. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.

29. All pedestrian walkways adjacent parking stalls shall be 7 feet wide to accommodate vehicle overhang, signage and impediments to walkway movements. Any request for variance shall be submitted to and reviewed by City Traffic Engineering.
30. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
31. The applicant shall provide a clearly defined 5' walkway clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
32. The driveway slope to the underground parking is not identified in the plan set, Traffic Engineering recommends driveway slope under 10%; if the slope is to exceed 10%, the applicant shall demonstrate inclement weather mitigation techniques to provide safe ingress/egress to be approved by the City Traffic Engineer.
33. Parking stalls that are located next to a sidewalk shall have a barrier between the stall and the sidewalk or a 3' minimum buffer to serve as protection for any pedestrians.
34. "Stop" signs shall be installed at a height of seven (7) feet at all class III driveway approaches, including existing driveways, behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
35. The applicant shall provide an executed copy of a cross-access agreement between lots 1 and 2.
36. All future development projects on lots 1 and 2 shall maintain circulation through the site between the existing driveways.

Please contact Jenny Kirchgatter of the Zoning Division at (608) 266-4429 if you have any questions regarding the following fourteen (14) items:

37. Work with Zoning and Planning staff to enhance the building entrance orientation. Per Section 28.060(2)(a), all new buildings shall have a functional entrance oriented to an abutting public street. Additional entrances may be oriented to a private street or parking area. Entries shall be clearly visible and identifiable from the street, and delineated with elements such as roof overhangs, recessed entries, landscaping, or similar design features. Barrier-free entrances are encouraged.
38. Section 28.185(7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson (608-266-4682).
39. Section 28.185(10) Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition.
40. Section 28.185(9)(a) A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.

41. The civil plans and landscape plan shall consistently show all site features, including paved areas, sidewalks, patios, bike parking areas, and unpaved lawn and landscaped areas.
42. Clearly show the useable open space areas on the final plans. In addition to showing structured useable open space at roof decks, porches, and balconies, identify each qualifying at-grade usable open space area on the final plans. Roof decks, porches, and balconies may be used to meet up to seventy-five percent (75%) of the minimum open space requirement, provided that minimum dimensional requirements are satisfied. Qualifying usable open space at ground level shall be in a compact area of not less than two hundred (200) square feet, with no dimension less than eight (8) feet and no slope grade greater than ten percent (10%).
43. Provide a vehicle and bicycle parking summary on the title page or site plan including the numbers of surface and underground vehicle and bicycle stalls.
44. Parking requirements for persons with disabilities must comply with Section 28.141(4)(e). Final plans shall show the existing accessible stalls at 340 S Whitney Way as well as the proposed accessible stalls with the dimensions. An accessible stall is a minimum of 8 feet wide with a 5 foot wide access aisle. A van accessible stall is a minimum of 8 feet wide with an 8 foot wide striped access aisle. The access aisles may not be obstructed by building columns or bike racks. Show the dimensions of the accessible stalls and access aisles and the required signage at the head of the stalls.
45. Bicycle parking shall comply with City of Madison General Ordinances Sections 28.141(4)(g) Table 28I-3 and 28.141(11) and shall be designated as short-term or long-term bicycle parking. A minimum of 48 resident bicycle stalls are required plus a minimum of 5 short-term guest stalls. A minimum of 90% of the resident stalls (43 stalls) shall be designed as long-term parking. Up to twenty-five percent (25%) of bicycle parking may be structured parking, vertical parking or wall mount parking, provided there is a five (5) foot access aisle for wall mount parking. NOTE: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area. Submit a detail showing the model of bike rack to be installed.
46. Submit a detail of the trash enclosure. The trash enclosure shall be screened on four (4) sides (including a gate for access) by a solid, commercial-grade wood fence, wall, or equivalent material with a minimum height of six (6) feet and not greater than eight (8) feet.
47. Provide details showing that the primary street façade meets the door and window opening requirements of Section 28.060(2)(d). For residential uses at ground level, a minimum of fifteen percent (15%) of the ground level of residential facades or side and rear facades not fronting a public street shall consist of windows and door openings. On upper stories, window or balcony openings shall occupy a minimum of fifteen percent (15%) of the upper-story wall area.
48. Exterior lighting provided shall be in accordance with City of Madison General Ordinances Section 10.085. Provide an exterior lighting plan and fixture cut sheets with the final plan submittal.
49. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.

50. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

Please contact Bill Sullivan of the Madison Fire Department at 261-9658 if you have any questions regarding the following two (2) items:

51. Per the architectural plans, the building will be protected with an NFPA 13 sprinkler system, smoke detection will be provided in the common corridors, and roof access will be provided from both exit stair enclosures. These features plus the aerial access proposed along the north drive of the site will be an acceptable equivalency to the required aerial access to 25% of the building perimeter.

52. Please consider allowing Madison Fire Dept. to conduct training sequences prior to demolition. Contact MFD Training Division to discuss possibilities: Division Chief Tracy Burrus at tburrus@cityofmadison.com or (608) 266-5959.

Please contact Sarah Lerner of the Parks Division at (608) 261-4281 if you have questions regarding the following three (3) items:

53. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the North Park –Infrastructure Impact Fee district. Please reference ID# 19018 when contacting Parks about this project.

54. The following note should be included on the CSM: "LOTS WITHIN THIS SUBDIVISION ARE SUBJECT TO IMPACT FEES THAT ARE DUE AND PAYABLE AT THE TIME BUILDING PERMIT(S) ARE ISSUED."

55. Parks Division will be required to sign off on this CSM.

Please contact Brad Hofmann of the Forestry Division at (608) 267-4908 if you have questions regarding the following five (5) items:

56. Existing street trees shall be protected. Please include the following note on the site plan: Contractor shall install tree protection fencing in the area between the curb and sidewalk and extend it at least 5 feet from both sides of the tree along the length of the terrace. No excavation is permitted within 5 feet of the outside edge of a tree trunk. If excavation within 5 feet of any tree is necessary, contractor shall contact City Forestry (266-4816) prior to excavation to assess the impact to the tree and root system. Tree pruning shall be coordinated with City Forestry prior to the start of construction. Tree protection specifications can be found in section 107.13 of City of Madison Standard Specifications for Public Works Construction - <http://www.cityofmadison.com/business/pw/documents/StdSpecs/2018/Part1.pdf>. Any tree removals that are required for construction after the development plan is approved will require at least a 72-hour wait period before a tree removal permit can be issued by Forestry, to notify the Alder of the change in the tree plan.

57. City Forestry will issue a removal permit for a 20" Honeylocust tree (5th tree on Mineral Point Road) due to driveway installation. Please contact Brad Hofmann – bhofmann@cityofmadison.com or 266-4816 to obtain the street tree removal permit.
58. Contractor shall contact City Forestry Brad Hofmann bhofmann@cityofmadison.com or 266-4816 at least one week prior to planting to schedule inspecting the nursery stock and review planting specifications with the landscaper.
59. An existing inventory of trees (location, species, & DBH) and any tree removal plans (in PDF format) shall be submitted to the plans and Brad Hofmann – bhofmann@cityofmadison.com or 266-4816. All proposed street tree removals within the right of way shall be reviewed by City Forestry. Approval and permitting of street tree removals shall be obtained from the City Forester and/or the Board of Public Works prior to the approval of the site plan.
60. Additional street trees are needed for this project. All street tree planting locations and trees species within the right of way shall be determined by City Forestry. Please submit a site plan (in PDF format) to Brad Hofmann – bhofmann@cityofmadison.com or 266-4816. Tree planting specifications can be found in Section 209 of City of Madison Standard Specifications for Public Works Construction.

Please contact Adam Wiederhoeft of the Madison Water Utility at 266-9121 if you have any questions regarding the following two (2) items:

61. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.
62. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumberscontractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

Please contact Tim Sobota, Metro Transit, at (608) 261-4289 if you have any questions regarding the following three (3) items:

63. In coordination with any public works improvements, the applicant shall maintain or replace the concrete terrace at the existing Metro bus stop on the north side of Mineral Point Road, west of Whitney Way (#2160).
64. The applicant shall include the location of these transit amenities on the final documents filed with their permit application so that Metro Transit may review the design.

65. Metro Transit operates daily service along Whitney Way and Mineral Point Road at this intersection. Bus stop ID #2160 is adjacent the proposed project site along the north side of Mineral Point Road, with the bus stop zone encompassing the area from the existing bus stop sign pole east through to the Whitney Way intersection. Trips operate at least once every 30 minutes along Whitney Way, at alternate stops in the Mineral Point Road intersection, on a daily basis.

Please contact my office at (608) 261-9632 if you have any questions regarding the following item:

66. No HVAC “wall-pack” penetrations/louvers are shown on the street-facing facades. Any HVAC penetrations in the building shall be perpendicular to the main facade, and provided within the recessed balcony spaces. Unless specifically approved by the Plan Commission, the addition of wall packs on outward-facing walls is not included in this approval and will require approval of an alteration to this conditional use should they be proposed at a later time.

No interior, exterior or structural demolition or wrecking activities or remodeling activities (including material reclamation activities by the applicant or a third party) shall commence nor any wrecking or building permits be issued until the applicant has met all of the conditions of approval stated in this letter.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining permits for your project:

1. After the plans have been revised per the above conditions, please file **ten (10) sets** of complete, fully dimensioned, and to-scale plans, the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, Suite 017 (Lower Level), Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard. **This submittal shall all also include one (1) complete digital plan set in PDF format.** The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. This letter shall be signed by the applicant and property owner (if not the applicant) to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval. [Signature block on last page]
3. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.
4. As stated in Section 28.185(7)(a)5, if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson (608-266-4682).

5. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition. (Section 28.185(10))
6. The conditional use approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
7. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator, following consideration by the alderperson of the district, may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
8. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.

If you have any questions regarding obtaining your building permits, please contact the Zoning Administrator at (608) 266-4551. If you have any questions or if you may be of any further assistance, please do not hesitate to contact my office at (608) 261-9135.

Sincerely,



Chris Wells
 Planner

I hereby acknowledge that I understand and will comply with the above conditions of approval for demolition permit and conditional use.

Signature of Applicant

Signature of Property Owner (If Not Applicant)

- cc: Timothy Troester, City Engineering Division–Main Office
 John Sapp, City Engineering Division–Main Office
 Jeff Quamme, City Engineering Division–Mapping
 Sean Malloy, Traffic Engineering
 Bill Sullivan, Madison Fire Department
 Jenny Kirchgatter, Zoning Division
 Sarah Lerner, Parks Division
 Adam Wiederhoeft, Madison Water Utility
 Tim Sobota, Metro Transit
 Bryan Johnson, Recycling Coordinator

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Wells)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Cmsn.
<input checked="" type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Metro Transit
<input type="checkbox"/>	Water Utility	<input checked="" type="checkbox"/>	Forestry