



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

215 Martin Luther King Jr. Boulevard

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

Fax (608) 267-8739

www.cityofmadison.com

August 14, 2019

Eric Welch
1341 Spaight Street, #1
Madison, Wisconsin 53703

RE: Legistar #56396; Accela ID: 'LNDUSE-2019-00071' -- Approval of a conditional use for a reception hall in the Traditional Employment (TE) District at 828 E. Main Street.

Dear Mr. Welch:

At its August 12, 2019 meeting, the Plan Commission, meeting in regular session, found the standards met and **approved** your conditional use request use for a reception hall in the Traditional Employment (TE) District at **828 E. Main Street**, subject to the conditions below. In order to receive final approval of the conditional use, and for any permits to be issued for your project, the following conditions shall be met:

Please contact Brenda Stanley of the City Engineering Division–Main Office at (608) 261-9127 if you have questions regarding the following four (4) items:

1. All outstanding Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
2. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
3. Based on historical Sanborn maps, this property was formerly an oil warehouse and may contain residual contaminated soil. If contaminated soil is encountered as part of this redevelopment, all WDNR and DSPS regulations must be followed for proper handling and disposal.
4. The Applicant's project requires the minor restoration of the street and sidewalk. The Applicant shall obtain a Street Excavation Permit for the street restoration work, which is available from the City Engineering Division. The applicant shall pay all fees associated with the permit including inspection fees. (MGO 16.23(9)(d)(6)) This permit application is available on line at <http://www.cityofmadison.com/engineering/permits.cfm>.

Please contact Lori Zenchenko of the City Engineering Division–Mapping Section, at (608) 266-5952 if you have questions regarding the following item:

5. Only one address is needed for the remodel. The 832 E Main St address has been inactivated/retired. The parcel situs has been updated to 828 E Main St. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.

Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following nine (9) items:

6. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be scaled to 1" = 20' and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
7. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
8. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
9. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
10. The applicant shall show the dimensions for the proposed class III driveway including the width of the drive entrance, width of the flares, and width of the curb cut.
11. All existing driveway approaches on which are to be abandoned shall be removed and replaced with curb and gutter and noted on the plan.
12. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
13. Items in the Right-of-Way are not approvable through the site plan approval process. Make a note on all pages showing improvements in the ROW that states: The Right-of-Way is the sole jurisdiction of the City of Madison and is subject to change at anytime per the recommendation/plan of Traffic Engineering and City Engineering Depts.
14. The applicant shall work with Traffic Engineering and Parking Utility to explore the possibility of on-site ADA parking.

Please contact Jenny Kirchgatter, Assistant Zoning Administrator, at (608) 266-4429 if you have any questions regarding the following seven (7) items:

15. Bicycle parking for the proposed reception hall shall comply with the requirements of Sections 28.141(4)(g) and 28.141(11). A minimum amount of bicycle parking equal to 5% of the capacity of persons (31 stalls) is required. The applicant proposes to provide 18 bicycle stalls. A bicycle parking reduction will be required per Section 28.141(5). Submit a request for a bicycle parking reduction with the final plan submittal including information to support the argument for reducing the required number of spaces.
16. Provide a calculation and plan detail for lot coverage with the final submittal. The lot coverage maximum is 85%. Lot coverage is defined as the total area of all buildings, measured at grade, all accessory structures including patios, etc., and all paved areas as a percentage of the total area of the lot, with the following exceptions: sidewalks or paved paths no wider than five (5) feet, pervious pavement, green roofs and decks. If the existing site currently exceeds 85% maximum lot coverage, proposed site improvements may not further increase lot coverage above the maximum.
17. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.
18. Submit a detail of the trash enclosure. The trash enclosure shall be screened on four (4) sides (including a gate for access) by a solid, commercial-grade wood fence, wall, or equivalent material with a minimum height of six (6) feet and not greater than eight (8) feet.
19. Exterior lighting is not required. However, if it is provided, it must comply with City of Madison General Ordinances Section 10.085 outdoor lighting standards. If exterior site lighting is provided, submit an exterior lighting plan and fixture cut sheets with the final plan submittal.
20. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.
21. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances and Chapter 33 Urban Design District ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

Please contact Bill Sullivan of the Fire Department at (608) 261-9658 if you have any questions regarding the following item:

22. The Madison Fire Department does not object to this proposal provided the project complies with all applicable fire codes and ordinances. With the proposed change of use to an assembly occupancy, fire sprinkler and fire alarm systems shall be provided in accordance with the IBC & the IFC.

Please contact Brad Hofmann of the Forestry Division at (608) 267-4908 if you have questions regarding the following item:

23. Additional street trees are needed for this project. All street tree planting locations and trees species within the right of way shall be determined by City Forestry. Please submit a site plan (in PDF format) to Brad Hofmann – bhofmann@cityofmadison.com or (608) 266-4816. Tree planting specifications can be found in section 209 of City of Madison Standard Specifications for Public Works Construction.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your conditional use:

1. Please revise your plans per the above conditions and submit **eight (8) copies** of a complete, fully dimensioned and scaled plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off. The final site plan shall be accompanied by the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, 215 Martin Luther King Jr. Boulevard. **This submittal shall all also include one complete digital plan set in PDF format.** The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval.
2. This property is not in a wellhead protection district. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility.
3. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
4. The approval is valid for one (1) year from the date of the Plan Commission approval. During this time, the applicant must either lawfully commence the use or obtain a building permit and begin erecting the building. If the applicant obtains a valid building permit, construction must commence within six (6) months of the date of issuance. The building permit shall not be renewed unless construction has commenced as is being diligently prosecuted.
5. Any alteration in plans for a proposed alternative use shall require Plan Commission approval, except for minor alterations. The Zoning Administrator may issue permits for minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the City Plan Commission and the conditional use approval standards.
6. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at (608) 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at (608) 261-9135.

Sincerely,



Chris Wells
Planner

cc: Brenda Stanley, Engineering
Lori Zenchenko, Engineering Mapping
Sean Malloy, Traffic Engineering
Jenny Kirchgatter, Zoning
Bill Sullivan, Fire Department
Brad Hofmann, Forestry

I hereby acknowledge that I understand and will comply with the above conditions of approval for the conditional use permit.

Signature of Applicant

Signature of Property Owner (if not the applicant)

For Official Use Only, Re: Final Plan Routing

<input checked="" type="checkbox"/>	Planning Div. (Wells)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Metro Transit
<input checked="" type="checkbox"/>	Forestry	<input type="checkbox"/>	