



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017

215 Martin Luther King, Jr. Blvd

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

www.cityofmadison.com

September 17, 2019

Jeffrey & Amy Steuer
5512 Ethelwyn Road
Madison, Wisconsin 53713

RE: Approval of a demolition permit to demolish a single-family residence at 2711 Waunona Way and construct a new single-family residence. [ID 57105; LNDUSE-2019-00093]

Dear Mr. & Mrs. Steuer;

At its September 16, 2019 meeting, the Plan Commission found the standards met and **approved** your demolition permit for 2711 Waunona Way. The conditions of approval in the following sections shall be satisfied prior to issuance of demolition or building permits for the project.

Please contact Tim Troester of the City Engineering Division at 261-9127 if you have questions regarding the following five (5) items:

1. Obtain a Street Terrace permit for any proposed work (installation of the driveway apron, landscaping, etc.) in the right of way.
2. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development.
3. Revise plan to show the location of all rain gutter down spout discharge locations.
4. Revise plan set to show more information on proposed drainage for the site. Use either spot elevations and drainage arrows or proposed contours to show the required drainage information. It is necessary to show the location of drainage leaving the site to the public right-of-way. It may be necessary to provide information off the site to fully meet this requirement.
5. Submit, prior to plan sign-off but after all revisions have been completed, a digital CAD file (single file) to the Engineering Division that is to scale and represents final construction with any private storm and sanitary sewer utilities.

Please contact Adam Wiederhoeft of the Madison Water Utility at 266-9121 if you have any questions regarding the following two (2) items:

6. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.
7. A private well may have served this parcel prior to the municipal water service connection. Any remaining unused/unpermitted private wells existing on this parcel must be properly abandoned according to Wisconsin Administrative Code NR-812 and Madison General Ordinance Section 13.21 prior to the demolition of the property. Please contact Water Utility staff at 266-4654 to schedule an on-site private well survey prior to demolition, otherwise for additional information regarding well abandonment procedures and potential well abandonment reimbursement programs.

Please contact Bill Sullivan of the Madison Fire Department at 261-9658 if you have any questions regarding the following item:

8. Madison Fire Department recommends the installation of a residential fire sprinkler system in accordance with NFPA 13D. Additional information is available online at the Home Fire Sprinkler Coalition website.

Please contact Jenny Kirchgatter, Assistant Zoning Administrator, 266-4429 if you have any questions regarding the following two (2) items:

9. Section 28.185(7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until a reuse and recycling plan is approved by the Recycling Coordinator. Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185 (7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition. Per Section 28.185(9)(a), a demolition or removal permit is valid for one (1) year from the date of the Plan Commission.
10. Show the roof eaves on the plans in relation to the setbacks with the amount of encroachment into the setback areas. Roof eaves and gutters are allowed to project a maximum of three (3) feet into the front and rear yard setbacks and two (2) feet into the side yard setbacks.

Please contact my office at 261-9632 if you have questions about the following item:

11. Approval of the proposed demolition permit should not be considered an endorsement of any potential division of the subject parcel. A Certified Survey Map (CSM) to divide the subject parcel in the manner suggested on Sheet SP.1 shall be submitted for review and approval with a completed Subdivision Application. If a CSM to divide the property has not been submitted, approved and recorded prior to the issuance of demolition and building permits for the residence, the lot line shall be removed from the final zoning plans for the demolition and new construction.

No interior, exterior or structural demolition or wrecking activities or remodeling activities (including material reclamation activities by the applicant or a third party) shall commence nor any wrecking or building permits be issued until the applicant has met all of the conditions of approval stated in this letter.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining permits for your project:

1. Please revise your plans per the above conditions and submit **six (6) copies** of complete, fully dimensioned, and to-scale plans, the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator, Suite 017, Madison Municipal Building, 215 Martin Luther King, Jr. Boulevard. **This submittal shall all also include one (1) complete digital plan set in PDF format.** The sets of final revised plans or documents will be circulated by the Zoning staff to the City department staff listed above for their final approval.
2. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission. Where the plans have not been altered since issuance of the demolition or removal permit and the permit has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date.

If you have any questions regarding obtaining your building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at 261-9632.

Sincerely,

Timothy M. Parks
Planner

LNDUSE-2019-00093			
For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (T. Parks)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Landmarks Commission
<input type="checkbox"/>	Traffic Engineering (EP)	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Other:
<input checked="" type="checkbox"/>	Water Utility (EP)	<input type="checkbox"/>	Other:

cc: Tim Troester, City Engineering Division
Jeff Quamme, City Engineering Division—Mapping Section
Bill Sullivan, Madison Fire Department
Jenny Kirchgatter, Assistant Zoning Administrator
Adam Wiederhoeft, Madison Water Utility