



Department of Planning & Community & Economic Development

## Planning Division

Heather Stouder, Director

---

Madison Municipal Building, Suite 017  
215 Martin Luther King Jr. Boulevard  
Madison, Wisconsin 53703  
Phone: (608) 266-4635  
[www.cityofmadison.com](http://www.cityofmadison.com)

**\*\*BY E-MAIL ONLY\*\***

September 10, 2020

Kevin Burow  
Knothe & Bruce Architects  
7601 University Avenue  
Middleton, WI 53562

RE: Consideration of a demolition permit to allow demolition of a one-story commercial building and consideration of a conditional use - for dwelling units in a mixed-use building – all to allow construction of a four-story, mixed-use building with 1,240 square-feet of commercial space and 66 residential units at 133 E Lakeside Street. (LNDUSE-2020-00056; ID 60480)

Dear Mr. Burow;

At its August 10, 2020 meeting, the Plan Commission found the standards met and **conditionally approved** the demolition permit and conditional use for 133 E Lakeside Street. (Note: The zoning map amendment request which was included in the original application – to rezone the property from the SE to the TE District - was Placed on File without Prejudice by the Common Council on September 1, 2020). The conditions of approval in the following sections shall be satisfied prior to issuance of demolition or building permits for the project.

**Please contact Brenda Stanley of the City Engineering Division at 267-9127 if you have questions regarding the following nineteen (19) items:**

1. Proposed sanitary sewer lateral connection requires a manhole (8" lateral proposed). Applicant shall revise plans to connect lateral to either existing sanitary manhole or a proposed manholes if there is no existing manholes in close proximity to the location of the lateral connection.
2. Applicant shall provide projected wastewater flow calculations for the proposed development. Offsite sewer improvements may be necessary to serve the proposed development.
3. This site drains to an enclosed depression that drains to Wingra Creek - the applicant shall either protect the building to a flood elevation of 852 including entrances to underground parking or shall submit a flood analysis to City Engineering for review and approval that documents protection of the building to the 100 year storm event.

4. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to submit a Storm Water Management Permit application, associated permit fee, Stormwater Management Plan, and Storm Water Management Report to City Engineering. The Stormwater Management Permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

The Storm Water Management Plan & Report shall include compliance with the following:

Report: Submit prior to plan sign-off, a stormwater management report stamped by a P.E. registered in the State of Wisconsin.

Electronic Data Files: Provide electronic copies of any stormwater management modeling or data files including SLAMM, RECARGA, TR-55, HYDROCAD, Sediment loading calculations, or any other electronic modeling or data files. If calculations are done by hand or are not available electronically, the hand copies or printed output shall be scanned to a PDF file and provided to City Engineering. (POLICY and MGO 37.09(2))

TSS Redevelopment with TMDL: Reduce TSS by 80% off of the proposed development when compared with the existing site.

Oil/Grease Control: Treat the first 1/2 inch of runoff over the proposed parking facility and/or drive up window.

Submit a draft Stormwater Management Maintenance Agreement (SWMA) for review and approval that covers inspection and maintenance requirements for any BMP used to meet stormwater management requirements on this project.

5. Enter into a City / Developer agreement for the required infrastructure improvements. Agreement to be executed prior to sign off. Allow 4-6 weeks to obtain agreement. Contact City Engineering to schedule the development and approval of the plans and the agreement. (MGO 16.23(9)c)
6. Construct sidewalk on Lakeside St and Sayle St to a plan and profile as approved by City Engineer.
7. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
8. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm> (MGO CH 35.02(14))

9. This project appears to require permanent dewatering. A permit to connect to the public stormwater system shall be required from City Engineering. Additionally, a permit for non-storm discharge to the storm sewer system from the City/County Health Department shall also be required. If contaminated soil or groundwater conditions exist on or adjacent to this project additional WDNR, Public Health, and/or City Engineering approvals may be required prior to issuance of the connection and non-storm discharge permits.
10. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.
11. This site appears to disturb over one (1) acre of land and requires a permit from the WDNR for stormwater management and erosion control. The City of Madison has been required by the WDNR to review projects for compliance with NR216 and NR-151 however a separate permit submittal is still required to the WDNR for this work. The City of Madison cannot issue our permit until concurrence is obtained from the WDNR via their NOI or WRAPP permit process. Contact Eric Rortvedt at 273-5612 of the WDNR to discuss this requirement. Information on this permit application is available on line: <http://dnr.wi.gov/Runoff/stormwater/constformsinfo.htm>.

The applicant is notified that the City of Madison is an approved agent of the Department of Safety and Professional Services (DSPS) and no separate submittal to this agency or CARPC is required for this project to proceed.

12. Revise the site plan to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)
13. Revise the plans to show a proposed private internal drainage system on the site. Include the depths and locations of structures and the type of pipe to be used. (POLICY AND MGO 10.29)
14. The area adjacent to this development is subject to backwater flooding from Lake Monona. Minimum entrance elevations for ramps to underground parking and to entrances shall be set at elevation 852.00. Structure exposed below this elevation shall be constructed of water resistant materials such as concrete or brick.
15. The proposed development proposes to construct underground parking. The proposed entrance to the underground parking is adjacent to a street low point. The applicant shall provide at a minimum of one (1) foot of rise from the adjacent back of walk in the driveway before breaking grade to the down ramp to the underground parking to protect the underground parking from inundation.
16. Provide additional detail how the enclosed depression(s) created by the parking entrance(s) to the below building parking area(s) is/are served for drainage purposes. The building must be protected from receiving runoff up through the 100-yr design storm that is current in Madison General Ordinance Chapter 37. If the enclosed depression(s) is/are to be served by a gravity system provide calculations stamped by a Wisconsin P.E. that show inlet and pipe capacities meet this requirement. If the enclosed depression(s) is/are to be served by a pump system provide pump sizing calculations stamped by a Wisconsin P.E. or licensed Plumber that show this requirement has been met.

17. This project falls in the area subject to increased erosion control enforcement as authorized by the fact that it is in a TMDL ZONE and therefore will be regulated to meet a higher standard.

This project will disturb 4,000 sf or more of land area and require an Erosion Control Permit. Submit the Erosion Control Permit Application (with USLE calculations and associated fee) to Megan Eberhardt (west) at [meberhardt@cityofmadison.com](mailto:meberhardt@cityofmadison.com), or Daniel Olivares (east) at [daolivares@cityofmadison.com](mailto:daolivares@cityofmadison.com), for approval. The permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

This project will disturb 20,000 sf or more of land area and require an Erosion Control Plan. Please submit an 11" x 17" copy of an erosion control plan (pdf electronic copy preferred) to Megan Eberhardt (west) at [meberhardt@cityofmadison.com](mailto:meberhardt@cityofmadison.com), or Daniel Olivares (east) at [daolivares@cityofmadison.com](mailto:daolivares@cityofmadison.com), for approval.

Demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. Include Universal Soil Loss Equation (USLE) computations for the construction period with the erosion control plan. Measures shall be implemented in order to maintain a soil loss rate below 5.0 tons per acre per year. The WDNR provided workbook to compute USLE rates can be found online at <https://dnr.wi.gov/topic/stormwater/publications.html>

This project will require a concrete management plan and a construction dewatering plan as part of the erosion control plan to be reviewed and approved by the City Engineer's Office. If contaminated soil or groundwater conditions exist on or adjacent to this project additional WDNR, Public Health, and/or City Engineering approvals may be required prior to the issuance of the required Erosion Control Permit. (POLICY)

This project appears to require fire system testing that can result in significant amounts of water to be discharged to the project grade. The Contractor shall coordinate this testing with the erosion control measures and notify City Engineering 608-266-4751 prior to completing the test to document that appropriate measures have been taken to prevent erosion as a result of this testing.

Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.

18. Submit, prior to plan sign-off but after all revisions have been completed, a digital CAD file (single file) to the Engineering Division that is to scale and represents final construction with any private storm and sanitary sewer utilities.
19. Submit, prior to plan sign-off but after all revisions have been completed, digital PDF files to the Engineering Division. Email PDF file transmissions are preferred to: [bstanley@cityofmadison.com](mailto:bstanley@cityofmadison.com) (East) or [ttroester@cityofmadison.com](mailto:ttroester@cityofmadison.com) (West).

**Please contact Jeffrey Quamme, of the City Engineering–Mapping Section at 266-4097 if you have any questions regarding the following five (5) items:**

20. Applicant shall provide proof that the communications utility is satisfied that their ability to access the communication facilities granted to Wisconsin Bell per Document No. 2414694 is adequate.
21. Applicant shall be solely responsible for any agreement with the lands to the south of this site necessary for the construction and maintenance of the proposed retaining wall proposed near the south property line for the underground parking entrance.
22. Provide a Plat of Survey completed by a Professional Land Surveyor of the property as there are site improvements proposed to be constructed abutting the right of way of E Lakeside St and Sayle Street.
23. The address of 133 E Lakeside St will be retired with the demolition of the VFW building. The address of the commercial tenant is 121 E Lakeside St. The base address of the apartments is 1010 Sayle St. If the sidewalk level apartments do not have access to the internal hallway, those units will each have an individual address. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
24. Submit a complete building Floor Plan in PDF format to Lori Zenchenko ([lzenchenko@cityofmadison.com](mailto:lzenchenko@cityofmadison.com)) that includes a floor plan of each floor level on a separate sheet/page for the development of a complete interior addressing plan. The Addressing Plan for the entire project shall be finalized and approved by Engineering (with consultation and consent from the Fire Marshal if needed) prior to the final verification submittal stage of this LNDUSE with Zoning. The approved Addressing Plan shall be included in the final application. For any changes pertaining to the location, deletion or addition of a unit, or to the location of a unit entrance, (before, during, or after construction), a revised Address Plan shall be resubmitted to Lori Zenchenko to review addresses that may need to be changed and/or reapproved. The final revised Addressing Plan shall be submitted by the applicant to Zoning to be attached to the final filed approved site plans.

**Please contact Sean Malloy of the Traffic Engineering Division at 266-5987 if you have any questions regarding the following eleven (11) items:**

25. Traffic Engineering has concerns about the proposed on-street parking configuration. The applicant is required to receive Transportation Commission and Board of Public Works approval for the proposed back-in angle on- street parking.
26. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be to engineering scale and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.

27. The Developer shall post a security deposit prior to the start of development. In the event that modifications need to be made to any City owned and/or maintained traffic signals, street lighting, signing, pavement marking and conduit/handholes, the Developer shall reimburse the City for all associated costs including engineering, labor and materials for both temporary and permanent installations.
28. The City Traffic Engineer may require public signing and marking related to the development; the Developer shall be financially responsible for such signing and marking.
29. All parking facility design shall conform to MGO standards, as set in section 10.08(6).
30. All bicycle parking adjacent pedestrian walkways shall have a 2 foot buffer zone to accommodate irregularly parked bicycles and/or bicycle trailers.
31. Per Section MGO 12.138 (14), this project is not eligible for residential parking permits. It is recommended that this prohibition be noted in the leases for the residential units.
32. The applicant shall adhere to all vision triangle requirements as set in MGO 27.05 (No visual obstructions between the heights of 30 inches and 10 feet at a distance of 25 feet behind the property line at streets and 10 feet at driveways.). Alteration necessary to achieve compliance may include but are not limited to; substitution to transparent materials, removing sections of the structure and modifying or removing landscaping elements. If applicant believes public safety can be maintained they shall apply for a reduction of MGO 27.05(2)(bb) - Vision Clearance Triangles at Intersections Corners. Approval or denial of the reduction shall be the determination of the City Traffic Engineer.
33. The applicant shall provide a clearly defined 5' walkway clear of all obstructions to assist citizens with disabilities, especially those who use a wheel chair or are visually impaired. Obstructions include but are not limited to tree grates, planters, benches, parked vehicle overhang, signage and doors that swing outward into walkway.
34. City of Madison radio systems are microwave directional line of sight to remote towers citywide. The building elevation will need to be reviewed by Traffic Engineering to accommodate the microwave sight and building. The applicant shall submit grade and elevations plans if the building exceeds three stories prior to sign-off to be reviewed and approved by Austin Scheib, (266-4768) ([ascheib@cityofmadison.com](mailto:ascheib@cityofmadison.com)) Traffic Engineering Shop, 1120 Sayle Street. The applicant shall return one signed approved building elevation copy to the City of Madison Traffic Engineering office with final plans for sign off.
35. The driveway slope to the underground parking is not identified in the plan set, Traffic Engineering recommends driveway slope under 10%; if the slope is to exceed 10%, the applicant shall demonstrate inclement weather mitigation techniques to provide safe ingress/egress to be approved by the City Traffic Engineer.

**Please contact Jenny Kirchgatter, Assistant Zoning Administrator, at 266-4429 if you have any questions regarding the following eleven (11) items:**

36. Clearly show the useable open space areas on the final plans. The areas of the roof plaza that are not accessible by residents, such as the roof ballast area, will not count toward the useable open space requirement. In addition to showing structured useable open space at roof decks, porches, and balconies, identify each qualifying at-grade usable open space area on the final plans. Roof decks, porches, and balconies may be used to meet up to seventy-five percent (75%) of the minimum open space requirement, provided that minimum dimensional requirements are satisfied.
37. Prior to the use of any outdoor eating area serving a food and beverage establishment, the applicant shall submit for approval a detailed plan for the outdoor eating area that includes the capacity, a seating plan (tables, chairs, capacity, etc.), proposed hours of operation, details for any amplified sound, details for lighting, and the enclosures that will be used to separate the dining area from pedestrians.
38. Section 28.185(7)(a)5. requires that if a demolition or removal permit is approved, it shall not be issued until the reuse and recycling plan is approved by the Recycling Coordinator, Bryan Johnson at [streets@cityofmadison.com](mailto:streets@cityofmadison.com). Every person who is required to submit a reuse and recycling plan pursuant to Section 28.185(7)(a)5. shall submit documents showing compliance with the plan within sixty (60) days of completion of demolition. A demolition or removal permit is valid for one (1) year from the date of the Plan Commission.
39. Show compliance with the building height transition to the rear (west) property line. Where the SE District abuts a residential district, building height at the rear yard setback line shall not exceed two (2) stories/twenty-five (25) feet. From this point, building height may increase at a ratio of one foot of rise to one foot of horizontal distance away from the property line, (a 45° angle) up to the maximum allowed height.
40. The entire development must reflect compliance in the required number of bicycle parking spaces, to be reviewed prior to obtaining zoning approval for each use. Bicycle parking requirements for food and beverage establishments will be based on the capacity or number of occupants as established by the Building Inspection Unit. Provide the capacity of the proposed restaurant-tavern to determine the minimum bicycle parking requirements.
41. Bicycle parking for the commercial tenant space shall comply with the requirements of MGO Sections 28.141(4)(g) and 28.141(11) and will be reviewed prior to obtaining zoning approval for each use. Provide a minimum of two (2) short-term bicycle parking stalls located in a convenient and visible area on a paved or pervious surface. Bicycle parking shall be located at least as close as the closest non-accessible automobile parking and within one hundred (100) feet of a principal entrance.
42. Bicycle parking for the residential dwelling units shall comply with the requirements of MGO Sections 28.141(4)(g) Table 28I-3 and 28.141(11) and shall be designated as short-term or long-term bicycle parking. A minimum of 66 resident bicycle stalls are required plus a minimum of 7 short-term guest stalls. Up to twenty-five percent (25%) of bicycle parking may be structured parking, vertical parking or wall mount parking, provided there is a five (5) foot access aisle for wall mount parking. NOTE: A bicycle stall is a minimum of two (2) feet by six (6) feet with a five (5) foot wide access area. Submit a detail showing the model of bike rack to be installed.

43. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect.
44. Screening is required adjacent the Zoning district boundary along the west property line. Screening shall be provided along side and rear property boundaries between employment districts and residential districts. Screening shall consist of a solid wall, solid fence, or hedge with year-round foliage, between six (6) and eight (8) feet in height. Submit a detail of the screening fence with the final plans.
45. Per Section 28.186(4)(b), the property owner or operator is required to bring the property into compliance with all elements of the approved site plans by the date established by the Zoning Administrator as part of the site and building plan approval. Work with Zoning staff to establish a final site compliance date.
46. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances and Chapter 33 Urban Design District ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.

**Please contact Bill Sullivan of the Madison Fire Department at 261-9658 if you have any questions regarding the following three (3) items:**

47. Provide an egress path out to the public way from Stair B.
48. Obtain permission to modify the public street from the other City Agencies. If the public interests doesn't align, then the development is responsible to provide other means to comply with the minimum safety standards.
49. Please consider allowing Madison Fire Dept. to conduct training sequences prior to demolition. Contact MFD Training Division to discuss possibilities: Division Chief Paul Ripp at [pripp@cityofmadison.com](mailto:pripp@cityofmadison.com) or (608)712-6277.

**Please contact Sarah Lerner of the Parks Division at (608) 261-4281 if you have questions regarding the following item:**

50. Park Impact Fees (comprised of the Park Infrastructure Impact Fee, per MGO Sec. 20.08(2)), and Park-Land Impact Fees, per MGO Sec. 16.23(8)(f) and 20.08(2) will be required for all new residential development associated with this project. This development is within the Central Park-Infrastructure Impact Fee district. Please reference ID# 20016 when contacting Parks about this project.



**Please contact Brad Hofmann of the Forestry Division at (608) 267-4908 if you have questions regarding the following eight (8) items:**

51. An existing inventory of street trees located within the right of way shall be included on the landscape, site, demo, and utility plans. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.
52. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alderperson within who's district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the plan set.
53. As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry (266-4816) prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the plan set.
54. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at 266-4816. Penalties and remediation shall be required. Add as a note on the plan set.
55. Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on the plan set.
56. On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on the plan set.
57. Street tree pruning shall be coordinated with Madison Forestry at a minimum of two weeks prior to the start of construction for this project. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on the plan set.

58. Additional street trees are needed for this project. Tree planting specifications can be found in section 209 of City of Madison Standard Specifications for Public Works Construction - All street tree planting locations and tree species within the right of way shall be determined by City Forestry. A landscape plan (in PDF format) shall be submitted City Forestry for approval of planting locations and tree species. All available street tree planting locations shall be planted within the project boundaries. Add following note to plan: At least one week prior to street tree planting, Contractor shall contact City Forestry at (608) 266-4816 to schedule inspection and approval of nursery tree stock and review planting specifications with the landscaper.

**Please contact Jeff Belshaw of the Madison Water Utility at 261-9835 if you have any questions regarding the following two (2) items:**

59. A Water Service Application Form and fees must be submitted before connecting to the existing water system. Provide at least two working days notice between the application submittal and the requested installation or inspection appointment. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumberscontractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. A Water Meter Application Form will subsequently be required to size & obtain a water meter establish a Water Utility customer account and/or establish a Water Utility fire service account. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

60. The Madison Water Utility shall be notified to remove the water meter at least two working days prior to demolition. Contact the Water Utility Meter Department at (608) 266-4765 to schedule the meter removal appointment.

**Please contact Tim Sobota of Metro Transit at 261-4289 if you have any questions regarding the following item:**

61. Metro Transit operates daily all-day service along Olin Avenue with stops in the Colby Street intersection, approximately 1/4 mile southwest of this property. Prior to service reductions put in place during March of 2020, trips operated up to every 30 minutes - but only passed once an hour each direction middays and evenings during the week, and all day on weekends.

**Please contact my office at (608) 261-9135 if you have questions regarding the following item, which was added by the Plan Commission at their August 10, 2020 meeting:**

62. That staff work with the applicant to reduce the size of the at-grade parking lot to approximately 12 vehicle spaces, giving staff some flexibility in determining the exact number to be provided.

**Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.**

**No interior, exterior or structural demolition or wrecking activities or remodeling activities (including material reclamation activities by the applicant or a third party) shall commence nor any wrecking or building permits be issued until the applicant has met all of the conditions of approval stated in this letter.**

**Please now follow the procedures listed below for obtaining permits for your project:**

1. The applicant shall resubmit a PDF copy of the plan set and any other supporting materials that are necessary, as specified in this letter to [Zoning@cityofmadison.com](mailto:Zoning@cityofmadison.com). (Note: A 20MB email limit applies and multiple transmittals may be required.). A check for the **site plan review fee** shall be mailed to the City of Madison Building Inspection Division; PO Box 2984; Madison, WI 53701-2984.
2. City Agencies who submitted conditions of approval will review your revised plans to verify that their conditions, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.
3. This letter shall be signed by the applicant and property owner (if not the applicant) to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval. [Signature block on last page]
4. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. No alteration of a conditional use shall be permitted unless approved by the Plan Commission provided, however, the Zoning Administrator following consideration by the alderperson of the district, may approve minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the Plan Commission and the conditional use standards. This approval shall become null and void one (1) year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within 6 months of the issuance of said building permit. Where the plans have not been altered from the Plan Commission's approval, and the conditional use has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.

If you have any questions regarding obtaining your demolition or building permits, please contact the Zoning Administrator at (608) 266-4551. If you have any questions or if may be of any further assistance, please do not hesitate to contact my office at (608) 261-9135.

Sincerely,



Chris Wells  
 Planner

<p>I hereby acknowledge that I understand and will comply with the above conditions of approval for this project.</p>  <hr style="border: 0; border-top: 1px solid black; margin-bottom: 5px;"/> <p style="text-align: center;"><i>Signature of Applicant</i></p>  <hr style="border: 0; border-top: 1px solid black; margin-bottom: 5px;"/> <p style="text-align: center;"><i>Signature of Property Owner (if not the applicant)</i></p>
---

- cc: Brenda Stanley, City Engineering Division  
 Jeff Quamme, City Engineering Division- Mapping Section  
 Sean Malloy, Traffic Engineering Division  
 Jenny Kirchgatter, Zoning Administrator  
 Bill Sullivan, Fire Department  
 Sarah Lerner, Parks Division  
 Brad Hofmann, Forestry Division  
 Janine Glaeser, UDC Secretary  
 Jeff Belshaw, Water Utility  
 Bryan Johnson, Streets Division  
 Tim Sobota, Metro Transit

<b>LNDUSE-2020-00056</b>			
<b>For Official Use Only, Re: Final Plan Routing</b>			
<input checked="" type="checkbox"/>	Planning Div. (Wells)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input checked="" type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input checked="" type="checkbox"/>	Water Utility
<input type="checkbox"/>	Metro Transit	<input checked="" type="checkbox"/>	Other: Forestry