


Madison Water Master Plan



Final Draft

Presentation to the
Water Utility Board

November 24, 2020



Water Master Plan

Presentation Outline

- Growth Projections
- Historic Water Demands
- Conservation Impacts
- Projected Water Needs
- System Analysis
- Capital Improvement Program



Water Master Plan

Executive Summary

- Master Plan meets WUB Policy for Long Term Planning
- Service Area Population may increase by 24% by 2040
- Water conservation is expected to continue and to improve
 - ✓ System Annual Avg Water demand may increase: 0% to 13%
 - ✓ Drought Max Day to Avg Day demand ratios may decrease 8%
- System is in good shape for fire flow, avg day supply, & pressure
- Drought conditions may stress supply during periods of max demand
- Projects: water quality & facility renewal: \$60M over next 20 yrs
- Pipelines: Renew 7.1 miles per year @ \$9.7M/yr




Water Master Plan

Population Projections

Table 2-3: Draft Population Estimates Provided by DPCED

| Year | 10-Estimate Average | 10-Estimate Average | High Estimate | High Estimate | Low Estimate | Low Estimate |
|---------------------------|---------------------|---------------------|---------------|---------------|--------------|--------------|
| | Population | Households | Population | Households | Population | Households |
| 2015 | 244,704 | 109,885 | 248,956 | 113,500 | 241,177 | 108,151 |
| 2020 | 256,496 | 116,099 | 265,756 | 120,798 | 247,919 | 112,690 |
| 2025 | 269,510 | 122,971 | 283,695 | 130,135 | 254,850 | 116,904 |
| 2030 | 282,622 | 129,454 | 302,844 | 139,560 | 261,975 | 120,726 |
| 2035 | 295,575 | 136,266 | 323,287 | 150,366 | 269,299 | 125,255 |
| 2040 | 309,768 | 143,135 | 345,109 | 161,266 | 276,828 | 129,359 |
| Annual Growth Rate | 0.95% | 1.06% | 1.31% | 1.41% | 0.55% | 0.72% |



Water Master Plan


Historic Water Demand

Table 3-1: Historical Water Production

| Year | AD (mgd) | MD (mgd) | MD:AD Ratio | MinD (mgd) | MinD:AD Ratio |
|------------------------|-------------|-------------|-------------|-------------|---------------|
| 2007 | 31.2 | 54.0 | 1.73 | 22.4 | 0.72 |
| 2008 | 29.9 | 45.1 | 1.51 | 21.1 | 0.70 |
| 2009 | 28.4 | 41.9 | 1.48 | 18.4 | 0.65 |
| 2010 | 28.1 | 39.8 | 1.42 | 18.3 | 0.65 |
| 2011 | 28.3 | 43.0 | 1.52 | 18.6 | 0.66 |
| Last Drought Year 2012 | 29.2 | 49.9 | 1.71 | 16.5 | 0.56 |
| 2013 | 27.6 | 43.1 | 1.56 | 18.9 | 0.69 |
| 2014 | 27.7 | 45.0 | 1.63 | 15.6 | 0.56 |
| 2015 | 27.3 | 39.8 | 1.46 | 19.8 | 0.73 |
| 2016 | 27.0 | 38.3 | 1.42 | 19.5 | 0.72 |
| Maximum | 31.2 | 54.0 | 1.73 | 22.4 | 0.73 |
| 90th Percentile | 30.0 | 50.3 | 1.71 | 21.2 | 0.72 |
| 5-year Average | 27.7 | 43.2 | 1.56 | 18.1 | 0.65 |
| Minimum | 27.0 | 38.3 | 1.42 | 15.6 | 0.56 |




Historic Water Demand



2012 Seasonal Water Use



Appendix C-6: Year 2012 7-Day Average AD Demand, Precipitation & High Temperature Data



Water Conservation – How low can you go?

Table 3-7: **Indoor** Conservation Potential - Per Capita Water Use

| Water Use | REU 1999 | REU 2016 | 2007 CP | High Eff. |
|---------------------|-------------|-------------|-------------|-------------|
| Showers | 11.6 | 11.1 | 8.8 | 8.4 |
| Clothes Washers | 15 | 9.6 | 10 | 4.7 |
| Dishwashers | 1 | 0.7 | 0.7 | 0.4 |
| Toilets | 18.5 | 14.2 | 8.2 | 6.1 |
| Baths | 1.2 | 1.5 | 1.2 | 5.8 |
| Leaks | 9.5 | 7.9 | 4 | 3.2 |
| Faucets | 10.9 | 11.1 | 10.8 | 6.5 |
| Other Domestic Uses | 1.6 | 2.5 | 1.6 | 1.6 |
| TOTAL | 69.3 | 58.6 | 45.3 | 36.7 |

1999 report, Residential end use of water (REU 1999)
 2016 report, Residential end use of water, Version 2 (REU 2016)
 2007 Madison Water Conservation Plan (Vickers, Amy. 2002. Handbook of Water Use and Conservation: Homes, Landscapes, Industries, Businesses, Farms.
 High Eff from 2016 report, Residential end use of water, Version 2 (REU 2016)

Madison 2020
 Madison Residential: 50.8 gpcpd
 Est. Indoor Use: 45.3 gpcpd
 Avg Annual Outdoor Use: 5.5 gpcpd*
 * Assume Outdoor annual average is constant
 Est. Lowest Indoor Use: 36.7 gpcpd
 Projected Lower Limit 42.2 gpcpd

Speculated Lowest Projection:
2040 Avg Day: 27.8 MG


Based on Residential demands for Single Family and Duplex Homes




Water Conservation



Figure 3-2: Estimated Total Indoor Water Use - Based on Minimum Month Production



Growth Location




TAZ Population Increase (2010 to 2040)
WATER NEEDS ASSESSMENT
Madison, Wisconsin

Appendix A-6


Average Day Demands – Drought Year

- Projections are typically expressed as a range based on past data.
- Actual conditions and trends in the future are unknown.



Maximum Day Demands – Drought Year

- Projections are typically expressed as a range based on past data.
- Actual conditions and trends in the future are unknown.



Hydraulic Analysis Criteria

- Use AMI water demand data
- Recalibrate the system computer model to current conditions
- Develop manageable analysis areas
 - ✓ Regions and Geographical Areas
- Assume 3 wells are out of service in the analysis area
- WUB policy requires redundancy and reliability
- Evaluate Avg Day, Max Day, Max 10-Day demand patterns
- Fire Flow capacity
- Water Transfer Potential between zones




Water Master Plan

Modeling Analysis

- Identify System Deficiencies
- Design Period
 - ✓ 2020 = Short Term
 - ✓ 2040 = Long Term
- Extended Period Computer Simulation – Max 10 Day
- Develop Alternatives to Mitigate Deficiencies
- Test Alternatives
- Refine Alternative and Retest



Water Master Plan




Water Supply Mass Balance

- Evaluate regional water demand projections
- ID areas of need
- ID areas of surplus
- Evaluate pumping water from area of surplus to area of need
- Consolidate geographical areas, east and west
- Develop alternatives that mitigate deficiencies



Demand Projections by Region



Mass Balance – Region D - (Zones 6w, 7 & 9)

| Supply Capacity Analysis | Design Year | | | | |
|--|-------------|-------------|-------------|-------------|-------------|
| | 2020 | 2025 | 2030 | 2035 | 2040 |
| Condition 1 - Average Day Capacity | | | | | |
| Average Day Demand (mgd) ² | 4.5 | 4.7 | 4.8 | 5.0 | 5.1 |
| Existing 12-Hour Pumping Capacity (mgd) ³ | 4.6 | | | | |
| 12-Hour Capacity Mass Balance (mgd) ⁴ | 0.1 | -0.1 | -0.2 | -0.4 | -0.5 |
| Condition 2a - Maximum Day Capacity | | | | | |
| Maximum Day Demand (mgd) ¹ | 10.1 | 10.8 | 11.5 | 12.2 | 12.9 |
| Existing Firm Supply Capacity (mgd) ³ | 6.0 | | | | |
| Firm Capacity Mass Balance (mgd)⁴ | -4.1 | -4.8 | -5.5 | -6.2 | -6.9 |
| Condition 2b - 115 % Maximum Day Capacity | | | | | |
| 115 % Maximum Day Demand (mgd) | 11.6 | 12.4 | 13.2 | 14.0 | 14.8 |
| Existing Total Pumping Capacity (mgd) ³ | 9.2 | | | | |
| 115 % Max Day Capacity Mass Balance (mgd) ⁴ | -2.4 | -3.2 | -4.0 | -4.8 | -5.6 |



¹ See Appendix G of Chapter 2-2 (*Water Needs Analysis Report*).

² See Appendix F of Chapter 2-2.

³ See Appendix D of Chapter 3 (*Hydraulic Analysis Report*).

⁴ Positive numbers equals the potential pumping capacity surplus. Negative numbers equal the pumping capacity deficit.

EAST SIDE ANALYSIS


| Supply Capacity Analysis | Design Year | | | | |
|--|-------------|-------------|-------------|-------------|-------------|
| | 2020 | 2025 | 2030 | 2035 | 2040 |
| Condition 1 - Average Day Capacity | | | | | |
| Average Day Demand (mgd) ² | 10.9 | 11.2 | 11.5 | 11.7 | 12.0 |
| Existing 12-Hour Pumping Capacity (mgd) ³ | 13.8 | | | | |
| 12-Hour Capacity Mass Balance (mgd)⁴ | 2.9 | 2.6 | 2.3 | 2.1 | 1.8 |
| Condition 2a - Maximum Day Capacity | | | | | |
| Maximum Day Demand (mgd) ¹ | 18.5 | 19.3 | 20.1 | 20.9 | 21.6 |
| Existing Firm Supply Capacity (mgd) ³ | 15.4 | | | | |
| Firm Capacity Mass Balance (mgd)⁴ | -3.1 | -3.9 | -4.7 | -5.5 | -6.2 |
| Condition 2b - 115 % Maximum Day Capacity | | | | | |
| 115 % Maximum Day Demand (mgd) | 21.3 | 22.2 | 23.1 | 24.0 | 24.9 |
| Existing Total Pumping Capacity (mgd) ³ | 24.4 | | | | |
| 115 % Max Day Capacity Mass Balance (mgd)⁴ | 3.1 | 2.2 | 1.3 | 0.4 | -0.5 |



- ¹ See Appendix G of Chapter 2-2 (Water Needs Analysis Report).
- ² See Appendix F of Chapter 2-2.
- ³ See Appendix D of Chapter 3 (Hydraulic Analysis Report).
- ⁴ Positive numbers equals the potential pumping capacity surplus. Negative numbers equal the pumping capacity deficit.

2020 Mass Balance East Side

3 Wells Out #25, 31, 13



WEST SIDE ANALYSIS


| Supply Capacity Analysis | Design Year | | | | |
|--|-------------|-------------|-------------|-------------|-------------|
| | 2020 | 2025 | 2030 | 2035 | 2040 |
| Condition 1 - Average Day Capacity | | | | | |
| Average Day Demand (mgd) ² | 18.3 | 18.5 | 18.7 | 18.9 | 19.0 |
| Existing 12-Hour Pumping Capacity (mgd) ³ | 19.6 | | | | |
| 12-Hour Capacity Mass Balance (mgd)⁴ | 1.3 | 1.1 | 0.9 | 0.7 | 0.6 |
| Condition 2a - Maximum Day Capacity | | | | | |
| Maximum Day Demand (mgd) ¹ | 33.3 | 34.4 | 35.4 | 36.4 | 37.4 |
| Existing Firm Supply Capacity (mgd) ³ | 29.9 | | | | |
| Firm Capacity Mass Balance (mgd)⁴ | -3.4 | -4.5 | -5.5 | -6.5 | -7.5 |
| Condition 2b - 115 % Maximum Day Capacity | | | | | |
| 115 % Maximum Day Demand (mgd) | 38.3 | 39.5 | 40.7 | 41.8 | 43.0 |
| Existing Total Pumping Capacity (mgd) ³ | 39.3 | | | | |
| 115 % Max Day Capacity Mass Balance (mgd)⁴ | 1.0 | -0.2 | -1.4 | -2.5 | -3.7 |




- 1 See Appendix G of Chapter 2-2 (*Water Needs Analysis Report*).
- 2 See Appendix F of Chapter 2-2.
- 3 See Appendix D of Chapter 3 (*Hydraulic Analysis Report*).
- 4 Positive numbers equals the potential pumping capacity surplus. Negative numbers equal the pumping capacity deficit.

2020 Mass Balance West Side

3 Wells Out #12, 18, 26



Deficiencies Analysis




Project: MADWU 130027
Print Date: 12/13/2018

Water System Deficiency Summary
Hydraulic Analysis Report
Madison, Wisconsin

Figure 6-11

Alternative Map



Project: MADWU 130027
Print Date: 12/13/2018

Water System Improvement Alternatives
Alternative Analysis Report
Madison, Wisconsin

Figure A1

Prelim Alternative Analysis



ALTERNATIVE S.E.08 - UNIT WELL & FILTRATION PLANT

WATER SYSTEM NEEDS
With 3 facilities offline on the East side, the east side is expected to have a 2020 maximum day demand supply shortage of 3.1 MGD while the West side may have a surplus of 6.0 MGD. The East side water deficit includes -8.3 MGD in region B and -2.8 MGD in region A.

DEFICIENCIES SUMMARY
Removal of well from service will require the construction of a replacement well.

PROJECT DETAILS
The proposed Unit Well & Filter Plant project would address water quality issues in Unit Well 8. This well is a major water supply for Zone 6e, and the east side. Replacing Unit Well 8 with a new unit well would be difficult as groundwater contamination has been documented in the area, and neighborhoods and parks would make permitting and public acceptance challenging to achieve. The project would allow for the continued utilization of Unit Well 8 by constructing a 2.4 MGD filtration plant located at the well improve the water quality.

2040 Impacts By 2040 The West Side will only be estimated to have an available surplus of 1.9 MGD. As a result it is expected that a new well supply source in the west would be required to support west to east water transfer. Additionally, another well source in the east would be needed to satisfy the anticipated 6.2 MGD deficit in the east. If Well 8 is not maintained, an additional well would need to be constructed in its place.

PROPOSED ALTERNATIVE SCHEMATIC


Advantages
Allow for the continued use of Unit Well 8
Improve water quality from Unit Well 8
Location of facility from a hydraulic perspective (near exhaust) is beneficial.
Known quantity of water available
Satisfies neighborhoods desire for treated water nearby.

Disadvantages
Complete reconstruction of building facility will be required
Existing facility site has space constraints
New facility may be intrusive
Permitting may be difficult
High profile site
Existing storage tank may need rehab or replacement.

COST

| Item | Qty | Unit Price | Total | Project Total (M) |
|---------------------------------------|-----|------------|-----------|-------------------|
| Water Treatment Facility Construction | 1 | \$ | 7,200,000 | \$8.2 M |
| Special Site Accommodations | 1 | \$ | 1,000,000 | |

FIGURE S.E.08
UNIT WELL & FILTRATION PLANT
Service to the East



Ranking of 37 Alternatives

Table 7-1 - Alternative Project Ranking

| Project # | Project Name | Project Planning Review | Weighted Score |
|-----------|--|-------------------------|----------------|
| SE-01 | Booster Pumping Station 124 | 2025 | 49.7 |
| SE-02 | Connect UWB to 3 Zone Well (Zones 6e/6f) | 2020 | 39.6 |
| SE-03 | Lake Monona Pipe Crossing | NA | 21.0 |
| SE-04 | City of Monona Transmission Main | 2025 | 28.8 |
| SE-05 | Unit Well 23A - Federal Rd | 2025 | 43.9 |
| SE-06 | Unit Well 23B - Shaughton Rd/Muskegon Street | 2025 | 52.8 |
| SE-07 | Unit Well 13C - Buckeye Road | 2025 | 58.7 |
| WSE-01 | Reconstruction and Upgrade of Unit Well 8 | 2025 | 60.8 |
| WSE-02 | Unit Well Treatment Upgrades | 2025 | 63.6 |
| SW-01 | Unit Well 32 - Fair Street Side | 2022 | 66.3 |
| SW-02 | Unit Well 24 - Whitney Way and Mineral Point | 2022 | 67.0 |
| SW-03 | Unit Well 35 - Co Hwy M and Midtown Road | 2022 | 50.1 |
| SW-04 | Internal Transmission Main to Well 24 | 2025 | 38.0 |
| SW-05 | Yahara River PRV | 2025 | 45.9 |
| WGW-01 | Water Treatment addition at Unit Well 19 | 2025 | 42.7 |
| WGW-02 | Water Treatment, Well 1 and Well 19 | 2025 | 67.5 |
| WGW-03 | New University Well to Replace Well 19 | 2025 | 50.2 |
| WGW-05 | Water Treatment addition at Unit Well 14 | 2030 | 49.5 |
| WGW-06 | Replace Well 14 | 2030 | 59.3 |
| TE-01 | Upgrade BPS 213 | 2020 | 51.1 |
| TE-02 | Replace BPS 120 | 2020 | 55.3 |
| TW-01 | Booster Pumping Station 109 | 2030 | 39.0 |
| TW-02 | Booster Pumping Station 114 | 2030 | 39.4 |
| TW-03 | Booster Pumping Station 134 | 2025 | 47.8 |
| TW-05 | Transmission main from BPS 106 | 2030 | 43.6 |
| TW-04 | BPS 112 | 2020 | 51.3 |
| TRW-01 | Unit Well 12 Upgrade and Connection to 8 Two Zone Well | 2020 | 56.3 |
| TW-06 | BPS 120 Upgrade | 2025 | 51.2 |
| TW-08 | BPS at Well 19 site | 2030 | 28.5 |
| TW-07 | 29th St PRV @ Raymond Rd | 2020 | 46.0 |
| TW-09 | BPS 200 @ Elver Park | 2030 | 44.2 |
| TW-10 | BPS 106 Discharge line to 8 | 2030 | 37.4 |
| TW-03 | After 15th Street Road Water Main Upgrade | 2030 | 48.0 |
| TW-11 | Raymond Road Water Main Upgrade | 2030 | 48.0 |
| TW-12 | Ador Hills Carbon Ball Pipeline Molds | 2030 | 57.4 |
| TW-13 | Booster Station 120 Upgrade | 2030 | 44.0 |



Definitions for the Triple Bottom Line

| | | Total Points Available | Weighted Value |
|---------------------------------|---|------------------------|----------------|
| Environmental/Regulatory | | 30.0% | 300 |
| | Regulatory/Board Policy | 15.0% | 100 |
| | City Sustainability Policy | 5.0% | 100 |
| | Environmental/Community/Neighborhood Impact | 10.0% | 100 |
| Financial | | 30.0% | 500 |
| | Benefit/Cost Efficiency | 10.0% | 100 |
| | Operational Improvement | 2.5% | 100 |
| | Risk Reduction | 12.5% | 100 |
| | Supplemental Benefits (e.g. innovation) | 2.5% | 100 |
| | Coordination with other projects | 2.5% | 100 |
| Social/Community | | 30.0% | 600 |
| | Public Trust | 3.0% | 100 |
| | Customers/Critical Customers Benefitted | 3.0% | 100 |
| | Water Quality | 13.0% | 100 |
| | System Growth & Capacity | 3.0% | 100 |
| | Public Health & Safety | 3.0% | 100 |
| | City Equity Policy | 5.0% | 100 |
| Engineering/Construction | | 10.0% | 300 |
| | Siting & Permitting Feasibility | 3.4% | 100 |
| | Operation and Maintenance Complexity | 3.3% | 100 |
| | Constructability | 3.3% | 100 |
| TOTAL | | 100.0% | 1700 |

Capital Improvement Program - Facilities

| Rank | # | Alternative Title | Score | Year | Budget Cost (\$Million) |
|------|--------|--|-------|------|-------------------------|
| 1 | WQW-01 | Water Treatment addition at Unit Well 19 | 63 | 2023 | \$6.5 |
| 2 | TW-04 | Unit Well 12 Upgrade and Conversion to a Two Zone Well | 56 | 2024 | \$4.5 |
| 3 | TE-01 | Upgrade BPS 213 | 51 | 2025 | \$2.3 |
| 4 | WQE-01 | Reconstruction and Upgrade of Unit Well 8 to 3 zone well | 61 | 2027 | \$11.8 |
| 5 | TW-05 | BPS 128 Upgrade | 51 | 2029 | \$0.8 |
| 6 | SW-01 | Unit Well 32 - Far West Side | 66 | 2030 | \$9.9 |
| 7 | WQW-08 | Well 30 Fe and Mn Filter | 60 | 2032 | \$5.5 |
| 8 | WQW-06 | Relocate Well 14 | 59 | 2034 | \$7.9 |
| 9 | TW-12 | Arbor Hills Cannon Ball Pipeline Mods | 57 | 2036 | \$1.4 |
| 10 | TE-02 | Relocate BPS 129 | 55 | 2038 | \$3.1 |
| 11 | WQW-07 | Well 28 Fe and Mn Filter | 54 | 2040 | \$6.5 |
| 12 | WQW-10 | Well 27 Fe, Mn & Radium Filter | 54 | 2042 | \$6.5 |
| 13 | WQW-09 | Well 18 Air Stripper | 53 | 2044 | \$5.0 |
| 14 | WQW-10 | Well 17 Fe and Mn Filter | 52 | 2046 | \$8.0 |
| 15 | WQW-10 | Well 24 Fe and Mn Filter | 51 | 2048 | \$6.5 |



Water Master Plan


Capital Improvement Program - Pipelines

| | | Annual Cost (2020 Dollars) |
|------------------------------------|----------------|-------------------------------|
| Annual Pipe Renewal Program | | |
| Pipe Replacement (Miles): | 7.1 | |
| Pipe Replacement: | 75% | 7,254,000 |
| | New Pipe: | 10% |
| | Pipe Lining: | 25% |
| | Annual Budget: | 9,662,000 |



Water Master Plan

Madison Water Master Plan



Questions?



Water Master Plan