



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

215 Martin Luther King Jr. Boulevard

P.O. Box 2985

Madison, Wisconsin 53701-2985

Phone: (608) 266-4635

Fax (608) 267-8739

www.cityofmadison.com

May 25, 2021

Melissa Destree

Destree Design Architects, Inc.

222 W Washington Avenue

Madison, WI 53703

RE: Legistar #64900; Accela ID: 'LNDUSE-2021-00027' -- Approval of a conditional use for lakefront development to construct a new park shelter (accessory building) for Tenney Beach at 1330 Sherman Avenue.

Dear Ms. Destree

At its May 24, 2021 meeting, the Plan Commission, meeting in regular session, found the standards met and approved your conditional use request to construct a new park shelter (accessory building) in the Parks and Recreation (PR) Zoning District on a lakefront property at 1330 Sherman Avenue. In order to receive final approval of the conditional use, and for any permits to be issued for your project, the following conditions shall be met:

Please contact Brenda Stanley of the Engineering Division at (608) 261-9127 if you have any questions regarding the following five (5) items:

1. Madison Metropolitan Sewerage District (MMSD) charges are due and payable prior to Engineering sign-off, unless otherwise collected with a Developer's / Subdivision Contract. Contact Mark Moder (608-261-9250) to obtain the final MMSD billing a minimum of two (2) working days prior to requesting City Engineering signoff. (MGO 16.23(9)(d)(4))
2. Obtain a permanent sewer plug permit for each existing sanitary sewer lateral serving a property that is not to be reused and a temporary sewer plug permit for each sewer lateral that is to be reused by the development. The procedures and fee schedule is available online at <http://www.cityofmadison.com/engineering/permits.cfm>. (MGO CH 35.02(14))
3. An Erosion Control Permit is required for this project. See Storm comments for permit specific details and requirements.
4. Revise the site plan to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service. (POLICY)

5. This project will disturb 4,000 sf or more of land area and require an Erosion Control Permit. Submit the Erosion Control Permit Application (with USLE calculations and associated fee) to Megan Eberhardt (west) at meberhardt@cityofmadison.com, or Daniel Olivares (east) at daolivares@cityofmadison.com, for approval. The permit application can be found on City Engineering's website at <http://www.cityofmadison.com/engineering/Permits.cfm>.

Complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website - as required by Chapter 37 of the Madison General Ordinances.

Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following item:

6. All parking facility design shall conform to MGO standards, as set in section 10.08(6).

Please contact Jacob Moskowitz, the Assistant Zoning Administrator at (608) 266-4560 if you have any questions regarding the following item:

7. Filling, grading and excavation of the zoning lot may be permitted only where protection against erosion, sedimentation and impairment of fish and aquatic life has been assured. Obtain necessary erosion control permits.

Please contact Bill Sullivan of the Fire Department at (608) 886-4691 if you have any questions regarding the following item:

8. Provide fire access lanes in accordance with Madison General Ordinances Chap 34 & the International Fire Code.

Please contact Brad Hofmann of City Forestry at (608) 267-4908 if you have any questions regarding the following seven (7) items:

9. Contractor shall take precautions during construction to not disfigure, scar, or impair the health of any street tree. Contractor shall operate equipment in a manner as to not damage the branches of the street tree(s). This may require using smaller equipment and loading and unloading materials in a designated space away from trees on the construction site. Any damage or injury to existing street trees (either above or below ground) shall be reported immediately to City Forestry at 266-4816. Penalties and remediation shall be required. Add as a note on the plan set.
10. Excavation As defined by the Section 107.13 of City of Madison Standard Specifications for Public Works Construction: No excavation is permitted within 5 feet of the trunk of the street tree or when cutting roots over 3 inches in diameter. If excavation is necessary, the Contractor shall contact Madison City Forestry (266-4816) prior to excavation. City of Madison Forestry personnel shall assess the impact to the tree and to its root system prior to work commencing. Tree protection specifications can be found on the following website: <https://www.cityofmadison.com/business/pw/specs.cfm> Add as a note on the plan set.

11. Protection On this project, street tree protection zone fencing is required. The fencing shall be erected before the demolition, grading or construction begins. The fence shall include the entire width of terrace and, extend at least 5 feet on both sides of the outside edge of the tree trunk. Do not remove the fencing to allow for deliveries or equipment access through the tree protection zone. Add as a note on the plan set.
12. Pruning Street tree pruning shall be coordinated with Madison Forestry at a minimum of two weeks prior to the start of construction for this project. All pruning shall follow the American National Standards Institute (ANSI) A300 - Part 1 Standards for pruning. Add as a note on the plan set.
13. Soil Section 107.13(g) of City of Madison Standard Specifications for Public Works Construction addresses soil compaction near street trees and shall be followed by Contractor. The storage of parked vehicles, construction equipment, building materials, refuse, excavated spoils or dumping of poisonous materials on or around trees and roots within five (5) feet of the tree or within the protection zone is prohibited. Add as a note on the plan set.
14. All proposed street tree removals within the right of way shall be reviewed by City Forestry before the Plan Commission meeting. Street tree removals require approval and a tree removal permit issued by City Forestry. Any street tree removals requested after the development plan is approved by the Plan Commission or the Board of Public Works and City Forestry will require a minimum of a 72-hour review period which shall include the notification of the Alder person within whose district is affected by the street tree removal(s) prior to a tree removal permit being issued. Add as a note on the plan set.
15. An existing inventory of street trees located within the right of way shall be included on the landscape, site, demo, and utility plans. The inventory shall include the following: location, size (diameter at 4 1/2 feet), and species of existing street trees. The inventory should also note if a street tree is proposed to be removed and the reason for removal.

Please contact Jeff Belshaw of the Water Utility at (608) 261-9835 if you have any questions regarding the following two (2) items:

16. Madison Water Utility records indicate an existing 1.5" copper service to this property. The utility plan indicates connecting to an existing 2" copper service. Verification is needed to ensure that a 1.5" copper service will be sufficient to serve the future building.
17. A Water Meter Application Form and fees must be submitted before connecting to the existing water lateral. Provide at least two working days notice between the application submittal and the scheduled lateral connection/extension. Application materials are available on the Water Utility's Plumbers & Contractors website (<http://www.cityofmadison.com/water/plumbers-contractors>), otherwise they may be obtained from the Water Utility Main Office at 119 E Olin Ave. A licensed plumber signature is required on all water service applications. For new or replacement services, the property owner or authorized agent is also required to sign the application. If you have questions regarding water service applications, please contact Madison Water Utility at (608) 266-4646.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining your conditional use:

1. After the plans have been revised per the above conditions, please resubmit a PDF copy of the complete, fully dimensioned, and to-scale plans, the appropriate site plan review application and fee pursuant to Section 28.206 of the Zoning Code, and any other documentation requested herein with the Zoning Administrator (zoning@cityofmadison.com). Note that the 20MB email limit still applies. Please mail the check, made out to "City Treasurer", for the site plan review fee to the following address: City of Madison Building Inspection P.O. Box 2984 Madison, WI 53701-2984. Include a cover page with the check, which includes the project address, brief description of the project, and contact information.
2. This property is not in a wellhead protection district. All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility.
3. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting conditional use approval.
4. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. No alteration of a conditional use shall be permitted unless approved by the Plan Commission provided, however, the Zoning Administrator following consideration by the alderperson of the district, may approve minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the Plan Commission and the conditional use standards. This approval shall become null and void one (1) year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within 6 months of the issuance of said building permit. Where the plans have not been altered from the Plan Commission's approval, and the conditional use has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.
5. The Plan Commission retains continuing jurisdiction over all conditional uses for the purpose of resolving complaints against all previously approved conditional uses.

If you have any questions regarding obtaining your conditional use or building permits, please contact the Zoning Administrator at (608) 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at sprusak@cityofmadison.com.

Sincerely,



Sydney Prusak, AICP
Planner

cc: Brenda Stanley, Engineering
Jeffery Quamme, Engineering Mapping
Sean Malloy, Traffic Engineering
Jacob Moskowitz, Zoning
Bill Sullivan, Fire Department
Brad Hofmann, City Forestry
Janine Glaeser, Urban Design Commission
Jeff Belshaw, Water Utility

I hereby acknowledge that I understand and will comply with the above conditions of approval for the conditional use permit.

Signature of Applicant

Signature of Property Owner (if not the applicant)

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Div. (Prusak)	<input checked="" type="checkbox"/>	Engineering Mapping Sec.
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Recycling Coord. (R&R)
<input checked="" type="checkbox"/>	Fire Department	<input type="checkbox"/>	Metro Transit
<input checked="" type="checkbox"/>	Water Utility		