



Department of Planning & Community & Economic Development

Planning Division

Heather Stouder, Director

Madison Municipal Building, Suite 017
215 Martin Luther King Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4635
www.cityofmadison.com

****BY E-MAIL ONLY****

October 7, 2021

Joseph Gallagher
Ramaker
1955 Atwood Avenue, Suite 202
Madison, WI 53704

RE: Consideration of conditional uses to establish a *restaurant-nightclub* in an existing building with an *outdoor eating area* on property zoned Industrial - Limited (IL) District at 2513 Seiferth Road.
(LNDUSE-2021-00084; ID [66977](#))

Dear Joseph,

At its October 4, 2021 meeting, the Plan Commission found the standards met and **approved** your client's conditional use requests for 2415 Seiferth Road. Prior to issuance of permits for the project, the conditions of approval in the following sections shall be satisfied:

Please contact Sean Malloy of the Traffic Engineering Division at (608) 266-5987 if you have any questions regarding the following two (2) items:

1. The applicant shall submit one contiguous plan showing proposed conditions and one contiguous plan showing existing conditions for approval. The plan drawings shall be to engineering scale and include the following, when applicable: existing and proposed property lines; parcel addresses; all easements; vision triangles; pavement markings; signing; building placement; items in the terrace such as signs, street light poles, hydrants; surface types such as asphalt, concrete, grass, sidewalk; driveway approaches, including those adjacent to and across street from the project lot location; parking stall dimensions, including two (2) feet of vehicle overhang; drive aisle dimensions; semitrailer movement and vehicle routes; dimensions of radii; and percent of slope.
2. All parking facility design shall conform to MGO standards, as set in section 10.08(6).

Please contact Jacob Moskowitz of the Zoning Division at (608) 266-4560 if you have any questions regarding the following ten (10) items:

3. The site plan as currently submitted shows no off-street parking. If parking is proposed, show the striping and dimensions on the plans.

4. If off-street parking is provided, parking requirements for persons with disabilities must comply with Section 28.141(4)(e). Final plans shall show the required accessible stalls including van accessible stalls. A van accessible stall is a minimum of 8 feet wide with an 8 foot wide striped access aisle. Show the required signage at the head of the stalls.
5. Bicycle parking for the project shall comply with the requirements of Sections 28.141(4)(g) and 28.141(11). Provide a minimum of 5% of the capacity of the building in short-term bicycle parking stalls located in a convenient and visible area on a paved or impervious surface. Bicycle parking shall be located at least as close as the closest non-accessible automobile parking and within one hundred (100) feet of a principal entrance. Note: A bicycle stall is a minimum two (2) feet by six (6) feet with a five (5) foot wide access area. Provide a detail of the proposed bike rack.
6. Submit the landscape plan and landscape worksheet stamped by the registered landscape architect. Per Section 28.142(3) Landscape Plan and Design Standards, landscape plans for zoning lots greater than ten thousand (10,000) square feet in size must be prepared by a registered landscape architect. Provide adequate development frontage landscaping per section 28.142(5) Development Frontage Landscaping. Landscaping and/or ornamental fencing shall be provided between buildings or parking areas and the adjacent street(s), except where buildings are placed at the sidewalk. Note that landscaping must be installed on the private property.
7. Exterior lighting provided shall be in accordance with City of Madison General Ordinances Section 10.085. Provide an exterior lighting plan and fixture cut sheets with the final plan submittal.
8. Show the trash enclosure area on the site plan. All developments, except single family and two family developments, shall provide a refuse disposal area. Such area shall be screened on four (4) sides (including a gate for access) by a solid, commercial-grade wood fence, wall, or equivalent material with a minimum height of six (6) feet and not greater than eight (8) feet. Submit a detail of the trash enclosure.
9. Meet applicable building/fire codes. The capacity shall be established for the outdoor eating area. Occupancy is established by the Building Inspection Unit. Contact Mike VanErem at 266-4559 to help facilitate this process.
10. If you have a license to sell alcohol in an outdoor eating area, the Alcohol License Review Committee will establish conditions for operation, which involve fencing, security guards, toilet facilities, litter, etc. All businesses that sell alcohol must comply with the requirements imposed by the Alcohol License Review Committee at the time of issuance of your original application to expand or change your licensed premises to include the outdoor eating area. It is your responsibility to have the outdoor service area added to your licensed premise. Please contact the City Clerk's office for assistance with ALRC issues.
11. The restaurant-nightclub and outdoor eating area must comply with all supplemental regulations in Sec. 28.151.
12. Maximum capacity for the restaurant-nightclub to be established by the Director of the Building Inspection Division, not to exceed the number of available seats, plus staff, plus a reasonable number of people waiting for seats.

Please contact Bill Sullivan of the Madison Fire Department at (608) 261-9658 if you have any questions regarding the following item:

13. Provide a detail information on the determination of the occupant load. The recent Liquor License Application LICLIB-2021-00417, estimated the capacity at 286. This submittal seems to imply the occupant load to be less than 100 based on the code analysis that fire sprinkler protection is not required.

Specific questions regarding the comments or conditions contained in this letter should be directed to the commenting agency.

Please now follow the procedures listed below for obtaining permits for your project:

1. After the plans have been revised per the above conditions, please **one (1) complete digital plan set in PDF format** of complete, fully dimensioned, and to-scale plans; the appropriate site plan review application and [site plan review fee \(pursuant to Section 28.206 of the Zoning Code\)](#); and any other documentation requested herein to the Zoning Administrator at zoning@cityofmadison.com. (Note that that an individual email cannot exceed 20MB and it is the responsibility of the applicant to present files in a manner that can be accepted. Please email zoning@cityofmadison.com regarding questions or if you need alternative filing options. The sets of final revised plans or documents will be circulated by Zoning staff to the City department staff listed above for their final approval.
2. The [site plan review fee pursuant to Section 28.206](#) can be mailed in, dropped in the drop box at the Madison Municipal Building, or you can make an appointment at the Zoning counter to pay the fee. Checks should be made out to "City Treasurer." If you mail in the check or use the drop box, please include the application form with the project address and contact information. Zoning staff typically suggest using the drop box or making an appointment with the Zoning counter to pay the fee as they are the quickest.

Mailing Address: City of Madison Building Inspection. P.O. Box 2984. Madison, WI 53701-2984

Drop Box Location: Madison Municipal Building, Doty Street Entrance. 215 Martin Luther King Jr Blvd. Madison, WI 53701-2984

Zoning Counter Appointment: <https://www.cityofmadison.com/dpced/bi/schedule-a-counter-appointment/3423/>

3. City Agencies who submitted conditions of approval will review your revised plans to verify that their conditions, along with any applicable requirements, have been satisfied. When the revised plans are submitted, the applicant will be emailed a hyperlink to a website to follow, in real time, which agencies have reviewed the revised documents, and signed off or need additional information.
4. This letter shall be signed by the applicant and property owner (if not the applicant) to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting building permit approval. [Signature block on last page]

5. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. No alteration of a conditional use shall be permitted unless approved by the Plan Commission provided, however, the Zoning Administrator following consideration by the alderperson of the district, may approve minor alterations or additions which are approved by the Director of Planning and Community and Economic Development and are compatible with the concept approved by the Plan Commission and the conditional use standards. This approval shall become null and void one (1) year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within 6 months of the issuance of said building permit. Where the plans have not been altered from the Plan Commission's approval, and the conditional use has expired, the Director of Planning and Community and Economic Development may, after consultation with the Alderperson of the District, approve an extension for up to 24 months from the expiration date. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.

If you have any questions regarding obtaining your building permits, please contact the Zoning Administrator at (608) 266-4551. If you have any other questions or if you may be of any further assistance, please do not hesitate to contact my office at cwells@cityofmadison.com or (608) 261-9135.

Sincerely,



Chris Wells
 Planner

I hereby acknowledge that I understand and will comply with the above conditions of approval for this project.

Signature of Applicant

Signature of Property Owner (if not the applicant)

cc: Sean Malloy, Traffic Engineering
 Jacob Moskowitz, Zoning Administrator
 Bill Sullivan, Fire Department

| LNDUSE-2021-00084 | | | |
|---|-----------------------|-------------------------------------|--------------------------|
| For Official Use Only, Re: Final Plan Routing | | | |
| <input checked="" type="checkbox"/> | Planning Div. (Wells) | <input checked="" type="checkbox"/> | Engineering Mapping Sec. |
| <input checked="" type="checkbox"/> | Zoning Administrator | <input type="checkbox"/> | Parks Division |
| <input checked="" type="checkbox"/> | City Engineering | <input type="checkbox"/> | Urban Design Commission |
| <input checked="" type="checkbox"/> | Traffic Engineering | <input type="checkbox"/> | Recycling Coord. (R&R) |
| <input checked="" type="checkbox"/> | Fire Department | <input type="checkbox"/> | Water Utility |
| <input type="checkbox"/> | Metro Transit | <input type="checkbox"/> | Other: Forestry |