



Legislation Details (With Text)

File #: 33755 **Version:** 1 **Name:** 2039 Winnebago Street_Basement
Type: Miscellaneous **Status:** Approved
File created: 4/15/2014 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 4/22/2014
Enactment date: **Enactment #:**

Title: 2039 Winnebago Street (C-04-21-2014)
Mark Schmidt, Architect, appealing IBC 1208.2. The rule requires that the minimum ceiling height in a commercial space be 7' 6". The Variance requested is to allow 7' 0" in an existing building. The Madison Fire Department has no comment.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2039 Winnebago St_Basement.pdf

Date	Ver.	Action By	Action	Result
4/22/2014	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

Title
2039 Winnebago Street (C-04-21-2014)
Mark Schmidt, Architect, appealing IBC 1208.2. The rule requires that the minimum ceiling height in a commercial space be 7' 6". The Variance requested is to allow 7' 0" in an existing building. The Madison Fire Department has no comment.