



## Legislation Details (With Text)

**File #:** 74251      **Version:** 1      **Name:** 302 N Yellowstone Dr  
**Type:** Miscellaneous      **Status:** Denied  
**File created:** 10/13/2022      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 11/1/2022  
**Enactment date:**      **Enactment #:**

**Title:** 302 N Yellowstone Dr  
BLDVAR-2022-15359  
The applicant is seeking a variance to SPS 321.05(1) requiring that each habitable room be provided with natural light by means of glazed openings. The applicant would like to remove a window in an existing bedroom, reducing the natural light to less than 8% of the floor area. Alder District #19

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 302 N Yellowstone app.pdf, 2. 302 N Yellowstone plans.pdf

Date	Ver.	Action By	Action	Result
11/1/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Deny	Fail

**Title**

302 N Yellowstone Dr  
BLDVAR-2022-15359  
The applicant is seeking a variance to SPS 321.05(1) requiring that each habitable room be provided with natural light by means of glazed openings. The applicant would like to remove a window in an existing bedroom, reducing the natural light to less than 8% of the floor area. Alder District #19