



## Legislation Details (With Text)

---

**File #:** 40067      **Version:** 1      **Name:** 3402 Kinsman Boulevard  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 9/8/2015      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 9/16/2015  
**Enactment date:**      **Enactment #:**  
**Title:** 3402 Kinsman Boulevard (C-09-43-2015)

Cliff Goodhart of Eppstein Uhen Architects appeals IBC 1008.1.4.4. The variance requested is to allow egress doors to be opened in a sequence so that two doors are not open at the same time. The Madison Fire Department supports the variance with conditions.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 3402 Kinsman Boulevard.pdf

Date	Ver.	Action By	Action	Result
9/16/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

**Title**

3402 Kinsman Boulevard (C-09-43-2015)

Cliff Goodhart of Eppstein Uhen Architects appeals IBC 1008.1.4.4. The variance requested is to allow egress doors to be opened in a sequence so that two doors are not open at the same time. The Madison Fire Department supports the variance with conditions.