



Legislation Details (With Text)

File #: 37295 **Version:** 1 **Name:** 15 W Gorham St
Type: Miscellaneous **Status:** Approved
File created: 2/12/2015 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 2/17/2015
Enactment date: **Enactment #:**

Title: 15 W. Gorham Street (C-02-11-2015)
 Matt Aro of Aro Eberle Architects appealing SPS 366.0602. The rule requires that all new construction comply with railing heights and accessibility rules. The current railings are 32 inches rather than 42 and an existing door 101A is 30 inches wide. The first floor unit is fully accessible.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 15 W Gorham St.pdf

Date	Ver.	Action By	Action	Result
2/17/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

Title
 15 W. Gorham Street (C-02-11-2015)
 Matt Aro of Aro Eberle Architects appealing SPS 366.0602. The rule requires that all new construction comply with railing heights and accessibility rules. The current railings are 32 inches rather than 42 and an existing door 101A is 30 inches wide. The first floor unit is fully accessible.