



## Legislation Details (With Text)

**File #:** 36196      **Version:** 1      **Name:** 2701 S. Stoughton Road  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 11/13/2014      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 11/18/2014  
**Enactment date:**      **Enactment #:**

**Title:** 2701 S. Stoughton Road (C-11-85-2014)  
Steve Roloff of R.A. Smith National appealing IBC 507.4. The rule requires that unlimited area building be separated by 60 feet from other buildings. The Variance requested is to allow an existing building to remain that is less than 60 feet away. Both buildings are fully sprinkled. The Variance is supported by the Madison Fire Department.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 2701 S Stoughton Rd.pdf

Date	Ver.	Action By	Action	Result
11/18/2014	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

### Title

2701 S. Stoughton Road (C-11-85-2014)  
Steve Roloff of R.A. Smith National appealing IBC 507.4. The rule requires that unlimited area building be separated by 60 feet from other buildings. The Variance requested is to allow an existing building to remain that is less than 60 feet away. Both buildings are fully sprinkled. The Variance is supported by the Madison Fire Department.