



## Legislation Details (With Text)

---

**File #:** 37286      **Version:** 1      **Name:** 822 E Washington Ave  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 2/12/2015      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 2/17/2015  
**Enactment date:**      **Enactment #:**

**Title:** 822 E. Washington Avenue (C-02-10-2015)  
Christopher Gosch of Bark Design appealing Section 503.1 of the 2009 IBC. The lowest level below the tower is IIB. The proposal is to separate the IIB from IA with a three hour horizontal fire separation. Three hour vertical fire walls will be used to separate the vertical areas. The Madison Fire Department supports the Variance.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 822 E Washington Ave.pdf

Date	Ver.	Action By	Action	Result
2/17/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

**Title**

822 E. Washington Avenue (C-02-10-2015)  
Christopher Gosch of Bark Design appealing Section 503.1 of the 2009 IBC. The lowest level below the tower is IIB. The proposal is to separate the IIB from IA with a three hour horizontal fire separation. Three hour vertical fire walls will be used to separate the vertical areas. The Madison Fire Department supports the Variance.