



Legislation Details (With Text)

File #: 41759 **Version:** 1 **Name:** 680 Grand Canyon Drive Suite #5
Type: Miscellaneous **Status:** Approved
File created: 2/10/2016 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 2/23/2016
Enactment date: **Enactment #:**

Title: 680 Grand Canyon Drive Suite #5 (C-02-08-2016)
Dan Schmidt of Beltline LLC appealing IBC Section 1010.2. The rule requires that non egress ramps have a slope of less than 1:8. The variance requested is to allow a convenience ramp of 1:6.44. Additional means of safety is being provided with an additional exit from the lower level and additional smoke detector stations.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 680 Grand Canyon Drive Suite #5.pdf

| Date | Ver. | Action By | Action | Result |
|-----------|------|---|---------|--------|
| 2/23/2016 | 1 | BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD | Approve | |

Title

680 Grand Canyon Drive Suite #5 (C-02-08-2016)
Dan Schmidt of Beltline LLC appealing IBC Section 1010.2. The rule requires that non egress ramps have a slope of less than 1:8. The variance requested is to allow a convenience ramp of 1:6.44. Additional means of safety is being provided with an additional exit from the lower level and additional smoke detector stations.