



Legislation Details (With Text)

File #: 35198 **Version:** 1 **Name:** 601 North Street
Type: Miscellaneous **Status:** Approved
File created: 8/13/2014 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 8/19/2014
Enactment date: **Enactment #:**

Title: 601 North Street (C-08-45-2014)
Jane Capito appealing IBC Table 602. The rule requires that a wood structure be 10' from the property line. There are not any wood structures within 10' of the pergola. The Fire Department supports the Variance if the pergola is removed if a structure is built within 20' of the property line.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 601 North St.pdf

Date	Ver.	Action By	Action	Result
8/19/2014	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

Title

601 North Street (C-08-45-2014)

Jane Capito appealing IBC Table 602. The rule requires that a wood structure be 10' from the property line. There are not any wood structures within 10' of the pergola. The Fire Department supports the Variance if the pergola is removed if a structure is built within 20' of the property line.