



Legislation Details (With Text)

File #: 55337 **Version:** 1 **Name:** 1000 Edgewood College Drive
Type: Miscellaneous **Status:** Held in Committee
File created: 4/8/2019 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 3/31/2022
Enactment date: **Enactment #:**

Title: 1000 Edgewood College Dr.
BLDNCC-2013-06890
Michael Guns of Edgewood College is seeking a variance to request a special locking system for after hours for safety issues, such as an active shooter, appealing IBC 1010.1.9, which requires all exit doors to open from the egress side at all times. The City of Madison Fire Department has conditionally approved the variance.
Alder District #13

Sponsors:

Indexes:

Code sections:

Attachments: 1. 1000_edgewood_college_dr_bba.pdf

Date	Ver.	Action By	Action	Result
5/21/2019	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Table	

Title

1000 Edgewood College Dr.
BLDNCC-2013-06890
Michael Guns of Edgewood College is seeking a variance to request a special locking system for after hours for safety issues, such as an active shooter, appealing IBC 1010.1.9, which requires all exit doors to open from the egress side at all times. The City of Madison Fire Department has conditionally approved the variance.
Alder District #13