



Legislation Details (With Text)

File #: 66357 **Version:** 1 **Name:**
Type: Miscellaneous **Status:** Approved
File created: 7/8/2021 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 8/11/2021
Enactment date: **Enactment #:**

Title: 2222 E Washington Ave
BLDVAR-2021-10276
Seeking a variance from 2015 IBC 1017.2 limiting group E buildings to a maximum exit travel distance of 200 feet in non-sprinklered buildings or 250 feet in buildings with sprinkler systems. The property owner is proposing the removal of an interior stairwell in combination with the installation of a full sprinkler system which will result in the reduction of a non-conforming exit travel distance from about 80 feet to 76 feet over the allowable exit travel distance. Alder District 12.

Sponsors:

Indexes:

Code sections:

Attachments: 1. MMSD 3- 2222 E Wash stairs.pdf, 2. Washington Ave 2222 E IBC 1017 MFD Position 7-7-2021.pdf

Date	Ver.	Action By	Action	Result
8/11/2021	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

Title

2222 E Washington Ave
BLDVAR-2021-10276
Seeking a variance from 2015 IBC 1017.2 limiting group E buildings to a maximum exit travel distance of 200 feet in non-sprinklered buildings or 250 feet in buildings with sprinkler systems. The property owner is proposing the removal of an interior stairwell in combination with the installation of a full sprinkler system which will result in the reduction of a non-conforming exit travel distance from about 80 feet to 76 feet over the allowable exit travel distance. Alder District 12.