



Legislation Details (With Text)

File #: 34811 **Version:** 1 **Name:** 155 E. Wilson Street
Type: Miscellaneous **Status:** Approved
File created: 7/9/2014 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 7/15/2014
Enactment date: **Enactment #:**

Title: 155 E. Wilson Street, Unit 102 (C-07-43-2014)
Andrew Sather appealing IBC 1208.2 - Minimum Ceiling Height. The rule requires occupiable space to have a ceiling height of 7' 6". The Variance requested is to allow ceiling height of 6' 9" at the mezzanine. The mezzanine is poured in place concrete and cannot be changed. The Fire Department has no comment.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 155 E Wilson St.pdf

Date	Ver.	Action By	Action	Result
7/15/2014	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

Title

155 E. Wilson Street, Unit 102 (C-07-43-2014)
Andrew Sather appealing IBC 1208.2 - Minimum Ceiling Height. The rule requires occupiable space to have a ceiling height of 7' 6". The Variance requested is to allow ceiling height of 6' 9" at the mezzanine. The mezzanine is poured in place concrete and cannot be changed. The Fire Department has no comment.