



## Legislation Details (With Text)

---

**File #:** 24845      **Version:** 1      **Name:** 652 Bear Claw Way  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 12/14/2011      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 12/20/2011  
**Enactment date:**      **Enactment #:**

**Title:** 652 Bear Claw Way (C-12-70-2011)  
Randy Bruce of Knothe & Bruce Architects appealing Comm 62.3002. The rule requires an elevator shall be sized to accommodate an ambulance stretcher. The Variance requested is to allow the existing shaft construction to remain and a standard elevator be installed. The code changed September 1, 2011; however, the changes were not distributed until October 1st. The internet packet sent out was not complete and did not include these changes.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 652 Bear Claw Way.pdf, 2. 652 Bear Claw Way Attachment.pdf

Date	Ver.	Action By	Action	Result
12/20/2011	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

**Title**

652 Bear Claw Way (C-12-70-2011)  
Randy Bruce of Knothe & Bruce Architects appealing Comm 62.3002. The rule requires an elevator shall be sized to accommodate an ambulance stretcher. The Variance requested is to allow the existing shaft construction to remain and a standard elevator be installed. The code changed September 1, 2011; however, the changes were not distributed until October 1st. The internet packet sent out was not complete and did not include these changes.