



Legislation Details (With Text)

**File #:** 54298      **Version:** 1      **Name:** 465 Science Dr.  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 1/4/2019      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 1/15/2019  
**Enactment date:**      **Enactment #:**

**Title:** 465 Science Dr.  
 BLDNCC-2018-10672  
 Kevin Seton of Affiliated Engineers is seeking an exception to local lighting control as required by Wisconsin Chapter SPS 363 in cGMP contractor development and manufacturing (CDMO) in a laboratory space. The specific section being petitioned is 9.4.1 (a) in ASHRAE 90.1 2013 for local control requirement in laboratory and corridor space types as defined in Table 9.6.1.  
 Alder District 10

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 465\_Science\_dr.pdf

Date	Ver.	Action By	Action	Result
1/15/2019	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

**Title**

465 Science Dr.  
 BLDNCC-2018-10672  
 Kevin Seton of Affiliated Engineers is seeking an exception to local lighting control as required by Wisconsin Chapter SPS 363 in cGMP contractor development and manufacturing (CDMO) in a laboratory space. The specific section being petitioned is 9.4.1 (a) in ASHRAE 90.1 2013 for local control requirement in laboratory and corridor space types as defined in Table 9.6.1.  
 Alder District 10